



Machine Id


**PRESS #8**

Component

**Hydraulic System**


Fluid

**PETRO CANADA HYDREX AW 68 (10000 GAL)**




**COMPONENT CONDITION SUMMARY**

**▲ Particle Trend**



**Non-ferrous Metals**



**RECOMMENDATION**

Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Confirm the source of the lubricant being utilized for top-up/fill. Resample in 30-45 days to monitor this situation. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using Advanced Oil Monitoring (AOM) kits for this system. The AOM test package includes advanced level testing to determine the suitability of turbine and large industrial compressor oils for continued use.

**PROBLEMATIC TEST RESULTS**

Sample Status		SEVERE	SEVERE	SEVERE
Particles >4µm	ASTM D7647 >5000	▲ 130641	▲ 104866	▲ 93866
Particles >6µm	ASTM D7647 >1300	▲ 19661	▲ 12877	▲ 6353
Oil Cleanliness	ISO 4406 (c) >19/17/14	▲ 24/21/14	▲ 24/21/13	▲ 24/20/13

Customer Id: EXTWOO  
Sample No.: PC0087731  
Lab Number: 02641132  
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Kevin Marson +1 (289)291-4644 x4644  
[Kevin.Marson@wearcheck.com](mailto:Kevin.Marson@wearcheck.com)

To change component or sample information:  
Gloria Gonzalez +1 (289)291-4643 x4643  
[gloria.gonzalez@wearcheck.com](mailto:gloria.gonzalez@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component.
Resample	---	---	?	Resample in 30-45 days to monitor this situation.
Contact Required	---	---	?	Please contact your representative for information regarding the proper sampling kits for your service.
Alert	---	---	?	NOTE: We recommend using Advanced Oil Monitoring (AOM) kits for this system. The AOM test package includes advanced level testing to determine the suitability of turbine and large industrial compressor oils for continued use.
Check Breathers	---	---	?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.
Check Fluid Source	---	---	?	Confirm the source of the lubricant being utilized for top-up/fill.
Check Seals	---	---	?	Check seals and/or filters for points of contaminant entry.

## HISTORICAL DIAGNOSIS


ISO



### 14 Mar 2024 Diag: Kevin Marson

Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Confirm the source of the lubricant being utilized for top-up/fill. Resample in 30-45 days to monitor this situation. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using Advanced Oil Monitoring (AOM) kits for this system. The AOM test package includes advanced level testing to determine the suitability of turbine and large industrial compressor oils for continued use. Component wear rates appear to be normal (unconfirmed). There is a high amount of silt (particulates < 14 microns in size) present in the oil. Additive levels indicate the addition of a different brand, or type of oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service (unconfirmed). The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report



ISO



### 14 Mar 2024 Diag: Kevin Marson

Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Confirm the source of the lubricant being utilized for top-up/fill. Resample in 30-45 days to monitor this situation. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using Advanced Oil Monitoring (AOM) kits for this system. The AOM test package includes advanced level testing to determine the suitability of turbine and large industrial compressor oils for continued use. Component wear rates appear to be normal (unconfirmed). There is a high amount of silt (particulates < 14 microns in size) present in the oil. Additive levels indicate the addition of a different brand, or type of oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service (unconfirmed). The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report



ISO




### 09 Mar 2024 Diag: Kevin Marson

Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Confirm the source of the lubricant being utilized for top-up/fill. Resample in 30-45 days to monitor this situation. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using Advanced Oil Monitoring (AOM) kits for this system. The AOM test package includes advanced level testing to determine the suitability of turbine and large industrial compressor oils for continued use. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. Additive levels indicate the addition of a different brand, or type of oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service (unconfirmed). The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report





Machine Id

**PRESS #8**

Component

**Hydraulic System**

Fluid

**PETRO CANADA HYDREX AW 68 (10000 GAL)**

## DIAGNOSIS

### ▲ Recommendation

Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Confirm the source of the lubricant being utilized for top-up/fill. Resample in 30-45 days to monitor this situation. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using Advanced Oil Monitoring (AOM) kits for this system. The AOM test package includes advanced level testing to determine the suitability of turbine and large industrial compressor oils for continued use.

### Wear

All component wear rates are normal.

### ▲ Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

### ● Fluid Condition

Additive levels indicate the addition of a different brand, or type of oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service (unconfirmed). The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>PC0087731</b>	PC0081051	PC0081055
Sample Date	Client Info	<b>11 Jun 2024</b>	14 Mar 2024	14 Mar 2024
Machine Age	mths	Client Info	0	0
Oil Age	mths	Client Info	0	0
Oil Changed	Client Info	<b>N/A</b>	N/A	N/A
Sample Status		<b>SEVERE</b>	SEVERE	SEVERE

## CONTAMINATION

method	limit/base	current	history1	history2
Water	WC Method >0.05	<b>NEG</b>	NEG	NEG

## WEAR METALS

method	limit/base	current	history1	history2
PQ	ASTM D8184*	<b>0</b>	0	0
Iron	ppm ASTM D5185(m) >20	<b>34</b>	33	32
Chromium	ppm ASTM D5185(m) >20	<b>&lt;1</b>	<1	<1
Nickel	ppm ASTM D5185(m) >20	<b>&lt;1</b>	<1	<1
Titanium	ppm ASTM D5185(m)	<b>0</b>	0	0
Silver	ppm ASTM D5185(m)	<b>0</b>	0	<1
Aluminum	ppm ASTM D5185(m) >20	<b>7</b>	7	7
Lead	ppm ASTM D5185(m) >20	<b>6</b>	6	7
Copper	ppm ASTM D5185(m) >20	<b>62</b>	60	60
Tin	ppm ASTM D5185(m) >20	<b>&lt;1</b>	<1	<1
Antimony	ppm ASTM D5185(m)	<b>0</b>	0	0
Vanadium	ppm ASTM D5185(m)	<b>0</b>	0	0
Beryllium	ppm ASTM D5185(m)	<b>0</b>	0	0
Cadmium	ppm ASTM D5185(m)	<b>0</b>	0	0






## ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm ASTM D5185(m) 0	<b>&lt;1</b>	0	0
Barium	ppm ASTM D5185(m) 0	<b>&lt;1</b>	<1	<1
Molybdenum	ppm ASTM D5185(m) 0	<b>0</b>	0	0
Manganese	ppm ASTM D5185(m) 0	<b>&lt;1</b>	0	0
Magnesium	ppm ASTM D5185(m) 0	<b>52</b>	52	52
Calcium	ppm ASTM D5185(m) 50	<b>76</b>	78	78
Phosphorus	ppm ASTM D5185(m) 330	<b>575</b>	600	603
Zinc	ppm ASTM D5185(m) 430	<b>499</b>	501	503
Sulfur	ppm ASTM D5185(m) 760	<b>1738</b>	1897	1909
Lithium	ppm ASTM D5185(m)	<b>&lt;1</b>	<1	<1

## CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185(m) >15	<b>2</b>	3	4
Sodium	ppm ASTM D5185(m)	<b>2</b>	2	2
Potassium	ppm ASTM D5185(m) >20	<b>&lt;1</b>	<1	<1

# OIL ANALYSIS REPORT



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : PC0087731  
**Lab Number** : 02641132  
**Unique Number** : 5798671  
**Test Package** : IND 2 ( Additional Tests: KV100, PQ, VI )

**Received** : 11 Jun 2024  
**Tested** : 12 Jun 2024  
**Diagnosed** : 12 Jun 2024 - Kevin Marson

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>5000	▲ 130641	▲ 104866	▲ 93866	
Particles >6µm	ASTM D7647	>1300	▲ 19661	▲ 12877	▲ 6353	
Particles >14µm	ASTM D7647	>160	101	63	55	
Particles >21µm	ASTM D7647	>40	24	9	13	
Particles >38µm	ASTM D7647	>10	2	2	3	
Particles >71µm	ASTM D7647	>3	1	2	1	
Oil Cleanliness	ISO 4406 (c)	>19/17/14	▲ 24/21/14	▲ 24/21/13	▲ 24/20/13	

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.60	0.66	0.71	0.56

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>0.05	NEG	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	67.4	65.1	65.1	65.0
Visc @ 100°C	cSt	ASTM D7279(m)	8.9	8.9	9.0	8.8
Viscosity Index (VI)	Scale	ASTM D2270*	105	110	113	108

SAMPLE IMAGES		method	limit/base	current	history1	history2
Color						
Bottom						

**EXTRUDEX ALUMINIUM**  
 411 CHRISLEA ROAD  
 WOODBRIDGE, ON  
 CA L4L 8N4  
 Contact: Daljeet Munday  
 dmunday@extrudex.com  
 T: (416)745-4444  
 F: (416)745-0925