

## FUEL REPORT

Sample Rating Trend

### NORMAL

## Machine Id

MIDCRANE

Component Diesel Fuel

Fluid No.2 DIESEL FUEL (ULTRALOW SULPHUR) (--- GAL)

### DIAGNOSIS

#### Recommendation

Laboratory test indicate that this fuel is suitable for use and meets all test requirements. Resample at the next service interval to monitor.

#### Contaminants

The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. There is no indication of any contamination in the diesel fuel.

#### **Fuel Condition**

All laboratory tests indicate that this sample meets specifications for No.2 ultra-low-sulfur diesel fuel (US EPA/CGSB-3.517-3 type B).

SAMPLE INFORM	NATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PC		
Sample Date		Client Info		06 Jun 2024		
Machine Age	hrs	Client Info		0		
Sample Status				NORMAL		
PHYSICAL PROP	ERTIES	method	limit/base	current	history1	history2
Specific Gravity		ASTM D1298*	0.839	0.843		
Fuel Color	text	Visual Screen*	Yllow	Yllow		
Visc @ 40°C	cSt	ASTM D7279(m)	3.0	2.9		
Pensky-Martens Flash Point	°C	ASTM D7215*	52	63.5		
SULFUR CONT	ſENT	method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185(m)	10	8		
DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D2887*	165	175		
5% Distillation Point	°C	ASTM D2887*		200		
10% Distill Point	°C	ASTM D2887*	201	212		
15% Distillation Point	°C	ASTM D2887*		221		
20% Distill Point	°C	ASTM D2887*	216	229		
30% Distill Point	°C	ASTM D2887*	230	244		
40% Distill Point	°C	ASTM D2887*	243	257		
50% Distill Point	°C	ASTM D2887*	255	269		
60% Distill Point	°C	ASTM D2887*	267	283		
70% Distill Point	°C	ASTM D2887*	280	297		
80% Distill Point	°C °C	ASTM D2887*	295	313		
85% Distillation Point 90% Distill Point	°C	ASTM D2887* ASTM D2887*	310	324 336		
95% Distillation Point	°C	ASTM D2887*	310	355		
Final Boiling Point	°C	ASTM D2887*	341	355		
IGNITION QUA	LITY	method	limit/base	current	history1	history2
API Gravity		ASTM D1298*	37.7	36		
Cetane Index		ASTM D4737*	<40.0	49		
CONTAMINAN	TS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	<1.0	0		
Sodium	ppm	ASTM D5185(m)	<0.1	0		
Potassium	ppm	ASTM D5185(m)	<0.1	0		
Water	%	ASTM D6304*	<0.05	0.003		
ppm Water	ppm	ASTM D6304*	<500	39		
FLUID CLEANL	INESS.	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>2500	1053		
Particles >6µm		ASTM D7647	>640	217		
Particles >14µm		ASTM D7647	>80	24		
Particles >21µm		ASTM D7647	>20	6		
Particles >38µm		ASTM D7647	>4	1		
Particles >71µm		ASTM D7647		0		
Oil Cleanliness		ISO 4406 (c)	>18/16/13	17/15/12		vnes - TFRHAM

Contact/Location: Josh Hynes - TERHAM Page 1 of 2



## FUEL REPORT

ppm

ppm

ppm

ppm

ppm

ppm

ppm

ppm

HEAVY METALS

Aluminum

Vanadium

Calcium

Magnesium


Phosphorus


Nickel

Lead

Iron

Zinc





Received

Diagnosed

Tested

Suncor - Terra Nova Projects Scotia Centre, 235 Water Strret St. John`s, NL CA A1C 1B6 Contact: Josh Hynes joshynes@suncor.com T: (709)778-3575 F: (709)724-2835


Time (min)

FEIDER

# Particle Trend Ê 31 E 21 n, Gas Chromatography (GCD) 40 GCD 10% 35 GCD 90% 300 g 250

200

150



0

0

0

0

0

0

0

<1

<0.1

<0.1

< 0.1

<0.1

<0.1

< 0.1

<0.1

< 0.1

ASTM D5185(m)

Validity of results and interpretation are based on the sample and information as supplied. Contact/Location: Josh Hynes - TERHAM

: 26 Jun 2024


: 02 Jul 2024 - Kevin Marson

: 02 Jul 2024

Page 2 of 2

no image

no image



CALA

ISO 17025:2017 Accredited

Laboratory

Jun6/24

Unique Number : 5801807

: PC

: 02644268

To discuss this sample report, contact Customer Service at 1-800-268-2131.

Test Package : FUEL (Additional Tests: CC Flash, PrtCount)

Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.

Laboratory

Sample No.

Lab Number