


# OIL ANALYSIS REPORT

Area  
**TEAM 15**  
Machine Id  
**156115 (S/N ROTARY AIR LOCK FEEDER)**  
Component  
**Gearbox**  
Fluid  
**PETRO CANADA ENDURATEX SYNTHETIC EP 220 (5 GAL)**

Sample Rating Trend



**NORMAL**



## DIAGNOSIS

### Recommendation

Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is no indication of any contamination in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>PC0080407</b>	PC0078840	PC0076947
Sample Date	Client Info		<b>03 Jul 2024</b>	05 Jun 2024	14 Jan 2024
Machine Age	mths	Client Info	<b>0</b>	0	0
Oil Age	mths	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>NORMAL</b>	NORMAL	NORMAL

## CONTAMINATION

	method	limit/base	current	history1	history2
Water	WC Method	>0.2	<b>NEG</b>	NEG	NEG

## WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184*		<b>0</b>	---	0
Iron	ppm	ASTM D5185(m) >200	<b>5</b>	5	44
Chromium	ppm	ASTM D5185(m) >15	<b>0</b>	0	<1
Nickel	ppm	ASTM D5185(m) >15	<b>&lt;1</b>	0	<1
Titanium	ppm	ASTM D5185(m)	<b>0</b>	0	0
Silver	ppm	ASTM D5185(m)	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185(m) >25	<b>&lt;1</b>	0	<1
Lead	ppm	ASTM D5185(m) >100	<b>&lt;1</b>	0	0
Copper	ppm	ASTM D5185(m) >200	<b>&lt;1</b>	0	<1
Tin	ppm	ASTM D5185(m) >25	<b>0</b>	0	0
Antimony	ppm	ASTM D5185(m) >5	<b>0</b>	0	0
Vanadium	ppm	ASTM D5185(m)	<b>0</b>	0	0
Beryllium	ppm	ASTM D5185(m)	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185(m)	<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m) 33	<b>29</b>	32	46
Barium	ppm	ASTM D5185(m) 5	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185(m)	<b>0</b>	0	0
Manganese	ppm	ASTM D5185(m)	<b>0</b>	0	0
Magnesium	ppm	ASTM D5185(m) 5	<b>&lt;1</b>	<1	<1
Calcium	ppm	ASTM D5185(m) 5	<b>2</b>	<1	3
Phosphorus	ppm	ASTM D5185(m) 437	<b>316</b>	361	266
Zinc	ppm	ASTM D5185(m) 5	<b>3</b>	2	3
Sulfur	ppm	ASTM D5185(m) 5000	<b>5246</b>	4914	6047
Lithium	ppm	ASTM D5185(m)	<b>&lt;1</b>	<1	<1





## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m) >50	<b>4</b>	2	7
Sodium	ppm	ASTM D5185(m)	<b>1</b>	2	26
Potassium	ppm	ASTM D5185(m) >20	<b>&lt;1</b>	<1	2

## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974* 0.7	<b>0.60</b>	0.69	0.46


# OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>0.2	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	223	215	225
Visc @ 100°C	cSt	ASTM D7279(m)	26.39	24.3	20.3
Viscosity Index (VI)	Scale	ASTM D2270*	151	141	104

## SAMPLE IMAGES



## GRAPHS



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : PC0080407 **Received** : 10 Jul 2024  
**Lab Number** : 02647224 **Tested** : 11 Jul 2024  
**Unique Number** : 5812776 **Diagnosed** : 11 Jul 2024 - Wes Davis  
**Test Package** : IND 2 ( Additional Tests: KV100, VI )

**Dryden Fibre**  
 Box 3001, 1 Duke Street  
 Dryden, ON  
 CA P8N 2Z7  
 Contact: Adebukola Adekanye  
 aadekanye@drydenfibre.ca  
 T: (807)223-9950  
 F: (807)223-9176

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.