







Area
Water Injection [450360387]
Machine Id
Pump - Glycol Circulation (B) (S/N Sample Tag PA-38002B)
Component
Reciprocating Pump - Bearings/Crossheads
Fluid
PETRO CANADA DURON HP 15W40 (15 LTR)



COMPONENT CONDITION SUMMARY



RECOMMENDATION

Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation.

PROBLEMATIC TEST RESULTS

Sample Status			SEVERE	ABNORMAL	SEVERE
Particles >4µm	ASTM D7647	>5000	▲ 88147	82194	▲ 114109
Particles >6µm	ASTM D7647	>1300	▲ 14246	11411	▲ 20164
Particles >14µm	ASTM D7647	>40	▲ 154	▲ 126	▲ 163
Oil Cleanliness	ISO 4406 (c)	>19/17/12	▲ 24/21/14	▲ 24/21/14	▲ 24/22/15
Visc @ 40°C	cSt	ASTM D7279(m)	▲ 84.0	▲ 86.1	▲ 84.5
Visc @ 100°C	cSt	ASTM D7279(m)	▲ 11.3	▲ 11.6	▲ 11.8

Customer Id: TERHAM
Sample No.: PC
Lab Number: 02648138
Test Package: MAR 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Kevin Marson +1 (289)291-4644 x4644
Kevin.Marson@wearcheck.com

To change component or sample information:
Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component.
Resample	---	---	?	Resample in 30-45 days to monitor this situation.
Check Breathers	---	---	?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.
Check Seals	---	---	?	Check seals and/or filters for points of contaminant entry.

HISTORICAL DIAGNOSIS

VISCOSITY



03 May 2024 Diag: Kevin Marson

We recommend you service the filters on this component. We recommend an early resample to monitor this condition. All component wear rates are normal. There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The system cleanliness is above the acceptable limit for the target ISO 4406 cleanliness code. Viscosity of sample indicates oil is within SAE 10W30 range, advise investigate. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

[view report](#)



ISO



07 Apr 2024 Diag: Kevin Marson

Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The system cleanliness code is much higher than the acceptable limit for the target ISO 4406 cleanliness code. Viscosity of sample indicates oil is within SAE 10W30 range, advise investigate. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

[view report](#)



ISO




13 Mar 2024 Diag: Kevin Marson

We advise that you check all areas where contaminants can enter the system. We recommend that you drain the oil from the component if this has not already been done. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. Copper ppm levels are abnormal. There is a high amount of particulates (2 to 100 microns in size) present in the oil. The system cleanliness code is much higher than the acceptable limit for the target ISO 4406 cleanliness code. Viscosity of sample indicates oil is within SAE 10W30 range, advise investigate. The AN level is acceptable for this fluid. The oil is no longer serviceable as a result of the abnormal and/or severe wear.

[view report](#)





Area
Water Injection [450360387]
Machine Id
Pump - Glycol Circulation (B) (S/N Sample Tag PA-38002B)
Component
Reciprocating Pump - Bearings/Crossheads
Fluid
PETRO CANADA DURON HP 15W40 (15 LTR)

DIAGNOSIS

▲ Recommendation
Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation.

Wear
All component wear rates are normal.

▲ Contamination
There is a high amount of silt (particulates < 14 microns in size) present in the oil. The system cleanliness code is much higher than the acceptable limit for the target ISO 4406 cleanliness code.

▲ Fluid Condition
Viscosity of sample indicates oil is within SAE 10W30 range, advise investigate. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			PC	PC	PC
Sample Date	Client Info			26 Jun 2024	03 May 2024	07 Apr 2024
Machine Age	hrs Client Info			0	0	0
Oil Age	hrs Client Info			0	0	0
Oil Changed	Client Info			N/A	N/A	N/A
Sample Status				SEVERE	ABNORMAL	SEVERE

CONTAMINATION		method	limit/base	current	history1	history2
Water	WC Method		>.1	NEG	NEG	NEG






WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>20	5	4	6
Chromium	ppm	ASTM D5185(m)	>20	0	0	0
Nickel	ppm	ASTM D5185(m)	>20	0	0	0
Titanium	ppm	ASTM D5185(m)		0	0	0
Silver	ppm	ASTM D5185(m)		0	0	0
Aluminum	ppm	ASTM D5185(m)	>20	<1	<1	<1
Lead	ppm	ASTM D5185(m)	>20	0	0	0
Copper	ppm	ASTM D5185(m)	>20	3	2	4
Tin	ppm	ASTM D5185(m)	>20	0	0	0
Antimony	ppm	ASTM D5185(m)		0	0	0
Vanadium	ppm	ASTM D5185(m)		0	0	0
Beryllium	ppm	ASTM D5185(m)		0	0	0
Cadmium	ppm	ASTM D5185(m)		0	0	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	0	2	2	1
Barium	ppm	ASTM D5185(m)	0	0	0	0
Molybdenum	ppm	ASTM D5185(m)	60	62	59	62
Manganese	ppm	ASTM D5185(m)	0	<1	0	0
Magnesium	ppm	ASTM D5185(m)	1010	1009	955	973
Calcium	ppm	ASTM D5185(m)	1070	1114	1043	1043
Phosphorus	ppm	ASTM D5185(m)	1150	1020	1044	1034
Zinc	ppm	ASTM D5185(m)	1270	1250	1161	1175
Sulfur	ppm	ASTM D5185(m)	2060	2843	2644	2657
Lithium	ppm	ASTM D5185(m)		<1	<1	<1

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>15	4	3	3
Sodium	ppm	ASTM D5185(m)		1	<1	2
Potassium	ppm	ASTM D5185(m)	>20	0	<1	<1

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>5000	▲ 88147	82194	▲ 114109	
Particles >6µm	ASTM D7647	>1300	▲ 14246	11411	▲ 20164	
Particles >14µm	ASTM D7647	>40	▲ 154	▲ 126	▲ 163	
Particles >21µm	ASTM D7647	>10	● 15	● 17	● 19	
Particles >38µm	ASTM D7647	>3	2	1	2	
Particles >71µm	ASTM D7647	>3	1	0	1	
Oil Cleanliness	ISO 4406 (c)	>19/17/12	▲ 24/21/14	▲ 24/21/14	▲ 24/22/15	

OIL ANALYSIS REPORT




FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	3.2	1.64	1.95	1.55

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>.1	NEG	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	118.2	▲ 84.0	▲ 86.1	▲ 84.5
Visc @ 100°C	cSt	ASTM D7279(m)	15.6	▲ 11.3	▲ 11.6	▲ 11.8
Viscosity Index (VI)	Scale	ASTM D2270*	139	123	125	132

SAMPLE IMAGES method limit/base current history1 history2



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : PC **Received** : 16 Jul 2024
Lab Number : **02648138** **Tested** : 18 Jul 2024
Unique Number : 5813690 **Diagnosed** : 18 Jul 2024 - Kevin Marson
Test Package : MAR 2 (Additional Tests: KV100, PrtCount, TAN MAN, VI)

Suncor - Terra Nova Projects
 Scotia Centre, 235 Water Street
 St. John's, NL
 CA A1C 1B6
 Contact: Josh Hynes
 joshynes@suncor.com
 T: (709)778-3575
 F: (709)724-2835

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.