

### **OIL ANALYSIS REPORT**

Sample Rating Trend

NORMAL

Machine Id

# NO UNIT WC0123451

Diesel Engine Fluid {not provided} (--- GAL)

#### DIAGNOSIS

#### Recommendation

Resample at the next service interval to monitor. Please specify the component make and model with your next sample. Please specify the brand, type, and viscosity of the oil on your next sample.

#### Wear

All component wear rates are normal.

#### Contamination

Elevated aluminum (Al) and/or lead (Pb) and potassium (K) levels in your metals analysis are likely a result of solder flux release into the lubricant and is common on new equipment/components. There is no indication of any contamination in the oil.


#### Fluid Condition


The condition of the oil is acceptable for the time in service.

				Jul2024		
SAMPLE INFOR	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		GFL0123451		
Sample Date		Client Info		16 Jul 2024		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				NORMAL		
CONTAMINAT	ION	method	limit/base	current	history1	history2
Fuel		WC Method	>5	<1.0		
Water		WC Method	>0.2	NEG		
Glycol		WC Method		NEG		
WEAR METAL	S	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>100	9		
Chromium	ppm	ASTM D5185(m)	>20	<1		
Nickel	ppm	ASTM D5185(m)	>4	<1		
Titanium	ppm	ASTM D5185(m)		0		
Silver	ppm	ASTM D5185(m)	>3	0		
Aluminum	ppm	ASTM D5185(m)	>20	4		
Lead	ppm	ASTM D5185(m)	>40	0		
Copper	ppm	ASTM D5185(m)	>330	<1		
Tin	ppm	ASTM D5185(m)	>15	0		
Antimony	ppm	ASTM D5185(m)		0		
Vanadium	ppm	ASTM D5185(m)		0		
Beryllium	ppm	ASTM D5185(m)		0		
Cadmium	ppm	ASTM D5185(m)		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)		2		
Barium	ppm	ASTM D5185(m)		0		
Molybdenum	ppm	ASTM D5185(m)		56		
Manganese	ppm	ASTM D5185(m)		0		
Magnesium	ppm	ASTM D5185(m)		898		
Calcium	ppm	ASTM D5185(m)		989		
Phosphorus	ppm	ASTM D5185(m)		952		
Zinc	ppm	ASTM D5185(m)		1147		
Sulfur Lithium	ppm ppm	ASTM D5185(m) ASTM D5185(m)		2438 <1		
CONTAMINAN		method	limit/base		history1	
						history2
Silicon Sodium	ppm	ASTM D5185(m) ASTM D5185(m)	>25	2		
Potassium	ppm ppm	ASTM D5185(m) ASTM D5185(m)	>20	8		
INFRA-RED	PP	method	limit/base		history1	history2
Soot %	%	ASTM D7844*	>3	0.2		
Nitration	Abs/cm	ASTM D7644 ASTM D7624*		9.0		
Sulfation	Abs/cm Abs/.1mm	ASTM D7624 ASTM D7415*	>20 >30	9.0 19.4		
Julialiun	MD5/.111111	A01WI D7410	>00	13.4		



## **OIL ANALYSIS REPORT**





FLUID DEGRA	DATION	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	ASTM D7414*	>25	16.3		
VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE		
Yellow Metal	scalar	Visual*	NONE	NONE		
Precipitate	scalar	Visual*	NONE	NONE		
Silt	scalar	Visual*	NONE	NONE		
Debris	scalar	Visual*	NONE	NONE		
Sand/Dirt	scalar	Visual*	NONE	NONE		
Appearance	scalar	Visual*	NORML	NORML		
Odor	scalar	Visual*	NORML	NORML		
Emulsified Water	scalar	Visual*	>0.2	NEG		
Free Water	scalar	Visual*		NEG		
FLUID PROPE	RTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D7279(m)		13.8		
GRAPHS						
Iron (ppm)			100	Lead (ppm)		
200 Severe			80	Severe		
150 - Abnormal			E 60	Abnormal		
100 - 4 50			<sup>□</sup> 40			
0			0			
Jul16/24			Jul16/24	Jul16/24		Jul16/24
→ Aluminum (ppm)			7	¬ Chromium (p	nm)	~
50 Severe			50	TV		
40 1 9			40	Severe		
and a second sec			20	Abnormal		1
10			10			
0 42			24	24		- 24
Jul16/24			Jul16/24	Jul16/24		Jul16/24
Copper (ppm)				Silicon (ppm)		
400 Severe			80	Severe		
300 -			60			
200			톱 40	Abnormal		
100			20			
6/24 L 0			0	6/24		3/24
Jul16/2			Jul16/24	Jul16/24		Jul16/24
Viscosity @ 100°C	2			Soot %		
18 Abnormal			6.0	Severe		1
016 14 3 12 <b>Abnormal</b>			<sub>وب</sub> و4.0	Abnormal		
Abnormal			<sup>يو</sup> 4.0 کې 2.0			1
10			0.0			
Jul16/24			Jul16/24	Jult6/24		Jul16/24 +
Jult			Jult	Jult		Jult

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 GFL Environmental - 221 - Windsor Laboratory CALA Sample No. : GFL0123451 Received : 17 Jul 2024 905 Tecumseh Road W Lab Number : 02648367 Tested : 17 Jul 2024 Windsor, ON ISO 17025:2017 Accredited Laboratory Unique Number : 5813919 CA N8W 4J5 Diagnosed : 17 Jul 2024 - Wes Davis Test Package : MOB 1 (Additional Tests: Visual) Contact: Pamela-Jean Butler To discuss this sample report, contact Customer Service at 1-800-268-2131. pamelajean.butler@gflenv.com Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab. T: (519)948-8126 Validity of results and interpretation are based on the sample and information as supplied. F:

Report Id: GFL221 [WCAMIS] 02648367 (Generated: 07/17/2024 13:35:36) Rev: 1

Contact/Location: Pamela-Jean Butler - GFL221 Page 2 of 2