


PROBLEM SUMMARY

Area
SCOF [96394611]
 Machine Id
EMULSIFIER 1
 Component
Pump
 Fluid
ISO 100 (--- GAL)

Sample Rating Trend




CONTAMINANT



COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

No corrective action is recommended at this time. The oil change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status			ABNORMAL	ABNORMAL	SEVERE
Particles >4µm	ASTM D7647	>1300	▲ 150636	▲ 184111	---
Particles >6µm	ASTM D7647	>320	▲ 78044	▲ 160664	---
Particles >14µm	ASTM D7647	>80	▲ 1293	▲ 13777	---
Particles >21µm	ASTM D7647	>20	▲ 151	▲ 952	---
Oil Cleanliness	ISO 4406 (c)	>17/15/13	▲ 24/23/17	▲ 25/25/21	---
Appearance	scalar *Visual	NORML	▲ HAZY	NORML	NORML

Customer Id: KRASPRMO
 Sample No.: PCA0033299
 Lab Number: 05203108
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Don Baldrige +1
don.b505@comcast.net

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

08 Oct 2020 Diag: Don Baldrige

ISO



No corrective action is recommended at this time. The oil change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



19 Aug 2020 Diag: Don Baldrige

VISUAL METAL




The oil change at the time of sampling has been noted. We advise that you inspect for possible wear. Resample at the next service interval to monitor. We were unable to perform a particle count due to metal particles present in this sample. Moderate concentration of visible metal present. All component wear rates are normal. No other contaminants were detected in the oil. The AN level is acceptable for this fluid.

view report



Area
SCOF [96394611]
 Machine Id
EMULSIFIER 1
 Component
Pump
 Fluid
ISO 100 (--- GAL)



DIAGNOSIS

Recommendation
 No corrective action is recommended at this time. The oil change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear
 All component wear rates are normal.

Contamination
 There is a high amount of particulates present in the oil. Appearance is hazy.

Fluid Condition
 The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	PCA0033299	PCA0030806	PCA0027834
Sample Date	Client Info	08 Mar 2021	08 Oct 2020	19 Aug 2020
Machine Age	hrs	0	0	0
Oil Age	hrs	0	0	0
Oil Changed	Client Info	Changed	Changed	Changed
Sample Status		ABNORMAL	ABNORMAL	SEVERE

WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m >90	17	18	44
Chromium	ppm	ASTM D5185m >5	<1	<1	<1
Nickel	ppm	ASTM D5185m >5	0	<1	<1
Titanium	ppm	ASTM D5185m >3	0	0	<1
Silver	ppm	ASTM D5185m >3	<1	0	<1
Aluminum	ppm	ASTM D5185m >7	0	0	0
Lead	ppm	ASTM D5185m >12	<1	<1	<1
Copper	ppm	ASTM D5185m >30	<1	1	10
Tin	ppm	ASTM D5185m >9	0	<1	<1
Antimony	ppm	ASTM D5185m	0	0	0
Vanadium	ppm	ASTM D5185m	0	0	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m	<1	2	<1
Barium	ppm	ASTM D5185m	0	0	<1
Molybdenum	ppm	ASTM D5185m	0	0	<1
Manganese	ppm	ASTM D5185m	<1	<1	<1
Magnesium	ppm	ASTM D5185m	<1	<1	0
Calcium	ppm	ASTM D5185m	2	2	5
Phosphorus	ppm	ASTM D5185m	47	55	39
Zinc	ppm	ASTM D5185m	58	59	28
Sulfur	ppm	ASTM D5185m	37	12	30

CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >60	0	<1	2
Sodium	ppm	ASTM D5185m	4	6	4
Potassium	ppm	ASTM D5185m >20	<1	1	1
Water	%	ASTM D6304	0.005	0.001	0.003
ppm Water	ppm	ASTM D6304 >.1	51.5	0.00	28.7






FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >1300	▲ 150636	▲ 184111	---
Particles >6µm	ASTM D7647 >320	▲ 78044	▲ 160664	---
Particles >14µm	ASTM D7647 >80	▲ 1293	▲ 13777	---
Particles >21µm	ASTM D7647 >20	▲ 151	▲ 952	---
Particles >38µm	ASTM D7647 >4	3	▲ 16	---
Particles >71µm	ASTM D7647 >3	0	0	---
Oil Cleanliness	ISO 4406 (c) >17/15/13	▲ 24/23/17	▲ 25/25/21	---

FLUID DEGRADATION

method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045	0.178	0.282	0.224


OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2	
White Metal	scalar	*Visual	NONE	LIGHT	LIGHT	MODER
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	HAZY	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	NEG	NEG	NEG	
Free Water	scalar	*Visual	NEG	NEG	NEG	

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D445	100	101	99.0	106

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : PCA0033299 **Received** : 12 Mar 2021
Lab Number : 05203108 **Diagnosed** : 16 Mar 2021
Unique Number : 9404517 **Diagnostician** : Don Baldrige
Test Package : IND 2 (Additional Tests: KF, PrtCount)

KraftHeinz - Springfield - Plant 8311 PCA
 2035 E BENNETT
 SPRINGFIELD, MO
 US 65804
 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)