


## **PROBLEM SUMMARY**


## SCOF [96865471] **CMX SURGE 4760**

Component Pump Fluid

**R&O OIL ISO 100 (--- GAL)** 



## **COMPONENT CONDITION SUMMARY**



### RECOMMENDATION

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS									
Sample Status		ABNORMAL	ABNORMAL	ABNORMAL					
Particles >4μm	ASTM D7647 >130	0 <u>^</u> 91698	<u>▲</u> 110138						
Particles >6μm	ASTM D7647 >320	<b>7216</b>	<b>△</b> 11886						
Oil Cleanliness	ISO 4406 (c) >17/1	5/13 <b>A 24/20/13</b>	<u>4</u> 24/21/14						

Customer Id: KRASPRMO Sample No.: PCA0054007 Lab Number: 05375310 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 dougb@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

## **RECOMMENDED ACTIONS**

Action	Status	Date	Done By	Description
Change Filter			?	We recommend you service the filters on this component if applicable.

## HISTORICAL DIAGNOSIS

## 08 Mar 2021 Diag: Jonathan Hester

ISO



The oil change at the time of sampling has been noted. We recommend you service the filters on this component. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



## 08 Oct 2020 Diag: Don Baldridge

WAIER




We advise that you check for the source of water entry. The oil change at the time of sampling has been noted. Resample at the next service interval to monitor. There is too much water present in this sample to perform a particle count. All component wear rates are normal. There is a light concentration of water present in the oil. Free water present. The AN level is acceptable for this fluid.





## **OIL ANALYSIS REPORT**

## Sam



# SCOF [96865471] Machine Id CMX SURGE 4760

Component **Pump** 

**R&O OIL ISO 100 (--- GAL)** 

## DIAGNOSIS

### Recommendation

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

## Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

#### **Fluid Condition**


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		0et2020		Mar2021 0±2021		
SAMPLE INFORI	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PCA0054007	PCA0033302	PCA0030805
Sample Date		Client Info		11 Oct 2021	08 Mar 2021	08 Oct 2020
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		Changed	Changed	Changed
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METAL	S	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>90	16	19	26
Chromium	ppm	ASTM D5185m	>5	<1	1	2
Nickel	ppm	ASTM D5185m	>5	0	<1	<1
Titanium	ppm	ASTM D5185m	>3	0	<1	0
Silver	ppm	ASTM D5185m	>3	0	0	0
Aluminum	ppm	ASTM D5185m	>7	<1	<1	0
Lead	ppm	ASTM D5185m	>12	0	0	0
Copper	ppm	ASTM D5185m	>30	<1	<1	3
Tin	ppm	ASTM D5185m	>9	0	1	0
Antimony	ppm	ASTM D5185m		0	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	5	0	<1	2
Barium	ppm	ASTM D5185m	5	0	<1	0
Molybdenum	ppm	ASTM D5185m	5	0	<1	0
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m	5	0	1	0
Calcium	ppm	ASTM D5185m	5	0	<1	0
Phosphorus	ppm	ASTM D5185m	100	34	40	57
Zinc	ppm	ASTM D5185m	25	29	47	80
Sulfur	ppm	ASTM D5185m	1500	0	0	0
CONTAMINAN	TS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>60	0	1	1
Sodium	ppm	ASTM D5185m		0	<1	<1
Potassium	ppm	ASTM D5185m	>20	0	18	0
Water	%	ASTM D6304		0.002	0.005	<u>△</u> 0.158
ppm Water	ppm	ASTM D6304	>.1	24.1	59.1	<u> </u>
FLUID CLEAN	INESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>1300	<u> </u>	<u>▲</u> 110138	
Particles >6µm		ASTM D7647	>320	<b>^</b> 7216	<u>▲</u> 11886	
Particles >14µm		ASTM D7647	>80	65	<u> 106</u>	
Particles >21µm		ASTM D7647	>20	9	<u>^</u> 22	
Particles >38µm		ASTM D7647	>4	1	0	
Particles >71µm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>17/15/13	<u>4</u> 24/20/13	<u>4</u> 24/21/14	
FLUID DEGRA	OATION	method	limit/base	current	history1	history2

Contact/Location: Service Manager - KRASPRMO



## **OIL ANALYSIS REPORT**







Certificate L2367

Laboratory Sample No. Lab Number **Unique Number** 

Test Package

: 05375310

: PCA0054007 : 9699421

Received : 15 Oct 2021 Diagnosed

: 18 Oct 2021

Diagnostician : Doug Bogart : IND 2 ( Additional Tests: KF, PrtCount )

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

KraftHeinz - Springfield - Plant 8311 PCA

2035 E BENNETT SPRINGFIELD, MO

US 65804

Contact: Service Manager

T: F: