


OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL



Area
LONGHORN A
Machine Id
LONGHORN A UNIT 3 (S/N 1494549)
Component
Natural Gas Engine
Fluid
PETRO CANADA SENTRON LD 8000 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor. No other corrective action is recommended at this time.

Wear

Metal levels are typical for a new component breaking in.

Contamination

Fuel content negligible. There is no indication of any contamination in the oil.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		PCA0080827	PCA0080829	PCA0080832
Sample Date	Client Info		16 Nov 2022	31 Oct 2022	17 Oct 2022
Machine Age	hrs	Client Info	989	647	318
Oil Age	hrs	Client Info	989	647	318
Oil Changed	Client Info		Not Changed	Not Changed	Not Changed
Sample Status			NORMAL	NORMAL	NORMAL

CONTAMINATION

	method	limit/base	current	history1	history2
Water	WC Method	>0.1	NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	8	5	4
Chromium	ppm	ASTM D5185m >4	<1	0	0
Nickel	ppm	ASTM D5185m >2	<1	0	0
Titanium	ppm	ASTM D5185m	0	0	0
Silver	ppm	ASTM D5185m >3	0	0	0
Aluminum	ppm	ASTM D5185m >9	0	2	2
Lead	ppm	ASTM D5185m >30	4	<1	<1
Copper	ppm	ASTM D5185m >35	7	6	5
Tin	ppm	ASTM D5185m >4	2	1	<1
Vanadium	ppm	ASTM D5185m	<1	0	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	2	2	2
Barium	ppm	ASTM D5185m	0	2	0
Molybdenum	ppm	ASTM D5185m	2	2	2
Manganese	ppm	ASTM D5185m	<1	<1	<1
Magnesium	ppm	ASTM D5185m	25	20	19
Calcium	ppm	ASTM D5185m 1351	1503	1478	1456
Phosphorus	ppm	ASTM D5185m 302	319	297	300
Zinc	ppm	ASTM D5185m 358	369	373	375
Sulfur	ppm	ASTM D5185m 2758	3127	3188	3623

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >+100	8	8	11
Sodium	ppm	ASTM D5185m	3	0	<1
Potassium	ppm	ASTM D5185m >20	3	3	3
Fuel	%	ASTM D3524 >4.0	0.4	0.3	0.3





INFRA-RED

	method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844	0.1	0.1	0.1
Nitration	Abs/cm	*ASTM D7624 >20	7.1	6.2	5.0
Sulfation	Abs/.1mm	*ASTM D7415 >30	18.6	18.4	18.2

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414 >25	14.2	13.1	11.9
Acid Number (AN)	mg KOH/g	ASTM D8045 0.86	0.93	0.46	0.29
Base Number (BN)	mg KOH/g	ASTM D2896 4.64	3.97	3.35	3.89









OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	LIGHT
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 100°C	cSt	ASTM D445	13.3	13.7	13.4	13.2

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : PCA0080827 **Received** : 21 Nov 2022
Lab Number : 05699890 **Tested** : 23 Nov 2022
Unique Number : 10229464 **Diagnosed** : 23 Nov 2022 - Wes Davis
Test Package : MOB 2 (Additional Tests: FuelDilution, PercentFuel)

DIVERSIFIED ENERGY - CURWENSVILLE
 325 WALNUT ST FL2
 CURWENSVILLE, PA
 US 16833
 Contact: ZACH MCGARY
 zmcgary@dgoc.com

Certificate L2367
 To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)