OIL DIAGNOSTICS

PROBLEM SUMMARY

Sample Rating Trend



ISO

Area
PASTA [97274478]
Machine Id
L28 KNIFE
Component
Gearbox
Fluid
GEAR OIL ISO 150 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
Particles >4µm		ASTM D7647	>1300	▲ **172613**	▲ 279594	▲ 165675
Particles >6µm		ASTM D7647	>320	▲ **43152**	▲ 190453	▲ 57706
Particles >14µm		ASTM D7647	>80	▲ **1548**	▲ 7030	▲ 2203
Particles >21µm		ASTM D7647	>20	▲ **247**	▲ 268	▲ 398
Particles >38µm		ASTM D7647	>4	▲ **11**	3	▲ 13
Oil Cleanliness		ISO 4406 (c)	>17/15/13	▲ **25/23/18**	▲ 25/25/20	▲ 25/23/18

Customer Id: KRASPRMO
Sample No.: PCA0071827
Lab Number: 05708370
Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data:
Don Baldridge +1
don.b505@comcast.net

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component if applicable.

HISTORICAL DIAGNOSIS

03 Dec 2021 Diag: Jonathan Hester

WATER

We recommend you service the filters on this component. We recommend an early resample to monitor this condition.Gear wear is indicated. There is a high amount of particulates present in the oil. Appearance is hazy. There is a light concentration of water present in the oil. The AN level is acceptable for this fluid.

view report

25 Nov 2020 Diag: Jonathan Hester

ISO

We recommend you service the filters on this component. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report

OIL DIAGNOSTICS

OIL ANALYSIS REPORT

Sample Rating Trend



ISO

Area
PASTA [97274478]
Machine Id
L28 KNIFE
Component
Gearbox
Fluid
GEAR OIL ISO 150 (--- GAL)

DIAGNOSIS

Recommendation
We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

Wear
All component wear rates are normal.

Contamination
There is a high amount of particulates present in the oil.

Fluid Condition
The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number		Client Info		**PCA0071827**	PCA0056518	PCA0033306
Sample Date		Client Info		**19 Nov 2022**	03 Dec 2021	25 Nov 2020
Machine Age	hrs	Client Info		**0**	0	0
Oil Age	hrs	Client Info		**0**	0	0
Oil Changed		Client Info		**N/A**	N/A	Changed
Sample Status				**ABNORMAL**	ABNORMAL	ABNORMAL

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>200	**38**	▲ 265	28
Chromium	ppm	ASTM D5185m	>15	**<1**	1	0
Nickel	ppm	ASTM D5185m	>15	**0**	<1	0
Titanium	ppm	ASTM D5185m		**0**	<1	0
Silver	ppm	ASTM D5185m		**0**	0	0
Aluminum	ppm	ASTM D5185m	>25	**1**	6	0
Lead	ppm	ASTM D5185m	>100	**0**	<1	0
Copper	ppm	ASTM D5185m	>200	**<1**	1	2
Tin	ppm	ASTM D5185m	>25	**0**	<1	0
Antimony	ppm	ASTM D5185m	>5	**---**	0	0
Vanadium	ppm	ASTM D5185m		**0**	0	0
Cadmium	ppm	ASTM D5185m		**0**	0	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	50	**0**	0	<1
Barium	ppm	ASTM D5185m	15	**0**	0	0
Molybdenum	ppm	ASTM D5185m	15	**0**	<1	0
Manganese	ppm	ASTM D5185m		**<1**	5	<1
Magnesium	ppm	ASTM D5185m	50	**3**	3	2
Calcium	ppm	ASTM D5185m	50	**0**	13	2
Phosphorus	ppm	ASTM D5185m	350	**107**	203	174
Zinc	ppm	ASTM D5185m	100	**4**	183	0
Sulfur	ppm	ASTM D5185m	12500	**0**	0	18

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	**3**	18	7
Sodium	ppm	ASTM D5185m		**2**	<1	1
Potassium	ppm	ASTM D5185m	>20	**0**	<1	<1

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>1300	▲ **172613**	▲ 279594	▲ 165675
Particles >6µm		ASTM D7647	>320	▲ **43152**	▲ 190453	▲ 57706
Particles >14µm		ASTM D7647	>80	▲ **1548**	▲ 7030	▲ 2203
Particles >21µm		ASTM D7647	>20	▲ **247**	▲ 268	▲ 398
Particles >38µm		ASTM D7647	>4	▲ **11**	3	▲ 13
Particles >71µm		ASTM D7647	>3	**1**	0	0
Oil Cleanliness		ISO 4406 (c)	>17/15/13	▲ **25/23/18**	▲ 25/25/20	▲ 25/23/18

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.85	**0.15**	0.378	0.584

OIL ANALYSIS REPORT

OIL DIAGNOSTICS









VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	**NONE**	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	**NONE**	NONE	NONE
Precipitate	scalar	*Visual	NONE	**NONE**	NONE	NONE
Silt	scalar	*Visual	NONE	**NONE**	NONE	NONE
Debris	scalar	*Visual	NONE	**NONE**	LIGHT	LIGHT
Sand/Dirt	scalar	*Visual	NONE	**NONE**	NONE	NONE
Appearance	scalar	*Visual	NORML	**NORML**	▲ HAZY	NORML
Odor	scalar	*Visual	NORML	**NORML**	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	**NEG**	0.2%	NEG
Free Water	scalar	*Visual		**NEG**	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	150	**156**	340.0	149

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

GRAPHS











ANAB ACCREDITED ISO/IEC 17025 TESTING LABORATORY
Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : PCA0071827 **Received** : 05 Dec 2022
Lab Number : 05708370 **Diagnosed** : 06 Dec 2022
Unique Number : 10242945 **Diagnostician** : Don Baldridge
Test Package : IND 2 (Additional Tests: PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369.
** - Denotes test methods that are outside of the ISO 17025 scope of accreditation.*
Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

KraftHeinz - Springfield - Plant 8311 PCA
2035 E BENNETT
SPRINGFIELD, MO
US 65804
Contact: Service Manager
T:
F: