


# PROBLEM SUMMARY


Sample Rating Trend



Machine Id  
**RC-4 (S/N R60182)**  
 Component  
**Reciprocating Compressor**  
 Fluid  
**CHEVRON REFRIGERATION OIL WF 68 (--- GAL)**

## COMPONENT CONDITION SUMMARY

▲ Particle Trend




## RECOMMENDATION

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

## PROBLEMATIC TEST RESULTS

Sample Status			ABNORMAL	ATTENTION	ATTENTION
Particles >4µm	ASTM D7647	>2500	▲ 14458	377	277
Particles >6µm	ASTM D7647	>320	▲ 2235	95	66
Particles >14µm	ASTM D7647	>40	▲ 42	7	8
Oil Cleanliness	ISO 4406 (c)	>18/15/12	▲ 21/18/13	16/14/10	15/13/10

Customer Id: KRAWAL  
 Sample No.: PCA0095713  
 Lab Number: 05853247  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Jonathan Hester +1 919-379-4092 x4092  
[jhester@wearcheckusa.com](mailto:jhester@wearcheckusa.com)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Fluid	---	---	?	Oil and filter change at the time of sampling has been noted.
Change Filter	---	---	?	Oil and filter change at the time of sampling has been noted.

## HISTORICAL DIAGNOSIS

**19 Jan 2023 Diag: Jonathan Hester**

### VISCOSITY



Resample at the next service interval to monitor. All component wear rates are normal. The water content is negligible. The amount and size of particulates present in the system are acceptable. The oil viscosity is higher than normal. The AN level is acceptable for this fluid.

[view report](#)



**30 Sep 2021 Diag: Don Baldrige**

### VISCOSITY



Resample at the next service interval to monitor. All component wear rates are normal. The water content is negligible. The amount and size of particulates present in the system are acceptable. The oil viscosity is higher than normal. The AN level is acceptable for this fluid.

[view report](#)



**30 Jun 2021 Diag: Don Baldrige**

### VISCOSITY




Resample at the next service interval to monitor. All component wear rates are normal. The water content is negligible. The amount and size of particulates present in the system are acceptable. The oil viscosity is higher than normal. The AN level is acceptable for this fluid.

[view report](#)



# OIL ANALYSIS REPORT

## Sample Rating Trend



ISO



Machine Id  
**RC-4 (S/N R60182)**

Component  
**Reciprocating Compressor**

Fluid  
**CHEVRON REFRIGERATION OIL WF 68 (--- GAL)**

## DIAGNOSIS

### Recommendation

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is a high amount of particulates present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>PCA0095713</b>	PCA0088355	PCA0059319
Sample Date	Client Info	<b>09 May 2023</b>	19 Jan 2023	30 Sep 2021
Machine Age	hrs	<b>37767</b>	37621	33790
Oil Age	hrs	<b>0</b>	9206	5321
Oil Changed	Client Info	<b>Changed</b>	Not Changd	Not Changd
Sample Status		<b>ABNORMAL</b>	ATTENTION	ATTENTION

## WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m >50	<b>0</b>	1	1
Chromium	ppm	ASTM D5185m >10	<b>0</b>	0	0
Nickel	ppm	ASTM D5185m	<b>0</b>	0	0
Titanium	ppm	ASTM D5185m	<b>0</b>	0	0
Silver	ppm	ASTM D5185m	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >25	<b>0</b>	0	5
Lead	ppm	ASTM D5185m >25	<b>0</b>	0	0
Copper	ppm	ASTM D5185m >50	<b>0</b>	0	<1
Tin	ppm	ASTM D5185m >15	<b>0</b>	0	<1
Antimony	ppm	ASTM D5185m	<b>---</b>	---	0
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	0

## ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m	<b>0</b>	0	0
Barium	ppm	ASTM D5185m	<b>11</b>	0	0
Molybdenum	ppm	ASTM D5185m	<b>0</b>	0	0
Manganese	ppm	ASTM D5185m	<b>0</b>	0	0
Magnesium	ppm	ASTM D5185m	<b>13</b>	0	0
Calcium	ppm	ASTM D5185m	<b>13</b>	2	0
Phosphorus	ppm	ASTM D5185m	<b>14</b>	5	4
Zinc	ppm	ASTM D5185m	<b>71</b>	0	0
Sulfur	ppm	ASTM D5185m	<b>127</b>	0	216

## CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >25	<b>0</b>	0	0
Sodium	ppm	ASTM D5185m	<b>&lt;1</b>	0	0
Potassium	ppm	ASTM D5185m >20	<b>0</b>	0	0
Water	%	ASTM D6304 >0.1	<b>0.002</b>	0.003	0.004
ppm Water	ppm	ASTM D6304 >1000	<b>21.8</b>	36.4	44.5

## FLUID CLEANLINESS


method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >2500	<b>▲ 14458</b>	377	277
Particles >6µm	ASTM D7647 >320	<b>▲ 2235</b>	95	66
Particles >14µm	ASTM D7647 >40	<b>▲ 42</b>	7	8
Particles >21µm	ASTM D7647 >10	<b>10</b>	2	3
Particles >38µm	ASTM D7647 >3	<b>1</b>	0	0
Particles >71µm	ASTM D7647 >3	<b>0</b>	0	0
Oil Cleanliness	ISO 4406 (c) >18/15/12	<b>▲ 21/18/13</b>	16/14/10	15/13/10

## FLUID DEGRADATION


method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045	<b>0.014</b>	0.014	0.015

# OIL ANALYSIS REPORT


## ▲ Particle Trend




## Water




## Acid Number



## Water




## Viscosity @ 40°C






VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	64.0	65.8 ▲	138 ▲

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : PCA0095713 **Received** : 22 May 2023  
**Lab Number** : 05853247 **Diagnosed** : 24 May 2023  
**Unique Number** : 10482602 **Diagnostician** : Jonathan Hester  
**Test Package** : IND 2 ( Additional Tests: KF, PrtCount )

**KraftHeinz - Walton - Plant UNK**  
 261 Delaware St.  
 Walton, NY  
 US 13856  
 Contact: Cindy Scofield  
 cindy.scofield@kraft.com  
 T: (607)865-2330  
 F: (607)865-8863

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)