


PROBLEM SUMMARY

Sample Rating Trend




DIRT



Machine Id
BASIN DRILLING 105
Component
1 Pump
Fluid
BAD ASS 220 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

We advise that you check all areas where dirt can enter the system. We recommend an early resample to monitor this condition.

PROBLEMATIC TEST RESULTS

Sample Status				SEVERE	ABNORMAL	ABNORMAL
Copper	ppm	ASTM D5185m	>50	▲ 118	▲ 68	▲ 56
Silicon	ppm	ASTM D5185m	>50	▲ 277	▲ 69	▲ 108
Debris	scalar	*Visual	NONE	▲ MODER	▲ MODER	NONE

Customer Id: DELSHR
Sample No.: PCA0096198
Lab Number: 05864462
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Jonathan Hester +1 919-379-4092 x4092
jhester@wearcheckusa.com

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Resample	MISSED	Jul 12 2023	?	We recommend an early resample to monitor this condition.
Check Dirt Access	MISSED	Jul 12 2023	?	We advise that you check all areas where dirt can enter the system.

HISTORICAL DIAGNOSIS

DIRT



27 Apr 2023 Diag: Jonathan Hester

We advise that you check all areas where dirt can enter the system. Resample at the next service interval to monitor. The copper level is abnormal. All other component wear rates are normal. Elemental levels of silicon (Si) and aluminum (Al) indicate alumina-silicate (coarse dirt) ingress. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



DIRT



01 Mar 2023 Diag: Don Baldrige

We advise that you check all areas where dirt can enter the system. We recommend an early resample to monitor this condition. The copper level is abnormal. All other component wear rates are normal. Elemental levels of silicon (Si) and aluminum (Al) indicate alumina-silicate (coarse dirt) ingress. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

view report



DIRT




19 Jan 2023 Diag: Don Baldrige

We advise that you check all areas where dirt can enter the system. We recommend that you drain the oil from the component if this has not already been done. We recommend an early resample to monitor this condition. All component wear rates are normal. Elemental levels of silicon (Si) and aluminum (Al) indicate alumina-silicate (coarse dirt) ingress. The AN level is acceptable for this fluid. The oil is no longer serviceable due to the presence of contaminants.

view report



OIL ANALYSIS REPORT

Sample Rating Trend


Machine Id
BASIN DRILLING 105
 Component
1 Pump
 Fluid
BAD ASS 220 (--- GAL)

DIAGNOSIS

▲ Recommendation
 We advise that you check all areas where dirt can enter the system. We recommend an early resample to monitor this condition.

▲ Wear
 The copper level is abnormal. All other component wear rates are normal.

▲ Contamination
 Elemental levels of silicon (Si) and aluminum (Al) indicate alumina-silicate (coarse dirt) ingress. Moderate concentration of visible dirt/debris present in the oil.

● Fluid Condition
 Additive levels indicate the addition of a different brand, or type of oil. Viscosity of sample indicates oil is within ISO 150 range, advise investigate. Confirm oil type.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		PCA0096198	PCA0096211	PCA0090231
Sample Date	Client Info		31 May 2023	27 Apr 2023	01 Mar 2023
Machine Age	mls	Client Info	0	0	0
Oil Age	mls	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			SEVERE	ABNORMAL	ABNORMAL

CONTAMINATION

	method	limit/base	current	history1	history2
Water	WC Method		NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >500	219	86	134
Chromium	ppm	ASTM D5185m >7	3	2	2
Nickel	ppm	ASTM D5185m	<1	0	<1
Titanium	ppm	ASTM D5185m	6	1	2
Silver	ppm	ASTM D5185m	0	0	0
Aluminum	ppm	ASTM D5185m >25	106	21	35
Lead	ppm	ASTM D5185m >35	2	1	3
Copper	ppm	ASTM D5185m >50	118	68	56
Tin	ppm	ASTM D5185m >5	3	<1	1
Vanadium	ppm	ASTM D5185m	<1	0	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	17	21	3
Barium	ppm	ASTM D5185m	566	66	112
Molybdenum	ppm	ASTM D5185m	<1	<1	1
Manganese	ppm	ASTM D5185m	4	1	3
Magnesium	ppm	ASTM D5185m	22	7	12
Calcium	ppm	ASTM D5185m	320	62	109
Phosphorus	ppm	ASTM D5185m	242	233	187
Zinc	ppm	ASTM D5185m	30	21	36
Sulfur	ppm	ASTM D5185m	8393	6693	9991






CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >50	277	69	108
Sodium	ppm	ASTM D5185m	40	54	16
Potassium	ppm	ASTM D5185m >20	39	8	11

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.19	0.31	0.18


OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	▲ MODER	▲ MODER	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	NEG	NEG	NEG
Free Water	scalar	*Visual	NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	● 132.6	202	189

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : PCA0096198
Lab Number : 05864462
Unique Number : 10498927
Test Package : IND 2

Received : 05 Jun 2023
Tested : 09 Jun 2023
Diagnosed : 09 Jun 2023 - Jonathan Hester

DELTA FUEL COMPANY
 1000 WELLS ISLAND RD
 SHREVEPORT, LA
 US 71107
 Contact: BRAD GORDON
 bgordon@deltafuel.com
 T: (318)780-3921
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)