

# **OIL ANALYSIS REPORT**

Sample Rating Trend



946027-260305

Component

**Natural Gas Engine** 

PETRO CANADA DURON GEO LD 15W40

## DIAGNOSIS

#### Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

#### Contamination

There is no indication of any contamination in the

## **Fluid Condition**


The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.


GAL)		Feb2022	Mar2022 Nov2022	Feb2023 Apr2023 M	ay2023	
SAMPLE INFOR	MATION	method	limit/base	current	history 1	history 2
Sample Number		Client Info		GFL0084747	GFL0078181	GFL0078049
Sample Date		Client Info		21 Jun 2023	11 May 2023	19 Apr 2023
Machine Age	hrs	Client Info		0	2487	16420
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		Not Changd	Not Changd	Not Changd
Sample Status				NORMAL	NORMAL	ABNORMAL
WEAR METAL	S	method	limit/base	current	history 1	history 2
Iron	ppm	ASTM D5185m	>50	3	13	<b>△</b> 51
Chromium	ppm	ASTM D5185m	>4	<1	1	<u></u> 5
Nickel	ppm	ASTM D5185m	>2	0	<1	2
Titanium	ppm	ASTM D5185m		0	0	<1
Silver	ppm	ASTM D5185m	>3	0	0	0
Aluminum	ppm	ASTM D5185m	>9	1	6	<u>^</u> 28
Lead	ppm	ASTM D5185m	>30	0	<1	13
Copper	ppm	ASTM D5185m	>35	0	1	6
Tin	ppm	ASTM D5185m	>4	0	<1	<1
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history 1	history 2
Boron	ppm	ASTM D5185m	50	41	20	2
Barium	ppm	ASTM D5185m	5	0	0	0
Molybdenum	ppm	ASTM D5185m	50	48	56	115
Manganese	ppm	ASTM D5185m	0	<1	<1	<1
Magnesium	ppm	ASTM D5185m	560	623	553	737
Calcium	ppm	ASTM D5185m	1510	1444	1518	1819
Phosphorus	ppm	ASTM D5185m	780	781	754	916
Zinc	ppm	ASTM D5185m	870	960	928	1156
Sulfur	ppm	ASTM D5185m	2040	3013	2375	2964
CONTAMINAN	ITS	method	limit/base	current	history 1	history 2
Silicon	ppm	ASTM D5185m	>+100	8	5	14
Sodium	ppm	ASTM D5185m		2	4	8
Potassium	ppm	ASTM D5185m	>20	<1	2	2
INFRA-RED		method	limit/base	current	history 1	history 2
Soot %	%	*ASTM D7844		0.1	0.1	0
Nitration	Abs/cm	*ASTM D7624	>20	5.9	8.6	13.2
Sulfation	Abs/.1mm	*ASTM D7415	>30	19.0	20.2	28.6
FLUID DEGRA	DATION	method	limit/base	current	history 1	history 2
Oxidation	Abs/.1mm	*ASTM D7414	>25	15.5	17.2	24.2
Raco Number (RNI)	ma KOU/a	VCTM DOOUG	10.2	0.6	0.1	A 2 0

Sullur	ppm	ASTIVI DO 100III	2040	3013	23/5	2904
CONTAMINAN <sup>-</sup>	ΓS	method	limit/base	current	history 1	history 2
Silicon	ppm	ASTM D5185m	>+100	8	5	14
Sodium	ppm	ASTM D5185m		2	4	8
Potassium	ppm	ASTM D5185m	>20	<1	2	2
INFRA-RED		method	limit/base	current	history 1	history 2
Soot %	%	*ASTM D7844		0.1	0.1	0
Nitration	Abs/cm	*ASTM D7624	>20	5.9	8.6	13.2
Sulfation	Abs/.1mm	*ASTM D7415	>30	19.0	20.2	28.6
FLUID DEGRAD	ATION	method	limit/base	current	history 1	history 2
Oxidation	Abs/.1mm	*ASTM D7414	>25	15.5	17.2	24.2
Base Number (BN)	mg KOH/g	ASTM D2896	10.2	8.6	8.1	<u>^</u> 2.0



# **OIL ANALYSIS REPORT**








VISUAL		method	limit/base	current	history 1	history 2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
<b>Emulsified Water</b>	scalar	*Visual	>0.1	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG


FLUID PROPE	RHES	metnoa	ilmit/base	current	nistory i	nistory 2
Visc @ 100°C	cSt	ASTM D445	15.1	14.9	14.8	13.8

### **GRAPHS**













Certificate L2367

Laboratory Sample No. Lab Number **Unique Number** Test Package : FLEET

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : GFL0084747 : 05884943 : 10535426

Received Diagnosed

: 27 Jun 2023 : 30 Jun 2023 Diagnostician : Wes Davis

GFL Environmental - 856 - Houston South

8515 Highway 6 South Houston, TX US 77083

Contact: KEITH ROWALD krowald@gflenv.com T: (303)641-3906

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)