

# **OIL ANALYSIS REPORT**


### Sample Rating Trend

# NORMAL

# Galv Line [Galv Line] 640120-# 5 BRIDLE ROLL # 1

Gearbox

PETRO CANADA ENDURATEX EP 220 (--- GAL)





#### DIAGNOSIS

#### Recommendation

Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

#### Wear

All component wear rates are normal.

#### Contamination

There is no indication of any contamination in the

#### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

GAL)		Aug2021	Nov2021 Feb2022 May21	022 Aug2022 Nov2022 Feb2023	May2023	
SAMPLE INFOR	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PCA0095442	PCA0089466	PCA0081715
Sample Date		Client Info		23 May 2023	01 Feb 2023	22 Nov 2022
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		Not Changd	Not Changd	Not Changd
Sample Status				NORMAL	NORMAL	NORMAL
WEAR METAL	.S	method	limit/base	current	history1	history2
PQ		ASTM D8184		10	12	
Iron	ppm	ASTM D5185m	>200	15	15	18
Chromium	ppm	ASTM D5185m	>15	0	0	0
Nickel	ppm	ASTM D5185m	>15	0	0	0
Titanium	ppm	ASTM D5185m		<1	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	<1	0	<1
Lead	ppm	ASTM D5185m		0	<1	0
Copper	ppm	ASTM D5185m	>200	<1	<1	<1
Tin	ppm	ASTM D5185m		0	0	0
Vanadium	ppm	ASTM D5185m	720	<1	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES	ррпп		line it //e e e e			
		method	limit/base		history1	history2
Boron	ppm	ASTM D5185m	60	13	17	17
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	<1	<1
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m	0	3	<1	0
Calcium	ppm	ASTM D5185m	0	8	9	13
Phosphorus	ppm	ASTM D5185m	270	243	233	240
Zinc	ppm	ASTM D5185m	0	6	12	12
Sulfur	ppm	ASTM D5185m	11200	9096	8274	8633
CONTAMINAN	ITS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	1	2	3
Sodium	ppm	ASTM D5185m		<1	<1	0
Potassium	ppm	ASTM D5185m	>20	3	0	0
FLUID DEGRA	DATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.40	0.77	0.65	0.74
VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG	NEG


ocative BRAD ELLISIES DITER

**NEG** 

scalar \*Visual



## **OIL ANALYSIS REPORT**





Certificate L2367

Laboratory Sample No. Lab Number **Unique Number** 

: PCA0095442 : 05894554 : 10550364 Test Package : PLANT

To discuss this sample report, contact Customer Service at 1-800-237-1369.

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 10 Jul 2023 Diagnosed : 13 Jul 2023 : Wes Davis Diagnostician

SDI - Steel DynamicsInc. - Heartland 455 West Industrial Drive Terre Haute, IN

US 47802 Contact: BRAD ELLIS

brad.ellis@steeldynamics.com T:

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: