


# PROBLEM SUMMARY

Area  
**[98230599]**  
 Machine Id  
**TFXL32 TURBOFLO**  
 Component  
**Turbine**  
 Fluid  
**{not provided} (--- GAL)**


Sample Rating Trend



**WATER**



## COMPONENT CONDITION SUMMARY



## RECOMMENDATION

We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

## PROBLEMATIC TEST RESULTS

Sample Status				<b>ABNORMAL</b>	---	---
Water	%	ASTM D6304	>0.03	<b>▲ 0.043</b>	---	---
ppm Water	ppm	ASTM D6304	>300	<b>▲ 430</b>	---	---
Silt	scalar	*Visual	NONE	<b>▲ MODER</b>	---	---
Debris	scalar	*Visual	NONE	<b>▲ MODER</b>	---	---
Appearance	scalar	*Visual	NORML	<b>▲ LAYRD</b>	---	---
Free Water	scalar	*Visual		<b>▲ 5.0</b>	---	---

Customer Id: WHEPOR  
 Sample No.: PCA05905403  
 Lab Number: 05905403  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Doug Bogart +1 (800)237-1369 x4016  
[dougb@wearcheckusa.com](mailto:dougb@wearcheckusa.com)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Water Drain-off	---	---	?	We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid.
Alert	---	---	?	We were unable to perform a particle count due to a high concentration of particles present in this sample.


## HISTORICAL DIAGNOSIS

# OIL ANALYSIS REPORT

Sample Rating Trend

**WATER**

Area  
**[98230599]**  
 Machine Id  
**TFXL32 TURBOFLO**  
 Component  
**Turbine**  
 Fluid  
**{not provided} (--- GAL)**



## DIAGNOSIS

**Recommendation**  
 We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

**Wear**  
 All component wear rates are normal.

**Contamination**  
 There is a trace of moisture present in the oil. Free water present. There is a moderate amount of visible silt present in the sample. Moderate concentration of visible dirt/debris present in the oil.

**Fluid Condition**  
 The AN level is acceptable for this fluid.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>PCA05905403</b>	---	---
Sample Date	Client Info	<b>19 Jul 2023</b>	---	---
Machine Age	hrs Client Info	<b>0</b>	---	---
Oil Age	hrs Client Info	<b>0</b>	---	---
Oil Changed	Client Info	<b>N/A</b>	---	---
Sample Status		<b>ABNORMAL</b>	---	---

## WEAR METALS

method	limit/base	current	history1	history2
Iron ppm ASTM D5185m	>15	<b>2</b>	---	---
Chromium ppm ASTM D5185m	>4	<b>&lt;1</b>	---	---
Nickel ppm ASTM D5185m	>2	<b>0</b>	---	---
Titanium ppm ASTM D5185m		<b>0</b>	---	---
Silver ppm ASTM D5185m		<b>&lt;1</b>	---	---
Aluminum ppm ASTM D5185m	>10	<b>0</b>	---	---
Lead ppm ASTM D5185m		<b>0</b>	---	---
Copper ppm ASTM D5185m	>5	<b>&lt;1</b>	---	---
Tin ppm ASTM D5185m	>5	<b>0</b>	---	---
Vanadium ppm ASTM D5185m		<b>0</b>	---	---
Cadmium ppm ASTM D5185m		<b>0</b>	---	---

## ADDITIVES

method	limit/base	current	history1	history2
Boron ppm ASTM D5185m		<b>0</b>	---	---
Barium ppm ASTM D5185m		<b>&lt;1</b>	---	---
Molybdenum ppm ASTM D5185m		<b>0</b>	---	---
Manganese ppm ASTM D5185m		<b>0</b>	---	---
Magnesium ppm ASTM D5185m		<b>0</b>	---	---
Calcium ppm ASTM D5185m		<b>0</b>	---	---
Phosphorus ppm ASTM D5185m		<b>3490</b>	---	---
Zinc ppm ASTM D5185m		<b>0</b>	---	---
Sulfur ppm ASTM D5185m		<b>299</b>	---	---




## CONTAMINANTS

method	limit/base	current	history1	history2
Silicon ppm ASTM D5185m	>15	<b>2</b>	---	---
Sodium ppm ASTM D5185m		<b>0</b>	---	---
Potassium ppm ASTM D5185m	>20	<b>0</b>	---	---
Water % ASTM D6304	>0.03	<b>▲ 0.043</b>	---	---
ppm Water ppm ASTM D6304	>300	<b>▲ 430</b>	---	---

## FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN) mg KOH/g ASTM D8045		<b>0.10</b>	---	---

# OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2	
White Metal	scalar	*Visual	NONE	NONE	---	---
Yellow Metal	scalar	*Visual	NONE	NONE	---	---
Precipitate	scalar	*Visual	NONE	NONE	---	---
Silt	scalar	*Visual	NONE	▲ MODER	---	---
Debris	scalar	*Visual	NONE	▲ MODER	---	---
Sand/Dirt	scalar	*Visual	NONE	NONE	---	---
Appearance	scalar	*Visual	NORML	▲ LAYRD	---	---
Odor	scalar	*Visual	NORML	NORML	---	---
Emulsified Water	scalar	*Visual	>0.03	0.2%	---	---
Free Water	scalar	*Visual		▲ 5.0	---	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	33.94	---	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------

Color				no image	no image
Bottom				no image	no image

## GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : PCA05905403 **Received** : 24 Jul 2023  
**Lab Number** : 05905403 **Diagnosed** : 24 Jul 2023  
**Unique Number** : 10566759 **Diagnostician** : Doug Bogart  
**Test Package** : IND 2 ( Additional Tests: KF )

**WHEELABRATOR PORTSMOUTH - WIN-WASTE**  
 3809 ELM AVE  
 PORTSMOUTH, VA  
 US 23704  
 Contact: DEBORAH RECKART  
 dreckart@win-waste.com  
 T: (919)934-1174  
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)