

## **PROBLEM SUMMARY**


## PLANT 1 [906942399] RC-6 PLANT 1 (S/N MK61518)

**Refrigeration Compressor** 

**IRVING STAR C 4G ISO 68 (80 GAL)** 

# Sample Rating Trend ISO

#### **COMPONENT CONDITION SUMMARY**



#### RECOMMENDATION

No corrective action is recommended at this time. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS									
Sample Status			ABNORMAL	NORMAL	ATTENTION				
Particles >4µm	ASTM D7647	>10000	<u> </u>	6470	<u>▲</u> 14582				
Particles >6µm	ASTM D7647	>2500	<b>8033</b>	1554	1876				
Oil Cleanliness	ISO 4406 (c)	>20/18/15	<b>22/20/14</b>	20/18/13	<u>^</u> 21/18/10				

Customer Id: MCCEASPCA Sample No.: PCA0068401 Lab Number: 05919342 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 dougb@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

#### **RECOMMENDED ACTIONS**

There are no recommended actions for this sample.

#### HISTORICAL DIAGNOSIS

#### 13 Feb 2023 Diag: Don Baldridge

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



#### 14 Sep 2022 Diag: Don Baldridge

ISO



No corrective action is recommended at this time. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



#### 01 Mar 2022 Diag: Don Baldridge

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.







## **OIL ANALYSIS REPORT**

# PLANT 1 [906942399] RC-6 PLANT 1 (S/N MK61518)

**Refrigeration Compressor** 







#### **DIAGNOSIS**

#### Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

All component wear rates are normal.

#### Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.


#### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Sep2017	3692010	Sep2020 Sep2021 Sep2022	Jul2023	
SAMPLE INFORI	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PCA0068401	PCA0071499	PCA0056215
Sample Date		Client Info		25 Jul 2023	13 Feb 2023	14 Sep 2022
Machine Age	hrs	Client Info		74302	70648	67597
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		Not Changd	Not Changd	Not Changd
Sample Status				ABNORMAL	NORMAL	ATTENTION
WEAR METAL	S	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>8	28	25	32
Chromium	ppm	ASTM D5185m	>2	0	0	0
Nickel	ppm	ASTM D5185m		0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m	>2	<1	0	0
Aluminum	ppm	ASTM D5185m	>3	<1	<1	<1
Lead	ppm	ASTM D5185m	>2	0	<1	0
Copper	ppm	ASTM D5185m	>8	0	0	0
Tin	ppm	ASTM D5185m	>4	<1	<1	<1
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m		0	0	0
Calcium	ppm	ASTM D5185m		0	1	0
Phosphorus	ppm	ASTM D5185m		0	2	0
Zinc	ppm	ASTM D5185m		5	5	3
Sulfur	ppm	ASTM D5185m		777	669	547
CONTAMINAN		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	<1	1	1
Sodium	ppm	ASTM D5185m	00	0	0	0
Potassium	ppm	ASTM D5185m	>20	<1	0	0
Water	%	ASTM D6304		0.003	0.005	0.003
ppm Water	ppm	ASTM D6304		34.4	58.8	29.2
FLUID CLEANL	INESS		limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	▲ 31708	6470	<u>14582</u>
Particles >6µm		ASTM D7647		<u>^</u> 8033	1554	1876
Particles >14µm		ASTM D7647	>320	123	56	9
Particles >21µm		ASTM D7647	>80	8	7	0
Particles >38µm		ASTM D7647	>20	0	1	0
Particles >71µm		ASTM D7647		0	0	0
Oil Cleanliness		ISO 4406 (c)	>20/18/15	<u>22/20/14</u>	20/18/13	<u>^</u> 21/18/10
FLUID DEGRAD	OATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974	0.01	0.014	0.015	0.014



## **OIL ANALYSIS REPORT**



Test Package : IND 2 ( Additional Tests: PrtCount )

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

To discuss this sample report, contact Customer Service at 1-800-237-1369.

Certificate L2367

Contact: ROCKY DEWITT

rocky.dewitt@mccain.com

T: (207)488-1251

F: (207)488-1249