


# **PROBLEM SUMMARY**

#### Area **PLANT** 1 [906948199] Machine Id **RC-12 PLANT** 1 (S/N 23886) Component

Refrigeration Compressor

IRVING STAR C 4G ISO 68 (165 GAL)

# COMPONENT CONDITION SUMMARY



### RECOMMENDATION

We recommend you service the filters on this component. Resample at the next service interval to monitor.

Sam	Sample Rating Trend					ISO		
0ct2017	Sep2018	Sep2019	Sep2020	Sep2021	Sep2022	Jul2023		

PROBLEMATIC 7	FEST RESULTS			
Sample Status		ABNORMAI	ABNORMAL	ABNORMAL
Particles >4µm	ASTM D7647 >1	0000 🔺 130930	A 192785	165548
Particles >6µm	ASTM D7647 >2	<b>43082</b>	<b>4</b> 99147	<u> </u>
Particles >14µm	ASTM D7647 >3	20 🔺 <b>1172</b>	<u> </u>	<b>1</b> 055
Particles >21µm	ASTM D7647 >8	0 🔺 <b>106</b>	<b>4</b> 94	49
Oil Cleanliness	ISO 4406 (c) >2	0/18/15 🔺 24/23/17	▲ 25/24/20	<b>a</b> 25/23/17

Customer Id: MCCEASPCA Sample No.: PCA0079285 Lab Number: 05919351 Test Package: IND 2



To manage this report scan the QR code

*To discuss the diagnosis or test data:* Doug Bogart +1 (800)237-1369 x4016 <u>dougb@wearcheckusa.com</u>

*To change component or sample information:* Customer Service +1 1-800-237-1369 <u>customerservice@wearcheck.com</u>

RECOMMENDED	ACTIONS				
Action	Status	Date	Done By	Description	
Change Filter			?	We recommend you service the filters on this component.	

# **HISTORICAL DIAGNOSIS**



09 Feb 2023 Diag: Don Baldridge

We recommend you service the filters on this component. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

# view report

view report

## 14 Sep 2022 Diag: Don Baldridge



We recommend you service the filters on this component. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

01 Mar 2022 Diag: Don Baldridge

We recommend you service the filters on this component. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.







# **OIL ANALYSIS REPORT**

Sample Rating Trend

ISO

#### Area **PLANT** 1 [906948199] Machine Id **RC-12 PLANT** 1 (S/N 23886) Component

Refrigeration Compressor

IRVING STAR C 4G ISO 68 (165 GAL)

# DIAGNOSIS

### Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is a high amount of particulates present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


,						
		0ct2017	Sep2018 Sep2019	Sep2020 Sep2021 Sep2022	Jul2023	
SAMPLE INFOR	RMATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PCA0079285	PCA0071490	PCA0056211
Sample Date		Client Info		25 Jul 2023	09 Feb 2023	14 Sep 2022
Machine Age	hrs	Client Info		65949	67477	60081
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		Not Changd	N/A	Not Changd
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR META	LS	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>8	5	7	10
Chromium	ppm	ASTM D5185m	>2	0	0	0
Nickel	ppm	ASTM D5185m		0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m	>2	<1	0	0
Aluminum	ppm	ASTM D5185m	>3	<1	<1	<1
Lead	ppm	ASTM D5185m	>2	0	<1	0
Copper	ppm	ASTM D5185m	>8	<1	0	0
Tin	ppm	ASTM D5185m	>4	0	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m		0	0	0
Calcium	ppm	ASTM D5185m		<1	3	0
Phosphorus	ppm	ASTM D5185m		0	4	0
Zinc	ppm	ASTM D5185m		<1	1	<1
Sulfur	ppm	ASTM D5185m		582	454	518
CONTAMINA	NTS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	1	2	<1
Sodium	ppm	ASTM D5185m		0	0	0
Potassium	ppm	ASTM D5185m	>20	<1	0	0
Water	%	ASTM D6304	>0.01	0.003	0.003	0.004
ppm Water	ppm	ASTM D6304	>100	37.0	28.1	41.2
FLUID CLEAN	ILINESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	<u> 130930</u>	<b>1</b> 92785	165548
Particles >6µm		ASTM D7647	>2500	<u> </u>	<b>9</b> 9147	▲ 54452
Particles >14µm		ASTM D7647	>320	<u> </u>	<b>5</b> 468	▲ 1055
Particles >21µm		ASTM D7647	>80	<u> </u>	<b>4</b> 94	49
Particles >38µm		ASTM D7647	>20	0	10	1
Particles >71µm		ASTM D7647	>4	0	0	0
Oil Cleanliness		ISO 4406 (c)	>20/18/15	<b>4/23/17</b>	▲ 25/24/20	▲ 25/23/17
FLUID DEGRA		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974	0.01	0.014	0.015	0.045
( )	0 - 0					





Acid Number


0.05

# **OIL ANALYSIS REPORT**









Bottom

