


## **OIL ANALYSIS REPORT**

#### Sample Rating Trend



NORMAL



# BLENDER 11

Component

Gearbox

**MOBIL SHC 630 (15 GAL)** 

### DIAGNOSIS

#### Recommendation

Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

#### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

2002 0±2003 8±p2004 Aug2005 Jun2005 Jun2009 Jul2017 Ma2009 Jul2021 Jul2022 Aug20								
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2		
Sample Number		Client Info		PCA0099633	PCA0092057	PCA0073737		
Sample Date		Client Info		06 Aug 2023	02 Jun 2023	08 Aug 2022		
Machine Age	hrs	Client Info		0	0	0		
Oil Age	hrs	Client Info		0	0	0		
Oil Changed		Client Info		N/A	N/A	N/A		
Sample Status				NORMAL	ABNORMAL	NORMAL		
WEAR METALS	S	method	limit/base	current	history1	history2		
Iron	ppm	ASTM D5185m	>200	44	65	62		
Chromium	ppm	ASTM D5185m	>15	0	0	<1		
Nickel	ppm	ASTM D5185m	>15	0	0	0		
Titanium	ppm	ASTM D5185m		0	<1	0		
Silver	ppm	ASTM D5185m		0	0	0		
Aluminum	ppm	ASTM D5185m	>25	<1	<1	<1		
Lead	ppm	ASTM D5185m	>100	<1	<1	1		
Copper	ppm	ASTM D5185m	>200	<1	0	<1		
Tin	ppm	ASTM D5185m	>25	0	0	0		
Vanadium	ppm	ASTM D5185m		<1	0	0		
Cadmium	ppm	ASTM D5185m		0	0	0		
ADDITIVES		method	limit/base	current	history1	history2		
Boron	ppm	ASTM D5185m		0	<1	0		
Barium	ppm	ASTM D5185m		0	0	2		
Molybdenum	ppm	ASTM D5185m		1	2	2		
Manganese	ppm	ASTM D5185m		2	2	2		
Magnesium	ppm	ASTM D5185m		2	0	0		
Calcium	ppm	ASTM D5185m		0	<1	2		
Phosphorus	ppm	ASTM D5185m		474	439	410		
Zinc	ppm	ASTM D5185m		9	6	17		
Sulfur	ppm	ASTM D5185m		10106	10981	8506		
CONTAMINAN	TS	method	limit/base	current	history1	history2		
Silicon	ppm	ASTM D5185m	>50	15	13	12		
Sodium	ppm	ASTM D5185m		2	2	2		
Potassium	ppm	ASTM D5185m	>20	<1	0	0		
FLUID CLEANL	INESS	method	limit/base	current	history1	history2		
Particles >4µm		ASTM D7647	>10000	560	<u> </u>	451		
Particles >6µm		ASTM D7647	>2500	99	<u>24644</u>	95		
Particles >14µm		ASTM D7647	>640	6	<b>△</b> 1067	15		
Particles >21µm		ASTM D7647	>160	2	158	5		
Particles >38µm		ASTM D7647	>40	1	10	1		
Particles >71μm		ASTM D7647	>10	0	1	0		
Oil Cleanliness		ISO 4406 (c)	>20/18/16	16/14/10	<u>4</u> 24/22/17	16/14/11		
FLUID DEGRAD	ATION	method	limit/base	current	history1	history2		
	140114							

0.77


Acid Number (AN) mg KOH/g ASTM D8045

0.82

0.73



## **OIL ANALYSIS REPORT**



VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	LIGHT	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
<b>Emulsified Water</b>	scalar	*Visual	>0.2	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG

	d Nur	nber							
1.40 T					377	3777	7-7-7		
_1.20					^				
₹ 1.00				-	$\neg$	۸.۸			
N I I I								4	
€ 0.80				- +			$\sim$	1	^
흩 0.60									
Acid Number (mg KOH/g)									
0.20									
0.00					7	-			
70/6	0/0	8	9/0	1/06	2	Mar4/09	29/2	6/2	6/2
Jul29/02	Oct.1	Sep1	Aug9/05	Jun1,	Jun	Mai	Jul	Jul6/	Aug6/2
		03							

204 202 203 Visc @ 40°C cSt ASTM D445 217.7

SAMPLE IMAGES


Color

















**GRAPHS** Ferrous Alloys

60 20 Non-ferrous Metals Viscosity @ 40°C 250









Certificate L2367

Laboratory Sample No. Lab Number **Unique Number** 

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : PCA0099633 : 05919750 : 10591664

Received Diagnosed

: 09 Aug 2023 : 10 Aug 2023 Diagnostician : Don Baldridge

Test Package : IND 2 ( Additional Tests: PrtCount ) To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

KraftHeinz - New Ulm - Plant 8302

2525 S BRIDGE STREET NEW ULM, MN

US 56073 Contact: RYAN SCHMID

ryan.schmid@kraftheinz.com T: (507)568-0338

Submitted By: RYAN SCHMID

F: (507)354-7927