

PROBLEM SUMMARY

Sample Rating Trend



EISEN BEISS L-10 130 DIST

Component **Gearbox**

PETRO CANADA ENDURATEX EP 460 (75 GAL)

COMPONENT CONDITION SUMMARY

No relevant graphs to display

RECOMMENDATION

No corrective action is recommended at this time. Resample at the next service interval to monitor.

| | PROBLEMATION | CTEST | RESULT | S | | | |
|----|--------------|--------|---------|------|----------|--------|--------|
| Sa | ample Status | | | | ABNORMAL | NORMAL | NORMAL |
| D | ebris | scalar | *Visual | NONE | ▲ MODER | NONE | NONE |

Customer Id: CERCLA Sample No.: PCA0091813 Lab Number: 05921568 Test Package: PLANT

To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

22 May 2023 Diag: Angela Borella

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the component. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



15 Feb 2023 Diag: Don Baldridge

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the component. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



15 Nov 2022 Diag: Jonathan Hester

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the component. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend

VIS DEBRIS

EISEN BEISS L-10 130 DIST

Component

Gearbox

PETRO CANADA ENDURATEX EP 460 (75

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

Moderate concentration of visible dirt/debris present in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

| GAL) | | | | | | | | | | |
|--------------------|----------|-------------|------------|-------------|-------------|-------------|--|--|--|--|
| SAMPLE INFOR | MATION | method | limit/base | current | history1 | history2 | | | | |
| Sample Number | | Client Info | | PCA0091813 | PCA0091822 | PCA009189 | | | | |
| Sample Date | | Client Info | | 09 Aug 2023 | 22 May 2023 | 15 Feb 2023 | | | | |
| Machine Age | hrs | Client Info | | 0 | 0 | 0 | | | | |
| Oil Age | hrs | Client Info | | 0 | 0 | 0 | | | | |
| Oil Changed | | Client Info | | N/A | N/A | N/A | | | | |
| Sample Status | | | | ABNORMAL | NORMAL | NORMAL | | | | |
| WEAR METAL | .S | method | limit/base | current | history1 | history2 | | | | |
| PQ | | ASTM D8184 | | 17 | 21 | 21 | | | | |
| Iron | ppm | ASTM D5185m | >200 | 37 | 53 | 50 | | | | |
| Chromium | ppm | ASTM D5185m | >15 | <1 | 0 | <1 | | | | |
| Nickel | ppm | ASTM D5185m | >15 | <1 | 0 | 0 | | | | |
| Titanium | ppm | ASTM D5185m | | <1 | 0 | 0 | | | | |
| Silver | ppm | ASTM D5185m | | 0 | 0 | 0 | | | | |
| Aluminum | ppm | | >25 | 2 | 0 | 0 | | | | |
| Lead | ppm | ASTM D5185m | | 0 | <1 | 0 | | | | |
| Copper | ppm | ASTM D5185m | >200 | <1 | <1 | 0 | | | | |
| Fin | ppm | | >25 | <1 | 0 | 0 | | | | |
| √anadium | ppm | ASTM D5185m | 720 | <1 | 0 | 0 | | | | |
| Cadmium | ppm | ASTM D5185m | | 0 | 0 | 0 | | | | |
| ADDITIVES | ррш | method | limit/base | | history1 | history2 | | | | |
| Boron | ppm | ASTM D5185m | 55 | 27 | 28 | 27 | | | | |
| Barium | ppm | ASTM D5185m | | 0 | 0 | 0 | | | | |
| Molybdenum | ppm | ASTM D5185m | 0 | <1 | 1 | <1 | | | | |
| Manganese | ppm | | 0 | <1 | <1 | <1 | | | | |
| Magnesium | ppm | ASTM D5185m | 2 | 0 | <1 | <1 | | | | |
| Calcium | | ASTM D5185m | | 3 | 5 | 4 | | | | |
| | ppm | ASTM D5185m | 240 | 391 | 393 | 380 | | | | |
| Phosphorus Zinc | ppm | ASTM D5185m | | 6 | 7 | 3 | | | | |
| Sulfur | ppm | ASTM D5185m | 10310 | 5767 | 5897 | 4950 | | | | |
| | ppm | | | | | | | | | |
| CONTAMINAN | IIS | method | limit/base | current | history1 | history2 | | | | |
| Silicon | ppm | ASTM D5185m | >50 | 1 | 1 | 3 | | | | |
| Sodium | ppm | ASTM D5185m | | 3 | 0 | 0 | | | | |
| Potassium | ppm | ASTM D5185m | >20 | 2 | 1 | 2 | | | | |
| FLUID DEGRA | DATION | method | limit/base | current | history1 | history2 | | | | |
| Acid Number (AN) | mg KOH/g | ASTM D8045 | 0.5 | 1.71 | 1.66 | 1.53 | | | | |
| VISUAL | | method | limit/base | current | history1 | history2 | | | | |
| White Metal | scalar | *Visual | NONE | NONE | LIGHT | NONE | | | | |
| Yellow Metal | scalar | *Visual | NONE | NONE | NONE | NONE | | | | |
| Precipitate | scalar | *Visual | NONE | NONE | NONE | NONE | | | | |
| Silt | scalar | *Visual | NONE | NONE | NONE | NONE | | | | |
| Dobrio | acalar | *\/; | NONE | A MODED | NONE | NONE | | | | |



OIL ANALYSIS REPORT







Laboratory Sample No. Lab Number **Unique Number**

: 05921568 Test Package : PLANT

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : PCA0091813 Received : 10 Aug 2023

: 12 Aug 2023 Diagnosed : 10593482 : Don Baldridge Diagnostician

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

CERTAINTEED VINYL PLANT

2651 PENNY RD CLAREMONT, NC US 28613

Contact: BRUCE JAMES

bruce.a.james@saint-gobain.com

T: (828)459-3320 F: (828)459-3329

Contact/Location: BRUCE JAMES - CERCLA