


OIL ANALYSIS REPORT

Temper Mill [Temper Mill] 235020-HIGH PRESSURE HPU

Hydraulic System

PETRO CANADA HYDREX AW 46 (--- GAL)





DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the fluid. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the fluid is suitable for further service.

)		Nov2021 F	eb2022 May2022 Aug20	22 Nov2022 Feb2023 May2023	Aug2023	
SAMPLE INFORI	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PCA0101467	PCA0095448	PCA0089527
Sample Date		Client Info		14 Aug 2023	01 May 2023	23 Feb 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	Not Changd	Not Changd
Sample Status				NORMAL	NORMAL	NORMAL
WEAR METAL	S	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>20	<1	0	<1
Chromium	ppm	ASTM D5185m	>20	0	0	0
Nickel	ppm	ASTM D5185m	>20	0	0	0
Titanium	ppm	ASTM D5185m		0	<1	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m		0	<1	0
Lead	ppm	ASTM D5185m	>20	0	0	0
Copper	ppm	ASTM D5185m		2	2	2
Tin	ppm	ASTM D5185m	>20	0	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	0	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0	<1
Manganese	ppm	ASTM D5185m	0	0	0	0
Magnesium	ppm	ASTM D5185m	0	4	7	6
Calcium	ppm	ASTM D5185m	50	62	57	65
Phosphorus	ppm	ASTM D5185m	330	336	321	333
Zinc	ppm	ASTM D5185m	430	407	393	419
Sulfur	ppm	ASTM D5185m	760	1456	1411	1575
CONTAMINAN	TS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	0	0	<1
Sodium	ppm	ASTM D5185m		1	<1	0
Potassium	ppm	ASTM D5185m	>20	0	0	<1
FLUID CLEANL	INESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>5000	210	1876	518
Particles >6µm		ASTM D7647	>1300	69	591	133
Particles >14µm		ASTM D7647	>160	9	37	11
Particles >21µm		ASTM D7647		2	10	4
Particles >38µm		ASTM D7647	>10	0	1	1
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>19/17/14	15/13/10	18/16/12	16/14/11
FLUID DEGRAD			limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.70	0.28	0.26	0.24



OIL ANALYSIS REPORT







Laboratory Sample No.

Lab Number **Unique Number**

: PCA0101467 : 05924164 : 10604111 Test Package : PLANT

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 14 Aug 2023 Diagnosed : 15 Aug 2023

: Don Baldridge Diagnostician

SDI - Steel DynamicsInc. - Heartland 455 West Industrial Drive

Terre Haute, IN US 47802

Contact: BRAD ELLIS brad.ellis@steeldynamics.com

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:

F: