

OIL ANALYSIS REPORT

Sample Rating Trend


NORMAL



[Temper Mill] 210050-OPERATOR PAYOFF REEL

Gearbox

PETRO CANADA ENDURATEX EP 220 (--- GAL)





DIAGNOSIS

Recommendation

Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

GAL)		Nov2021	eb2022 May2022 Aug20	22 Nov2022 Feb2023 May2023	Aug2023	
SAMPLE INFOR	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PCA0101485	PCA0095456	PCA0089535
Sample Date		Client Info		01 Aug 2023	23 May 2023	23 Feb 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	Not Changd	Not Changd
Sample Status				NORMAL	NORMAL	NORMAL
WEAR METAL	S	method	limit/base	current	history1	history2
PQ		ASTM D8184		53	52	47
Iron	ppm	ASTM D5185m	>200	72	65	52
Chromium	ppm	ASTM D5185m	>15	1	1	1
Nickel	ppm	ASTM D5185m	>15	0	0	<1
Titanium	ppm	ASTM D5185m		0	<1	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	<1	1	<1
Lead	ppm	ASTM D5185m	>100	<1	<1	0
Copper	ppm	ASTM D5185m	>200	15	13	10
Tin	ppm	ASTM D5185m	>25	0	0	0
Vanadium	ppm	ASTM D5185m		0	<1	0
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	60	2	2	2
Barium	ppm	ASTM D5185m	0	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	<1	<1
Manganese	ppm	ASTM D5185m	0	1	1	<1
Magnesium	ppm	ASTM D5185m	0	<1	2	0
Calcium	ppm	ASTM D5185m	0	9	11	10
Phosphorus	ppm	ASTM D5185m	270	227	215	179
Zinc	ppm	ASTM D5185m	0	10	10	10
Sulfur	ppm	ASTM D5185m	11200	14311	14587	11897
CONTAMINAN	ITS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	6	5	4
Sodium	ppm	ASTM D5185m		2	2	0
Potassium	ppm	ASTM D5185m	>20	3	5	2
FLUID DEGRAI	OATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.40	0.41	0.42	0.35
VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG	NEG
					11 D D 1 D 1	I I I I I I I I I I I I I I I I I I I


scalar *Visual

NEG

ocative BRAD ELLISIES DITER



OIL ANALYSIS REPORT







Certificate L2367

Laboratory Sample No. Lab Number **Unique Number**

: PCA0101485 : 05924426

: 10604373 Test Package : PLANT

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 14 Aug 2023

: 15 Aug 2023 Diagnosed : Wes Davis Diagnostician

SDI - Steel DynamicsInc. - Heartland

455 West Industrial Drive Terre Haute, IN US 47802

Contact: BRAD ELLIS brad.ellis@steeldynamics.com

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: SDITER [WUSCAR] 05924426 (Generated: 08/15/2023 15:31:15) Rev: 1

Contact/Location: BRAD ELLIS - SDITER

T:

F: