


# **PROBLEM SUMMARY**

## KR-GR-000325-SOUTH - 15000 LB MIXER (S/N MIX D - 11513074) Component **Gear Reducer** Fluic



# COMPONENT CONDITION SUMMARY Water 3.00 2.50





## RECOMMENDATION

We advise that you check for the source of water entry. We recommend an early resample to monitor this condition.

PROBLEMATIC TEST RESULTS								
Sample Status				SEVERE	ATTENTION	ABNORMAL		
Water	%	ASTM D6304	>0.1	<b>e</b> 1.06		<b>0.864</b>		
ppm Water	ppm	ASTM D6304	>1000	🛑 10600		▲ 8640		
Emulsified Water	scalar	*Visual	>0.1	• 0.2%	NEG	▲ 0.2%		

Customer Id: KRAKIR Sample No.: PCA0101927 Lab Number: 05926499 Test Package: IND 1



To manage this report scan the QR code

To discuss the diagnosis or test data: Jonathan Hester +1 919-379-4092 x4092 ihester@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS							
Action	Status	Date	Done By	Description			
Resample			?	We recommend an early resample to monitor this condition.			
Check Water Access			?	We advise that you check for the source of water entry.			

## HISTORICAL DIAGNOSIS



## 31 Jul 2023 Diag: Jonathan Hester

No corrective action is recommended at this time. Resample at the next service interval to monitor.All component wear rates are normal. There is no indication of any contamination in the oil. Viscosity of sample indicates oil is within ISO 68 range, advise investigate. Confirm oil type. The AN level is acceptable for this fluid.





We advise that you check for the source of water entry. We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition.All component wear rates are normal. Appearance is milky. There is a high amount of visible silt present in the sample. There is a high concentration of water present in the oil. The condition of the oil is acceptable for the time in service.

#### 23 Jan 2023 Diag: Don Baldridge





We advise that you check for the source of water entry. Resample at the next service interval to monitor.All component wear rates are normal. Appearance is hazy. There is a moderate concentration of water present in the oil. The condition of the oil is acceptable for the time in service.





view report

#### view report





## **OIL ANALYSIS REPORT**

#### Sample Rating Trend

# WATER

Machine Id KR-GR-000325-SOUTH - 15000 LB MIXER (S/N MIX D - 11513074) Component Gear Reducer

Fluid PETRO CANADA 220 (50 QTS)

## DIAGNOSIS

#### Recommendation

We advise that you check for the source of water entry. We recommend an early resample to monitor this condition.

### Wear

All component wear rates are normal.

#### Contamination

There is a high concentration of water present in the oil.

#### Fluid Condition


The condition of the oil is acceptable for the time in service.

SAMPLE INFOR	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PCA0101927	PCA0102536	PCA0093103
Sample Date		Client Info		16 Aug 2023	31 Jul 2023	23 Apr 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				SEVERE	ATTENTION	ABNORMAL
WEAR METAL	.S	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>150	46	0	45
Chromium	ppm	ASTM D5185m	>10	<1	0	<1
Nickel	ppm	ASTM D5185m	>10	0	0	0
Titanium	ppm	ASTM D5185m		0	<1	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	0	0	0
Lead	ppm	ASTM D5185m	>100	0	0	<1
Copper	ppm	ASTM D5185m		<1	<1	<1
Tin	ppm	ASTM D5185m	>10	<1	0	<1
Vanadium	ppm	ASTM D5185m		0	<1	0
Cadmium	ppm	ASTM D5185m		<1	<1	<1
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		50	0	40
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		271	0	273
Manganese	ppm	ASTM D5185m		2	<1	2
Magnesium	ppm	ASTM D5185m		2	2	1
Calcium	ppm	ASTM D5185m		100	0	106
Phosphorus	ppm	ASTM D5185m		940	197	978
Zinc	ppm	ASTM D5185m		101	0	118
Sulfur	ppm	ASTM D5185m		22901	210	24065
CONTAMINAN	ITS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	11	<1	12
Sodium	ppm	ASTM D5185m		19	1	18
Potassium	ppm	ASTM D5185m	>20	3	2	3
Water	%	ASTM D6304	>0.1	🛑 1.06		▲ 0.864
ppm Water	ppm	ASTM D6304	>1000	• 10600		▲ 8640
VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	A HEAVY
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	🔺 MILKY
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	• 0.2%	NEG	▲ 0.2%
		*Visual		NEG	NEG	NEG


Contact/Location: WALLACE WARD - KRAKIR



# **OIL ANALYSIS REPORT**



FLUID PRO	PERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445		209	▲ 66.6	208
SAMPLE IM	AGES	method	limit/base	current	history1	history2
Color				no image		
Bottom				no image		



KraftHeinz - Kirksville - Plant 8333 PCA 2504 INDUSTRIAL DR KIRKSVILLE, MO US 63501 Contact: WALLACE WARD wallace.ward@kraftheinzcompany.com T: (660)627-1031 F: (660)627-5887



Unique Number : 10606446 Diagnostician : Jonathan Hester Test Package : IND 1 (Additional Tests: KF) Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369. \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Laboratory

Sample No.