


OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



FRICK FRICK 706 (S/N 201164)

Compressor

PETRO CANADA REFLO SYNTHETIC 68A LOW TEMP FLUID (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the

Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

V TEIVIP FLOID (-	GAL)	Sep2020	Feb2021 Feb2022	. Aug2022 Mar2023	Aug2023	
SAMPLE INFOR	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PCA0102074	PCA0092594	PCA0067424
Sample Date		Client Info		16 Aug 2023	09 Mar 2023	10 Aug 2022
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL
WEAR METAL	.S	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	0	0
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m		0	<1	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	0	<1	0
_ead	ppm	ASTM D5185m	>25	0	0	0
Copper	ppm	ASTM D5185m	>50	<1	<1	0
Γin	ppm	ASTM D5185m	>15	<1	0	0
Antimony	ppm	ASTM D5185m				
√anadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	<1
Barium	ppm	ASTM D5185m	0	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		<1	0	0
Magnesium	ppm	ASTM D5185m	0	0	0	0
Calcium	ppm	ASTM D5185m	0	<1	0	0
Phosphorus	ppm	ASTM D5185m	0	2	0	4
Zinc	ppm	ASTM D5185m	0	0	0	0
Sulfur	ppm	ASTM D5185m	0	31	22	17
CONTAMINAN	ITS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	1	<1
Sodium	ppm	ASTM D5185m		2	0	0
Potassium	ppm	ASTM D5185m	>20	0	<1	0
Water	%	ASTM D6304	>0.1	0.001	0.003	
ppm Water	ppm	ASTM D6304	>1000	12.4	31.2	
FLUID DEGRA	OITAC	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.1	0.015	0.03	





OIL ANALYSIS REPORT





Aug 10/22









Laboratory Sample No.

Lab Number **Unique Number**

: PCA0102074 : 05931623 : 10616894

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 22 Aug 2023 Diagnosed Diagnostician : Angela Borella Test Package : IND 2 (Additional Tests: KF, PrtCount)

: 24 Aug 2023

SMITHFIELD FOODS ONE SWEET APPLEWOOD LANE CUDAHY, WI

> US 53110 Contact: PETE LERAY pleray@smithfield.com

T: (414)918-3258

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: