

# **OIL ANALYSIS REPORT**

## Sample Rating Trend

**NORMAL** 



# Pickle Line [Pickle Line] 545010-SBRKR ENT BRDL ROLL # 1

Gearbox

PETRO CANADA ENDURATEX EP 220 (---

# DIAGNOSIS

### Recommendation

Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

### Wear

All component wear rates are normal.

### Contamination

There is no indication of any contamination in the

### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

GAL)		Aug2021 No	v2021 Feb2022 May2022	Aug2022 Nov2022 Feb2023 May20	23 Aug2023	
SAMPLE INFOR	RMATIO	V method	limit/base	current	history1	history2
Sample Number		Client Info		PCA0101449	PCA0095385	PCA0081766
Sample Date		Client Info		22 Aug 2023	23 May 2023	23 Feb 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	Not Changd	Not Changd
Sample Status				NORMAL	NORMAL	NORMAL
WEAR METAI	LS	method	limit/base	current	history1	history2
PQ		ASTM D8184		14	7	28
Iron	ppm	ASTM D5185m	>200	5	29	33
Chromium	ppm	ASTM D5185m	>15	0	<1	<1
Nickel	ppm	ASTM D5185m	>15	0	<1	<1
Titanium	ppm	ASTM D5185m		0	0	<1
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	<1	<1	<1
Lead	ppm	ASTM D5185m	>100	0	0	<1
Copper	ppm	ASTM D5185m	>200	<1	0	<1
Tin	ppm	ASTM D5185m	>25	0	0	0
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	60	73	4	12
Barium	ppm	ASTM D5185m	0	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0	<1
Manganese	ppm	ASTM D5185m	0	<1	<1	<1
Magnesium	ppm	ASTM D5185m	0	<1	0	<1
Calcium	ppm	ASTM D5185m	0	2	2	20
Phosphorus	ppm	ASTM D5185m	270	283	129	300
Zinc	ppm	ASTM D5185m	0	0	1	12

CONTAMINANTS metho		method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m	11200	8186	7896	10939
Zinc	ppm	ASTM D5185m	0	0	1	12
Phosphorus	ppm	ASTM D5185m	270	283	129	300
Calcium	ppm	ASTM D5185m	0	2	2	20
Magnesium	ppm	ASTM D5185m	0	<1	0	<1
Manganese	ppm	ASTM D5185m	0	<1	<1	<1
Molybdenum	ppm	ASTM D5185m	0	0	0	<1
Barium	ppm	ASTM D5185m	0	0	0	0
20.0	P P		00	. •		. —

Silicon	ppm	ASTM D5185m	>50	5	6	5
Sodium	ppm	ASTM D5185m		<1	<1	2
Potassium	ppm	ASTM D5185m	>20	1	2	<1
ELLUD DECE						

I LOID DEGITAL	יוטוואכ	method			Thistory	Tilotol y Z
Acid Number (AN)	mg KOH/g	ASTM D8045	0.40	0.46	0.26	0.56
VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
<b>Emulsified Water</b>	scalar	*Visual	>0.2	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	ocative BRAD E	LLISIESDITER



# **OIL ANALYSIS REPORT**







Laboratory Sample No. Lab Number **Unique Number** 

: 05932895 : 10618166 Test Package : PLANT

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : PCA0101449 Received : 23 Aug 2023

: 24 Aug 2023 Diagnosed Diagnostician : Wes Davis

SDI - Steel DynamicsInc. - Heartland

455 West Industrial Drive Terre Haute, IN US 47802

Contact: BRAD ELLIS brad.ellis@steeldynamics.com

To discuss this sample report, contact Customer Service at 1-800-237-1369. \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: SDITER [WUSCAR] 05932895 (Generated: 08/24/2023 15:43:40) Rev: 1

Contact/Location: BRAD ELLIS - SDITER

T:

F: