

OIL ANALYSIS REPORT







Machine Id GEHSK 4 Component Natural Gas Engine Fluid AMSOIL SYN TURBO ISO VG 32 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor. NOTE: one of two samples received with same ID and sampling date.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	NATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PCA0099977		
Sample Date		Client Info		05 Sep 2023		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				NORMAL		
WEAR METALS	S	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0		
Chromium	ppm	ASTM D5185m	>4	0		
Nickel	ppm	ASTM D5185m	>2	0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m	>3	0		
Aluminum	ppm	ASTM D5185m	>9	0		
Lead	ppm	ASTM D5185m	>30	0		
Copper	ppm	ASTM D5185m	>35	0		
Tin	ppm	ASTM D5185m	>4	0		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		6		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m		4		
Calcium	ppm	ASTM D5185m		0		
Phosphorus	ppm	ASTM D5185m		22		
Zinc	ppm	ASTM D5185m		3		
Sulfur	ppm	ASTM D5185m		732		
CONTAMINAN	TS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>+100	<1		
Sodium	ppm	ASTM D5185m		0		
Potassium	ppm	ASTM D5185m	>20	0		
FLUID CLEANL	INESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>20000	1738		
Particles >6µm		ASTM D7647	>5000	530		
Particles >14µm		ASTM D7647	>640	46		
Particles >21µm		ASTM D7647	>160	10		
Particles >38µm		ASTM D7647	>40	1		
Particles >71µm		ASTM D7647	>10	0		
Oil Cleanliness		ISO 4406 (c)	>21/19/16	18/16/13		
FLUID DEGRAD	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.071		
Base Number (BN)	mg KOH/g	ASTM D2896		0.25		



(10°C)

30

25

25

Ê 20

-151

10

0k

6.

4

41

cSt (40°C)

30

2

Abnorma


Abn


Particle Trend

14µm


St

OIL ANALYSIS REPORT





Viscosity @ 100°C 3.5 Sep5/2 Viscosity @ 40°C



Acid Number

0.08

0.07 60.06 MOX 0.06

¥0.05

50.04

- D 0.02

0.01

0.00

sep5/23

Ĕ Certificate L2367

Test Package : MOB 2 (Additional Tests: KV40, PrtCount, VI)

Received

Diagnosed

Viscosity @ 100°C

7 !

6

()001 5.5

3.5

Laboratory

Sample No.

Lab Number

Unique Number

Sep5/23

Abnorma

: PCA0099977

: 05945348

: 10635960

cSt (

F: