OIL DIAGNOSTICS

PROBLEM SUMMARY

Sample Rating Trend



WATER

Area
[98405046]
Machine Id
KR-GR-000825 - DOUFLEX B2 CRANE
Component
Hoist
Fluid
MOBIL GLYGOYLE HE ISO 460 (--- GAL)

COMPONENT CONDITION SUMMARY

Water



Particle Trend



RECOMMENDATION

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
Water	%	ASTM D6304	>0.05	▲ **0.129**	---	---
ppm Water	ppm	ASTM D6304	>500	▲ **1290**	---	---
Particles >4µm		ASTM D7647	>5000	▲ **52613**	---	---
Particles >6µm		ASTM D7647	>1300	▲ **43811**	---	---
Particles >14µm		ASTM D7647	>160	▲ **19350**	---	---
Particles >21µm		ASTM D7647	>40	▲ **10125**	---	---
Particles >38µm		ASTM D7647	>10	▲ **1773**	---	---
Particles >71µm		ASTM D7647	>3	▲ **114**	---	---
Oil Cleanliness		ISO 4406 (c)	>19/17/14	▲ **23/23/21**	---	---

Customer Id: KRAKIR
Sample No.: PCA0102560
Lab Number: 05945710
Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data:
Jonathan Hester +1 919-379-4092 x4092
jhester@wearcheckusa.com

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component if applicable.

HISTORICAL DIAGNOSIS

23 May 2023 Diag: Jonathan Hester

DIRT

No corrective action is recommended at this time. Resample at the next service interval to monitor.All component wear rates are normal. Elemental level of silicon (Si) above normal indicating ingress of seal material. The oil viscosity is higher than normal. The condition of the oil is acceptable for the time in service.

view report

22 Feb 2023 Diag: Don Baldridge

DIRT

No corrective action is recommended at this time. Resample at the next service interval to monitor.All component wear rates are normal. Elemental level of silicon (Si) above normal. The condition of the oil is acceptable for the time in service.

view report

24 Nov 2022 Diag: Jonathan Hester

NORMAL

Resample at the next service interval to monitor.All component wear rates are normal. There is no indication of any contamination in the oil. The condition of the oil is acceptable for the time in service.

view report

OIL DIAGNOSTICS

OIL ANALYSIS REPORT

Sample Rating Trend



WATER

Area
[98405046]
Machine Id
KR-GR-000825 - DOUFLEX B2 CRANE
Component
Hoist
Fluid
MOBIL GLYGOYLE HE ISO 460 (--- GAL)

DIAGNOSIS

▲ Recommendation

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

▲ Contamination

There is a high amount of particulates present in the oil. There is a light concentration of water present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number		Client Info		**PCA0102560**	PCA0097176	PCA0090207
Sample Date		Client Info		**05 Sep 2023**	23 May 2023	22 Feb 2023
Machine Age	hrs	Client Info		**0**	0	0
Oil Age	hrs	Client Info		**0**	0	0
Oil Changed		Client Info		**N/A**	N/A	N/A
Sample Status				**ABNORMAL**	ABNORMAL	ABNORMAL

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>20	**11**	9	4
Chromium	ppm	ASTM D5185m	>20	**0**	<1	<1
Nickel	ppm	ASTM D5185m	>20	**0**	<1	0
Titanium	ppm	ASTM D5185m		**0**	0	0
Silver	ppm	ASTM D5185m		**0**	0	0
Aluminum	ppm	ASTM D5185m	>20	**1**	<1	<1
Lead	ppm	ASTM D5185m	>20	**0**	0	0
Copper	ppm	ASTM D5185m	>20	**<1**	<1	<1
Tin	ppm	ASTM D5185m	>20	**0**	0	0
Vanadium	ppm	ASTM D5185m		**<1**	0	0
Cadmium	ppm	ASTM D5185m		**0**	0	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		**0**	0	0
Barium	ppm	ASTM D5185m		**0**	0	0
Molybdenum	ppm	ASTM D5185m		**48**	13	1
Manganese	ppm	ASTM D5185m		**0**	0	0
Magnesium	ppm	ASTM D5185m		**0**	<1	<1
Calcium	ppm	ASTM D5185m		**7**	5	9
Phosphorus	ppm	ASTM D5185m		**392**	319	75
Zinc	ppm	ASTM D5185m		**0**	5	39
Sulfur	ppm	ASTM D5185m		**2689**	653	531

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	**6**	▲ 21	▲ 17
Sodium	ppm	ASTM D5185m		**1**	3	3
Potassium	ppm	ASTM D5185m	>20	**<1**	2	0
Water	%	ASTM D6304	>0.05	▲ **0.129**	---	---
ppm Water	ppm	ASTM D6304	>500	▲ **1290**	---	---

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>5000	▲ **52613**	---	---
Particles >6µm		ASTM D7647	>1300	▲ **43811**	---	---
Particles >14µm		ASTM D7647	>160	▲ **19350**	---	---
Particles >21µm		ASTM D7647	>40	▲ **10125**	---	---
Particles >38µm		ASTM D7647	>10	▲ **1773**	---	---
Particles >71µm		ASTM D7647	>3	▲ **114**	---	---
Oil Cleanliness		ISO 4406 (c)	>19/17/14	▲ **23/23/21**	---	---

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		**0.68**	---	---

OIL ANALYSIS REPORT

OIL DIAGNOSTICS

Water



Particle Trend



Particle Trend



Acid Number



Viscosity @ 40°C



VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	**NONE**	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	**NONE**	NONE	NONE
Precipitate	scalar	*Visual	NONE	**NONE**	NONE	NONE
Silt	scalar	*Visual	NONE	**NONE**	NONE	NONE
Debris	scalar	*Visual	NONE	**NONE**	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	**NONE**	NONE	NONE
Appearance	scalar	*Visual	NORML	**LAYRD**	NORML	NORML
Odor	scalar	*Visual	NORML	**NORML**	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	**0.2%**	NEG	NEG
Free Water	scalar	*Visual		**NEG**	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	460	**473**	▲ 563	527

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

GRAPHS

Ferrous Alloys



Non-ferrous Metals



Viscosity @ 40°C



Particle Count



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : PCA0102560 **Received** : 08 Sep 2023
Lab Number : 05945710 **Diagnosed** : 15 Sep 2023
Unique Number : 10636322 **Diagnostician** : Jonathan Hester
Test Package : IND 2 (Additional Tests: KF)

To discuss this sample report, contact Customer Service at 1-800-237-1369.
** - Denotes test methods that are outside of the ISO 17025 scope of accreditation.*
Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

KraftHeinz - Kirksville - Plant 8333 PCA
2504 INDUSTRIAL DR
KIRKSVILLE, MO
US 63501
Contact: WALLACE WARD
wallace.ward@kraftheinzcompany.com
T: (660)627-1031
F: (660)627-5887