

OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL

TPO - Top Extrusion Calender Roll [T3290] **CALENDER 2 ROLL 1 (S/N G129615)** Component


Gearbox Fluid

PETRO CANADA PURITY FG PAG GEAR OIL 220 (38 LTR)

DIAGNOSIS	SAMPLE INFOR	MATION	method	limit/base	current	history1	history2
Recommendation	Sample Number		Client Info		PCA0106216		
Resample at the next service interval to monitor.	Sample Date		Client Info		12 Sep 2023		
Wear	Machine Age	yrs	Client Info		3		
All component wear rates are normal.	Oil Age	yrs	Client Info		3		
Contamination	Oil Changed		Client Info		Not Changd		
There is no indication of any contamination in the	Sample Status				NORMAL		
oil.	WEAR METAL	S	method	limit/base	current	history1	history2
Fluid Condition The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.	Iron	ppm	ASTM D5185m	>200	5		
	Chromium	ppm	ASTM D5185m		0		
	Nickel	ppm	ASTM D5185m		0		
	Titanium	ppm	ASTM D5185m		0		
	Silver	ppm	ASTM D5185m		0		
	Aluminum	ppm	ASTM D5185m	>25	0		
	Lead	ppm	ASTM D5185m		0		
	Copper	ppm	ASTM D5185m		0		
	Tin	ppm	ASTM D5185m		<1		
	Vanadium	ppm	ASTM D5185m		0		
	Cadmium	ppm	ASTM D5185m		0		
	ADDITIVES		method	limit/base	current	history1	history2
	Boron	ppm	ASTM D5185m		4		
	Barium	ppm	ASTM D5185m		0		
	Molybdenum	ppm	ASTM D5185m		0		
	Manganese	ppm	ASTM D5185m		<1		
	Magnesium	ppm	ASTM D5185m		0		
	Calcium	ppm	ASTM D5185m		0		
	Phosphorus	ppm	ASTM D5185m		516		
	Zinc	ppm	ASTM D5185m		0		
	Sulfur	ppm	ASTM D5185m		109		
	CONTAMINAN	NTS	method	limit/base	current	history1	history2
	Silicon	ppm	ASTM D5185m	>50	7		
	Sodium	ppm	ASTM D5185m		0		
	Potassium	ppm	ASTM D5185m	>20	2		
	FLUID DEGRA	DATION	method	limit/base	current	history1	history2
	Acid Number (AN)	mg KOH/g	ASTM D8045	0.65	0.156		
	VISUAL		method	limit/base	current	history1	history2
	White Metal	scalar	*Visual	NONE	NONE		
	Yellow Metal	scalar	*Visual	NONE	NONE		
	Precipitate	scalar	*Visual	NONE	NONE		
	Silt	scalar	*Visual	NONE	NONE		
	Debris	scalar	*Visual	NONE	LIGHT		
	Sand/Dirt	scalar	*Visual	NONE	NONE		
	Appearance	scalar	*Visual	NORML	NORML		
	Odor	scalar	*Visual	NORML	NORML		
	Emulsified Water	scalar	*Visual	>0.2	NEG		
	Free Water	scalar	*Visual		NEG		
	0 10.40.00) David				<u>c</u> .	dense fatter al IDS of 1,111	



OIL ANALYSIS REPORT



IKO HAGERSTOWN 160 IKO WAY HAGERSTOWN, MD US 21740 Contact: LUIS FERNANDEZ luis.fernandez@iko.com T: (240)267-4100 F:

no image

no image

no image

no image



 Certificate 12367
 Test Package
 : PLANT

 To discuss this sample report, contact Customer Service at 1-800-237-1369.
 *

 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Diagnostician : Doug Bogart

Unique Number : 10648146

Page 2 of 2

Sepi