

PROBLEM SUMMARY

Sample Rating Trend

VISCOSITY


VISCOSITY

DRYING [908003265] [DRYING] DB-13019 DB-13019 Component

Gearbox

PETRO CANADA PURITY FG SYNTH EP GEAR 220 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

No corrective action is recommended at this time. Resample at the next service interval to monitor.

DDODI	CNANTIO	TEOT	TOLU TO
PROBL	HMA HC	HSIF	RESULTS

	Sample Status				ATTENTION	ATTENTION	NORMAL		
	Visc @ 40°C	cSt	ASTM D445	221	176	<u>▲</u> 175	213		

Customer Id: HERHER Sample No.: PCA0100839 Lab Number: 05966470 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

25 Jan 2023 Diag: Jonathan Hester

VISCOSITY



No corrective action is recommended at this time. Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The oil viscosity is lower than normal. Confirm oil type. The AN level is acceptable for this fluid.



18 Jul 2022 Diag: Wes Davis

NORMAL



Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. All component wear rates are normal. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report

22 Oct 2021 Diag: Wes Davis

NORMAL



Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. All component wear rates are normal. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend

VISCOSITY



DRYING [908003265] [DRYING] DB-13019 DB-13019

Gearbox

PETRO CANADA PURITY FG SYNTH EP GEAR 220 (--- GAL

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the

▲ Fluid Condition

The oil viscosity is lower than normal. Confirm oil type. The AN level is acceptable for this fluid.

3	019						
ì	EAR 220 (GAL	-)	Mar2015 Jr	ul2016 Apr2018 May	2019 Sep.2020 Oct2021	Jan2023	
	SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
	Sample Number		Client Info		PCA0100839	PCA0078589	PCA0069150
	Sample Date		Client Info		10 Sep 2023	25 Jan 2023	18 Jul 2022
	Machine Age	hrs	Client Info		0	0	0
	Oil Age	hrs	Client Info		0	0	0
	Oil Changed		Client Info		N/A	N/A	N/A
	Sample Status				ATTENTION	ATTENTION	NORMAL
	WEAR METALS	S	method	limit/base	current	history1	history2
	PQ		ASTM D8184		20	13	19
	Iron	ppm	ASTM D5185m	>200	3	11	7
	Chromium	ppm	ASTM D5185m	>15	0	0	0
	Nickel	ppm	ASTM D5185m	>15	0	0	0

Chromium	ppm	ASTM D5185m	>15	0	0	0
Nickel	ppm	ASTM D5185m	>15	0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	<1	0	0
Lead	ppm	ASTM D5185m	>100	0	0	0
Copper	ppm	ASTM D5185m	>200	3	6	3
Tin	ppm	ASTM D5185m	>25	0	0	0
Antimony	ppm	ASTM D5185m	>5			
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Boron Barium	ppm ppm	ASTM D5185m ASTM D5185m		0	0	0 <1
	• •					-
Barium	ppm	ASTM D5185m		0	0	<1
Barium Molybdenum	ppm ppm	ASTM D5185m ASTM D5185m		0	0	<1
Barium Molybdenum Manganese	ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m		0 0 0	0 0	<1 0 0
Barium Molybdenum Manganese Magnesium	ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m		0 0 0 0	0 0 0 0	<1 0 0 0
Barium Molybdenum Manganese Magnesium Calcium	ppm ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m		0 0 0 0	0 0 0 0	<1 0 0 0 0
Barium Molybdenum Manganese Magnesium Calcium Phosphorus	ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m		0 0 0 0 0 0 379	0 0 0 0 0 0 440	<1 0 0 0 0 2 341
Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc	ppm ppm ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	limit/base	0 0 0 0 0 0 379	0 0 0 0 0 0 440 6	<1 0 0 0 0 2 341 <1
Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur	ppm ppm ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m		0 0 0 0 0 0 379 0 834	0 0 0 0 0 440 6 906	<1 0 0 0 0 2 341 <1 969

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	14	11	13
Sodium	ppm	ASTM D5185m		0	0	<1
Potassium	ppm	ASTM D5185m	>20	<1	0	0
ELLID DECDAI	ATION	l mothod	limit/baco	current	hictory1	hictory?

mg KOH/g ASTM D8045 0.59

0.50


Acid Number (AN)

0.66

0.43



OIL ANALYSIS REPORT







Certificate L2367

Laboratory Sample No. Lab Number **Unique Number**

: 05966470 : 10673021

160

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : PCA0100839

: 02 Oct 2023 Received Diagnosed

: 04 Oct 2023 : Don Baldridge

00.00 PG

Diagnostician

Test Package : IND 2 (Additional Tests: PQ) To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

THE HERSHEY COMPANY

WEST HERSHEY - TECHNICAL ASSURANCE, 1033 OLDE WEST CHOCOLATE

HERSHEY, PA US 17033

Contact: CLINTON ZOHNER

clintzohner@hersheys.com T: (717)374-4846

F: (717)374-4594