

OIL ANALYSIS REPORT

Sample Rating Trend

SAMPLE INFORMATION method limit/base





9158 Component Natural Gas Engine Fluid

PETRO CANADA DURON GEO LD 15W40 (--- GAL)

DIAGNOSIS
Recommendation

Resample at the next service interval to monitor.

Machine Id

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

		methou	iiiiii/base	Guirent	nistory i	nistoryz	
Sample Number		Client Info		GFL0090112	GFL0074972	GFL0047429	
Sample Date		Client Info		03 Oct 2023	21 Sep 2023	13 Feb 2023	
Machine Age	hrs	Client Info		16492	16463	15382	
Oil Age	hrs	Client Info		600	600	600	
Oil Changed		Client Info		Changed	Changed	Changed	
Sample Status				NORMAL	ABNORMAL	NORMAL	
WEAR METALS		method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>50	9	33	19	
Chromium	ppm	ASTM D5185m	>4	<1	<u> </u>	1	
Nickel	ppm	ASTM D5185m	>2	<1	1	<1	
Titanium	ppm	ASTM D5185m		0	<1	0	
Silver	ppm	ASTM D5185m	>3	0	0	0	
Aluminum	ppm	ASTM D5185m	>9	5	9	6	
Lead	ppm	ASTM D5185m	>30	0	<1	1	
Copper	ppm	ASTM D5185m	>35	<1	30	4	
Tin	ppm	ASTM D5185m	>4	0	<1	<1	
Vanadium	ppm	ASTM D5185m		0	<1	0	
Cadmium	ppm	ASTM D5185m		0	0	0	
ADDITIVES		method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m	50	40	15	18	
Barium	ppm	ASTM D5185m	5	0	0	0	
Molybdenum	ppm	ASTM D5185m	50	45	51	48	
Manganese	ppm	ASTM D5185m	0	<1	1	<1	
Magnesium	ppm	ASTM D5185m	560	577	536	537	
Calcium	ppm	ASTM D5185m	1510	1503	1592	1511	
Phosphorus	ppm	ASTM D5185m	780	744	761	709	
Zinc	ppm	ASTM D5185m	870	934	933	918	
Sulfur	ppm	ASTM D5185m	2040	2437	2393	2787	
CONTAMINAN	TS	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>+100	7	16	6	
Sodium	ppm	ASTM D5185m		2	8	6	
Potassium	ppm	ASTM D5185m	>20	0	4	<1	
INFRA-RED		method	limit/base	current	history1	history2	
Soot %	%	*ASTM D7844		0	0	0.1	
Nitration	Abs/cm	*ASTM D7624	>20	6.4	8.9	9.9	
Sulfation	Abs/.1mm	*ASTM D7415	>30	19.1	19.3	19.1	
FLUID DEGRA		method	limit/base	current	history1	history2	
Oxidation	Abs/.1mm	*ASTM D7414	>25	16.0	17.0	16.7	
Base Number (BN)	mg KOH/g	ASTM D2896	10.2	8.7	6.2	7.2	




() 16 () 15 15 14 Bas

> 13 Abnorma 12 11 Feb13/23

Ĥ

OIL ANALYSIS REPORT

VISUAL



	VICONE							
		scalar	*Visual	NONE	NONE	NONE	NONE	
	Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE	
	Precipitate		*Visual	NONE	NONE	NONE	NONE	
	Silt		*Visual	NONE	NONE	NONE	NONE	
	Debris		*Visual	NONE	NONE	NONE	NONE	
	Sand/Dirt		*Visual	NONE	NONE	NONE	NONE	
/23			*Visual	NORML	NORML	NORML	NORML	
Sep 21/23	Appearance Odor		*Visual	NORML	NORML	NORML	NORML	
	Emulsified Water		*Visual	>0.1	NEG	NEG	NEG	
°C	Free Water		*Visual	20.1	NEG	NEG	NEG	
					neo.			
	FLUID PROP	ERHES	method	limit/base	current	history1	history2	
	Visc @ 100°C	cSt	ASTM D445	15.1	14.5	14.9	14.2	
	GRAPHS							
	Ferrous Alloys							
	35 20 iron	\wedge						
Sep 21/23	30 - nickel							
30	25							
	20- E							
	¹⁵							
	10-							
	5-	South and a subsection of the state of the s	and the second second					
	All			A ADDRESS OF THE OWNER.				
	Feb 13/23	Sep21/23		0ct3/23				
		07		õ				
	Non-ferrous Met	tals						
	30 copper	\wedge						
	25 - management lead	$/ \setminus$						
	20		\					
	<u>۾</u> 15-		\mathbf{A}					
	10							
	5-							
	0		-					
	Feb 13/23	Sep21/23		0ct3/23				
	Feb	Sep		0				
	Viscosity @ 100°	°C			Base Number			
	18			12.0				
	Abnormal			10.0	Base			
	17			B/H03				
	() 16 00 15 15			Bu				
	E 15 to 14			a 6.0] =			
	10			N 4.0	D			
	13 Abnormal	1		2.0				
	11							
	3/23	1/23		0ct3/23		1/23 -	0ct3/23 -	
	Feb 13/23	Sep21/23		Oct	Feb13/23	Sep21/23	Octi	
				NO 6			. ·	
Laboratory Sample No.	: WearCheck USA - : GFL0090112	 501 Madisc Received 		ry, NC 2751: Oct 2023	3 GFL Envi	ronmental - 030 - Co		
Lab Number		Diagnosed			3010 HWY 378 Conway, SC			
TESTING LABORATORY Unique Numb		Diagnostic		US 29527				
Certificate L2367 Test Package	ge : FLEET	-		s Davis		Contact: CHET	STROSCHINE	
To discuss this sample report	rt, contact Customer Ser					cstroschin	e@gflenv.com	
* - Denotes test methods that	t are outside of the ISO	17025 scop	e of accred	itation.			T:	

* - Denotes test m Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Submitted By: CHET STROSCHINE

F: