

# OIL ANALYSIS REPORT

Sample Rating Trend



**NORMAL**



Machine Id  
**CHEVROLET CHEVY CAMARO**

Component  
**Gasoline Engine**

Fluid  
**AMSOIL LS/G 5W30 (--- GAL)**

## DIAGNOSIS

### Recommendation

Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is no indication of any contamination in the oil.

### Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>PCA0073693</b>	---	---
Sample Date	Client Info		<b>01 Jul 2023</b>	---	---
Machine Age	mls	Client Info	<b>42000</b>	---	---
Oil Age	mls	Client Info	<b>1500</b>	---	---
Oil Changed	Client Info		<b>Changed</b>	---	---
Sample Status			<b>NORMAL</b>	---	---

## CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>4.0	<b>&lt;1.0</b>	---	---
Glycol	WC Method		<b>NEG</b>	---	---

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >150	<b>38</b>	---	---
Chromium	ppm	ASTM D5185m >20	<b>2</b>	---	---
Nickel	ppm	ASTM D5185m >5	<b>&lt;1</b>	---	---
Titanium	ppm	ASTM D5185m	<b>10</b>	---	---
Silver	ppm	ASTM D5185m >2	<b>0</b>	---	---
Aluminum	ppm	ASTM D5185m >40	<b>6</b>	---	---
Lead	ppm	ASTM D5185m >50	<b>3</b>	---	---
Copper	ppm	ASTM D5185m >155	<b>41</b>	---	---
Tin	ppm	ASTM D5185m >10	<b>3</b>	---	---
Vanadium	ppm	ASTM D5185m	<b>&lt;1</b>	---	---
Cadmium	ppm	ASTM D5185m	<b>0</b>	---	---

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>265</b>	---	---
Barium	ppm	ASTM D5185m	<b>0</b>	---	---
Molybdenum	ppm	ASTM D5185m	<b>209</b>	---	---
Manganese	ppm	ASTM D5185m	<b>437</b>	---	---
Magnesium	ppm	ASTM D5185m	<b>950</b>	---	---
Calcium	ppm	ASTM D5185m	<b>1267</b>	---	---
Phosphorus	ppm	ASTM D5185m	<b>732</b>	---	---
Zinc	ppm	ASTM D5185m	<b>846</b>	---	---
Sulfur	ppm	ASTM D5185m	<b>3156</b>	---	---

## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >30	<b>19</b>	---	---
Sodium	ppm	ASTM D5185m >400	<b>1</b>	---	---
Potassium	ppm	ASTM D5185m >20	<b>0</b>	---	---



## INFRA-RED

	method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844	<b>0.1</b>	---	---
Nitration	Abs/cm	*ASTM D7624 >20	<b>10.9</b>	---	---
Sulfation	Abs/.1mm	*ASTM D7415 >30	<b>50.7</b>	---	---

## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414 >25	<b>59.7</b>	---	---
Acid Number (AN)	mg KOH/g	ASTM D8045	<b>1.26</b>	---	---









# OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	NONE	---
Debris	scalar	*Visual	NONE	NONE	---
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual	>0.2	NEG	---
Free Water	scalar	*Visual		NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	<b>9.8</b>	---	---

## GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : PCA0073693 **Received** : 12 Oct 2023  
**Lab Number** : **05977263** **Diagnosed** : 15 Oct 2023  
**Unique Number** : 10689213 **Diagnostician** : Don Baldrige  
**Test Package** : MOB 2

**PETRO-CANADA LUBRICANTS - GARRETT BAPP**  
 2416 N 12TH ST  
 BROKEN ARROW, OK  
 US 74012  
 Contact: GARRETT BAPP

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:  
F: