


# PROBLEM SUMMARY


Area  
**[98557573]**  
 Machine Id  
**KR-GR-000017 - MARLEN (S/N STUFF D - 11513137)**  
 Component  
**Hydraulic System**  
 Fluid  
**R&O OIL ISO 100 (40 GAL)**

Sample Rating Trend



## COMPONENT CONDITION SUMMARY

▲ Particle Trend



## RECOMMENDATION

We recommend you service the filters on this component. Resample at the next service interval to monitor.

## PROBLEMATIC TEST RESULTS

| Sample Status   |              |           | ABNORMAL   | NORMAL | ABNORMAL |
|-----------------|--------------|-----------|------------|--------|----------|
| Particles >4µm  | ASTM D7647   | >10000    | ▲ 45106    | ---    | ---      |
| Particles >6µm  | ASTM D7647   | >2500     | ▲ 16078    | ---    | ---      |
| Particles >14µm | ASTM D7647   | >640      | ▲ 1630     | ---    | ---      |
| Particles >21µm | ASTM D7647   | >160      | ▲ 453      | ---    | ---      |
| Oil Cleanliness | ISO 4406 (c) | >20/18/16 | ▲ 23/21/18 | ---    | ---      |

Customer Id: KRAKIR  
 Sample No.: PCA0108228  
 Lab Number: 05986431  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Jonathan Hester +1 919-379-4092 x4092  
[jhester@wearcheckusa.com](mailto:jhester@wearcheckusa.com)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

| Action        | Status | Date | Done By | Description                                             |
|---------------|--------|------|---------|---------------------------------------------------------|
| Change Filter | ---    | ---  | ?       | We recommend you service the filters on this component. |

## HISTORICAL DIAGNOSIS

20 Jul 2023 Diag: Jonathan Hester

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



18 Apr 2023 Diag: Angela Borella

VIS DEBRIS



We suspect abnormal contamination may be due to sampling method. Resample at the next service interval to monitor. All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The condition of the oil is acceptable for the time in service.

view report



18 Jan 2023 Diag: Don Baldrige

VISCOSITY




Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. Viscosity of sample indicates oil is within ISO 100 range, advise investigate. Confirm oil type.

view report



# OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area  
**[98557573]**  
 Machine Id  
**KR-GR-000017 - MARLEN (S/N STUFF D - 11513137)**  
 Component  
**Hydraulic System**  
 Fluid  
**R&O OIL ISO 100 (40 GAL)**

## DIAGNOSIS

### Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is a high amount of particulates present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

| method        | limit/base  | current            | history1    | history2    |
|---------------|-------------|--------------------|-------------|-------------|
| Sample Number | Client Info | <b>PCA0108228</b>  | PCA0102539  | PCA0093101  |
| Sample Date   | Client Info | <b>15 Oct 2023</b> | 20 Jul 2023 | 18 Apr 2023 |
| Machine Age   | hrs         | Client Info        | 0           | 0           |
| Oil Age       | hrs         | Client Info        | 0           | 0           |
| Oil Changed   | Client Info | <b>N/A</b>         | N/A         | N/A         |
| Sample Status |             | <b>ABNORMAL</b>    | NORMAL      | ABNORMAL    |

## WEAR METALS

| method   | limit/base | current         | history1     | history2 |   |
|----------|------------|-----------------|--------------|----------|---|
| Iron     | ppm        | ASTM D5185m >20 | <b>9</b>     | <1       | 2 |
| Chromium | ppm        | ASTM D5185m >20 | <b>0</b>     | 1        | 0 |
| Nickel   | ppm        | ASTM D5185m >20 | <b>1</b>     | 1        | 0 |
| Titanium | ppm        | ASTM D5185m     | <b>0</b>     | 1        | 0 |
| Silver   | ppm        | ASTM D5185m     | <b>0</b>     | 3        | 0 |
| Aluminum | ppm        | ASTM D5185m >20 | <b>3</b>     | 0        | 0 |
| Lead     | ppm        | ASTM D5185m >20 | <b>&lt;1</b> | 8        | 0 |
| Copper   | ppm        | ASTM D5185m >20 | <b>3</b>     | 2        | 3 |
| Tin      | ppm        | ASTM D5185m >20 | <b>&lt;1</b> | 2        | 0 |
| Vanadium | ppm        | ASTM D5185m     | <b>0</b>     | 2        | 0 |
| Cadmium  | ppm        | ASTM D5185m     | <b>0</b>     | <1       | 0 |

## ADDITIVES

| method     | limit/base | current          | history1     | history2 |     |
|------------|------------|------------------|--------------|----------|-----|
| Boron      | ppm        | ASTM D5185m 5    | <b>0</b>     | <1       | 0   |
| Barium     | ppm        | ASTM D5185m 5    | <b>0</b>     | 0        | 0   |
| Molybdenum | ppm        | ASTM D5185m 5    | <b>0</b>     | 1        | 1   |
| Manganese  | ppm        | ASTM D5185m      | <b>&lt;1</b> | <1       | 0   |
| Magnesium  | ppm        | ASTM D5185m 5    | <b>3</b>     | 19       | 0   |
| Calcium    | ppm        | ASTM D5185m 5    | <b>4</b>     | 0        | 0   |
| Phosphorus | ppm        | ASTM D5185m 100  | <b>550</b>   | 296      | 245 |
| Zinc       | ppm        | ASTM D5185m 25   | <b>0</b>     | 0        | 3   |
| Sulfur     | ppm        | ASTM D5185m 1500 | <b>1556</b>  | 1531     | 768 |

## CONTAMINANTS

| method    | limit/base | current         | history1 | history2 |    |
|-----------|------------|-----------------|----------|----------|----|
| Silicon   | ppm        | ASTM D5185m >15 | <b>2</b> | 3        | 1  |
| Sodium    | ppm        | ASTM D5185m     | <b>4</b> | 43       | 0  |
| Potassium | ppm        | ASTM D5185m >20 | <b>3</b> | 100      | <1 |

## FLUID CLEANLINESS


| method          | limit/base   | current   | history1          | history2 |     |
|-----------------|--------------|-----------|-------------------|----------|-----|
| Particles >4µm  | ASTM D7647   | >10000    | <b>▲ 45106</b>    | ---      | --- |
| Particles >6µm  | ASTM D7647   | >2500     | <b>▲ 16078</b>    | ---      | --- |
| Particles >14µm | ASTM D7647   | >640      | <b>▲ 1630</b>     | ---      | --- |
| Particles >21µm | ASTM D7647   | >160      | <b>▲ 453</b>      | ---      | --- |
| Particles >38µm | ASTM D7647   | >40       | <b>28</b>         | ---      | --- |
| Particles >71µm | ASTM D7647   | >10       | <b>3</b>          | ---      | --- |
| Oil Cleanliness | ISO 4406 (c) | >20/18/16 | <b>▲ 23/21/18</b> | ---      | --- |

## FLUID DEGRADATION


| method           | limit/base | current         | history1    | history2 |     |
|------------------|------------|-----------------|-------------|----------|-----|
| Acid Number (AN) | mg KOH/g   | ASTM D8045 0.08 | <b>0.07</b> | 0.17     | --- |

# OIL ANALYSIS REPORT


### ▲ Particle Trend




### ▲ Particle Trend



### Acid Number



### Viscosity @ 40°C




| VISUAL           | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|----------|----------|
| White Metal      | scalar | *Visual    | NONE    | NONE     | NONE     |
| Yellow Metal     | scalar | *Visual    | NONE    | NONE     | NONE     |
| Precipitate      | scalar | *Visual    | NONE    | NONE     | NONE     |
| Silt             | scalar | *Visual    | NONE    | LIGHT    | NONE     |
| Debris           | scalar | *Visual    | NONE    | NONE     | ▲ MODER  |
| Sand/Dirt        | scalar | *Visual    | NONE    | NONE     | NONE     |
| Appearance       | scalar | *Visual    | NORML   | NORML    | NORML    |
| Odor             | scalar | *Visual    | NORML   | NORML    | NORML    |
| Emulsified Water | scalar | *Visual    | >0.05   | NEG      | NEG      |
| Free Water       | scalar | *Visual    |         | NEG      | NEG      |


| FLUID PROPERTIES | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|----------|----------|
| Visc @ 40°C      | cSt    | ASTM D445  | 100     | 96.0     | 101      |

| SAMPLE IMAGES | method | limit/base | current | history1 | history2 |
|---------------|--------|------------|---------|----------|----------|
|---------------|--------|------------|---------|----------|----------|

Color




Bottom




### GRAPHS


#### Ferrous Alloys




#### Non-ferrous Metals




#### Viscosity @ 40°C



#### ▲ Particle Count



#### Acid Number



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : PCA0108228 **Received** : 23 Oct 2023  
**Lab Number** : 05986431 **Diagnosed** : 25 Oct 2023  
**Unique Number** : 10709093 **Diagnostician** : Jonathan Hester  
**Test Package** : IND 2

**KraftHeinz - Kirksville - Plant 8333 PCA**  
 2504 INDUSTRIAL DR  
 KIRKSVILLE, MO  
 US 63501  
 Contact: WALLACE WARD  
 wallace.ward@kraftheinzcompany.com  
 T: (660)627-1031  
 F: (660)627-5887

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)