


PROBLEM SUMMARY

Area
[98557984]
 Machine Id
KR-GR-000325-NORTH - 15000 LB MIXER (S/N MIX D - 11513074)
 Component
Gear Reducer
 Fluid
PETRO CANADA 220 (48 LTR)


Sample Rating Trend



WATER



COMPONENT CONDITION SUMMARY



RECOMMENDATION

We advise that you check for the source of water entry. We recommend an early resample to monitor this condition.

PROBLEMATIC TEST RESULTS

Sample Status				SEVERE	ABNORMAL	ATTENTION
Water	%	ASTM D6304	>0.1	1.17	0.713	---
ppm Water	ppm	ASTM D6304	>1000	11700	7130	---
Appearance	scalar	*Visual	NORML	MILKY	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	0.2%	0.2%	NEG

Customer Id: KRAKIR
 Sample No.: PCA0108232
 Lab Number: 05986436
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Jonathan Hester +1 919-379-4092 x4092
jhester@wearcheckusa.com

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Resample	---	---	?	We recommend an early resample to monitor this condition.
Check Water Access	---	---	?	We advise that you check for the source of water entry.

HISTORICAL DIAGNOSIS

16 Aug 2023 Diag: Jonathan Hester

WATER



We advise that you check for the source of water entry. We recommend an early resample to monitor this condition. All component wear rates are normal. There is a moderate concentration of water present in the oil. The condition of the oil is acceptable for the time in service.

[view report](#)



31 Jul 2023 Diag: Jonathan Hester

VISCOSITY



No corrective action is recommended at this time. Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. Viscosity of sample indicates oil is within ISO 68 range, advise investigate. Confirm oil type. The AN level is acceptable for this fluid.

[view report](#)



23 Apr 2023 Diag: Don Baldrige

WATER




We advise that you check for the source of water entry. We advise that you follow the water drain-off procedure for this component. We recommend an early resample to monitor this condition. All component wear rates are normal. There is a high concentration of water present in the oil. Free water present. The condition of the oil is acceptable for the time in service.

[view report](#)



Area
[98557984]
Machine Id
KR-GR-000325-NORTH - 15000 LB MIXER (S/N MIX D - 11513074)
Component
Gear Reducer
Fluid
PETRO CANADA 220 (48 LTR)



DIAGNOSIS

Recommendation

We advise that you check for the source of water entry. We recommend an early resample to monitor this condition.

Wear

All component wear rates are normal.

Contamination

Appearance is milky. There is a high concentration of water present in the oil.

Fluid Condition

The AN level is acceptable for this fluid.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	PCA0108232	PCA0101928	PCA0102535
Sample Date	Client Info	20 Oct 2023	16 Aug 2023	31 Jul 2023
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		SEVERE	ABNORMAL	ATTENTION

WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m >150	62	46	<1
Chromium	ppm	ASTM D5185m >10	<1	<1	1
Nickel	ppm	ASTM D5185m >10	2	0	1
Titanium	ppm	ASTM D5185m	0	0	1
Silver	ppm	ASTM D5185m	<1	0	3
Aluminum	ppm	ASTM D5185m >25	1	0	0
Lead	ppm	ASTM D5185m >100	1	0	8
Copper	ppm	ASTM D5185m >50	0	0	2
Tin	ppm	ASTM D5185m >10	2	<1	3
Vanadium	ppm	ASTM D5185m	<1	0	2
Cadmium	ppm	ASTM D5185m	0	0	<1

ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m	<1	0	<1
Barium	ppm	ASTM D5185m	0	0	0
Molybdenum	ppm	ASTM D5185m	8	0	<1
Manganese	ppm	ASTM D5185m	1	<1	<1
Magnesium	ppm	ASTM D5185m	5	2	▲ 19
Calcium	ppm	ASTM D5185m	13	6	0
Phosphorus	ppm	ASTM D5185m	426	431	226
Zinc	ppm	ASTM D5185m	2	0	0
Sulfur	ppm	ASTM D5185m	2011	1359	▲ 463




CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >50	4	3	3
Sodium	ppm	ASTM D5185m	4	2	45
Potassium	ppm	ASTM D5185m >20	5	1	107
Water	%	ASTM D6304 >0.1	● 1.17	▲ 0.713	---
ppm Water	ppm	ASTM D6304 >1000	● 11700	▲ 7130	---

FLUID DEGRADATION

method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045	0.30	---	0.20


OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	▲ MILKY	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	● 0.2%	0.2%
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	227	227	▲ 66.3

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : PCA0108232 **Received** : 23 Oct 2023
Lab Number : 05986436 **Diagnosed** : 25 Oct 2023
Unique Number : 10709098 **Diagnostician** : Jonathan Hester

KraftHeinz - Kirksville - Plant 8333 PCA
 2504 INDUSTRIAL DR
 KIRKSVILLE, MO
 US 63501
 Contact: WALLACE WARD
 wallace.ward@kraftheinzcompany.com
 T: (660)627-1031
 F: (660)627-5887

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)