


PROBLEM SUMMARY


Sample Rating Trend



Area
[98558972]
 Machine Id
KR-GR-001553-SOUTH - 15000 MIXER (S/N MIX C - 11513064)
 Component
Gearbox
 Fluid
PETRO CANADA 220 (50 QTS)

COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status			ABNORMAL	ABNORMAL	NORMAL
Particles >4µm	ASTM D7647	>10000	▲ 74595	---	---
Particles >6µm	ASTM D7647	>2500	▲ 25315	---	---
Particles >14µm	ASTM D7647	>640	▲ 2081	---	---
Particles >21µm	ASTM D7647	>160	▲ 534	---	---
Oil Cleanliness	ISO 4406 (c)	>20/18/16	▲ 23/22/18	---	---
Debris	scalar *Visual	NONE	▲ MODER	NONE	NONE

Customer Id: KRAKIR
 Sample No.: PCA0108240
 Lab Number: 05994322
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Don Baldrige +1
don.b505@comcast.net

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component if applicable.

HISTORICAL DIAGNOSIS

31 Jul 2023 Diag: Doug Bogart

WATER



We advise that you check for the source of water entry. Resample at the next service interval to monitor. All component wear rates are normal. There is a light concentration of water present in the oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

view report



22 Apr 2023 Diag: Angela Borella

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The condition of the oil is acceptable for the time in service.

view report



14 Oct 2022 Diag: Doug Bogart

WATER




We advise that you check for the source of water entry. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate concentration of water present in the oil. The oil viscosity is higher than normal. Confirm oil type.

view report



OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area
[98558972]
 Machine Id
KR-GR-001553-SOUTH - 15000 MIXER (S/N MIX C - 11513064)
 Component
Gearbox
 Fluid
PETRO CANADA 220 (50 QTS)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil. Moderate concentration of visible dirt/debris present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	PCA0108240	PCA0103226	PCA0093102
Sample Date	Client Info	22 Oct 2023	31 Jul 2023	22 Apr 2023
Machine Age	hrs	0	0	0
Oil Age	hrs	0	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		ABNORMAL	ABNORMAL	NORMAL

WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m >200	3	<1	8
Chromium	ppm	ASTM D5185m >15	<1	1	0
Nickel	ppm	ASTM D5185m >15	0	1	0
Titanium	ppm	ASTM D5185m	0	1	<1
Silver	ppm	ASTM D5185m	0	3	0
Aluminum	ppm	ASTM D5185m >25	<1	0	0
Lead	ppm	ASTM D5185m >100	0	8	0
Copper	ppm	ASTM D5185m >200	<1	2	0
Tin	ppm	ASTM D5185m >25	<1	2	0
Vanadium	ppm	ASTM D5185m	0	2	0
Cadmium	ppm	ASTM D5185m	0	<1	0

ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m	<1	2	<1
Barium	ppm	ASTM D5185m	19	0	0
Molybdenum	ppm	ASTM D5185m	2	1	7
Manganese	ppm	ASTM D5185m	<1	<1	<1
Magnesium	ppm	ASTM D5185m	0	20	<1
Calcium	ppm	ASTM D5185m	2	0	9
Phosphorus	ppm	ASTM D5185m	429	224	418
Zinc	ppm	ASTM D5185m	24	0	6
Sulfur	ppm	ASTM D5185m	1200	925	995

CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >50	2	3	2
Sodium	ppm	ASTM D5185m	1	43	<1
Potassium	ppm	ASTM D5185m >20	<1	100	2

FLUID CLEANLINESS


method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >10000	▲ 74595	---	---
Particles >6µm	ASTM D7647 >2500	▲ 25315	---	---
Particles >14µm	ASTM D7647 >640	▲ 2081	---	---
Particles >21µm	ASTM D7647 >160	▲ 534	---	---
Particles >38µm	ASTM D7647 >40	23	---	---
Particles >71µm	ASTM D7647 >10	4	---	---
Oil Cleanliness	ISO 4406 (c) >20/18/16	▲ 23/22/18	---	---

FLUID DEGRADATION


method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045	0.44	0.51	---

OIL ANALYSIS REPORT


▲ Particle Trend




▲ Particle Trend



Acid Number




Viscosity @ 40°C








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	LIGHT
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	LIGHT
Debris	scalar	*Visual	NONE	▲ MODER	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	▲ HAZY	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	0.2%
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	225	223	219

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : PCA0108240 **Received** : 31 Oct 2023
Lab Number : 05994322 **Diagnosed** : 02 Nov 2023
Unique Number : 10722682 **Diagnostician** : Don Baldrige
Test Package : IND 2 (Additional Tests: PrtCount)

KraftHeinz - Kirksville - Plant 8333 PCA
 2504 INDUSTRIAL DR
 KIRKSVILLE, MO
 US 63501
 Contact: WALLACE WARD
 wallace.ward@kraftheinzcompany.com
 T: (660)627-1031
 F: (660)627-5887

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)