

OIL ANALYSIS REPORT





Machine Id 10695

Component

Diesel Engine

PETRO CANADA DURON SHP 15W40 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.


Fluid Condition


The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

SAMPLE INFORI	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		GFL0089581	GFL0089636	GFL0089590
Sample Date		Client Info		27 Oct 2023	10 Oct 2023	24 Aug 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		Not Changd	Not Changd	Not Changd
Sample Status				NORMAL	NORMAL	NORMAL
CONTAMINAT	ION	method	limit/base	current	history1	history2
Fuel		WC Method	>5	<1.0	<1.0	<1.0
Glycol		WC Method		NEG	NEG	NEG
WEAR METAL	S	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>100	12	8	22
Chromium	ppm	ASTM D5185m	>20	1	<1	1
Nickel	ppm	ASTM D5185m	>4	<1	<1	0
Titanium	ppm	ASTM D5185m		<1	<1	<1
Silver	ppm	ASTM D5185m	>3	0	<1	0
Aluminum	ppm	ASTM D5185m		4	2	6
Lead	ppm	ASTM D5185m	>40	- <1	0	0
Copper	ppm	ASTM D5185m	>330	2	3	9
Tin	ppm	ASTM D5185m	>15	= <1	<1	0
Vanadium	ppm	ASTM D5185m	210	0	<1	0
Cadmium	ppm	ASTM D5185m		0	0	0
Caumum	ppin	AUTIV DUTUUIII		0	0	0
			11 1. 4			
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	10	8	54
Boron Barium	ppm	ASTM D5185m ASTM D5185m	0	10 0	8	54 4
Boron Barium Molybdenum	ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m	0 0 60	10 0 54	8 0 65	54 4 43
Boron Barium Molybdenum Manganese	ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	0 0 60 0	10 0 54 <1	8 0 65 <1	54 4 43 3
Boron Barium Molybdenum Manganese Magnesium	ppm ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	0 0 60 0 1010	10 0 54 <1 801	8 0 65 <1 876	54 4 43 3 519
Boron Barium Molybdenum Manganese Magnesium Calcium	ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	0 0 60 0 1010 1070	10 0 54 <1 801 976	8 0 65 <1 876 1019	54 4 43 3 519 1708
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus	ppm ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	0 0 60 0 1010 1070 1150	10 0 54 <1 801 976 942	8 0 65 <1 876 1019 938	54 4 43 3 519 1708 751
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc	ppm ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	0 0 60 0 1010 1070 1150 1270	10 0 54 <1 801 976 942 1071	8 0 65 <1 876 1019 938 1167	54 4 43 3 519 1708 751 916
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur	ppm ppm ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	0 0 60 0 1010 1070 1150	10 0 54 <1 801 976 942	8 0 65 <1 876 1019 938	54 4 43 3 519 1708 751
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc	ppm ppm ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	0 0 60 0 1010 1070 1150 1270	10 0 54 <1 801 976 942 1071	8 0 65 <1 876 1019 938 1167	54 4 43 3 519 1708 751 916
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur	ppm ppm ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m method	0 0 60 1010 1070 1150 1270 2060	10 0 54 <1 801 976 942 1071 2580	8 0 65 <1 876 1019 938 1167 2797 history1 9	54 4 43 3 519 1708 751 916 3012
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINAN	ppm ppm ppm ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	0 0 60 1010 1070 1150 1270 2060	10 0 54 <1 801 976 942 1071 2580 current	8 0 65 <1 876 1019 938 1167 2797 history1	54 4 43 3 519 1708 751 916 3012 history2
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINAN Silicon	ppm ppm ppm ppm ppm ppm ppm ppm TS	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m method	0 0 60 1010 1070 1150 1270 2060 <i>limit/base</i>	10 0 54 <1 801 976 942 1071 2580 current 9	8 0 65 <1 876 1019 938 1167 2797 history1 9	54 4 43 519 1708 751 916 3012 history2 17
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINAN Silicon Sodium	ppm ppm ppm ppm ppm ppm ppm ppm TS	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m method ASTM D5185m ASTM D5185m	0 0 60 1010 1070 1150 1270 2060 <i>limit/base</i>	10 0 54 <1 801 976 942 1071 2580 current 9 5	8 0 65 <1 876 1019 938 1167 2797 history1 9 2	54 4 43 519 1708 751 916 3012 history2 17 15
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINAN Silicon Sodium Potassium	ppm ppm ppm ppm ppm ppm ppm ppm TS	ASTM D5185m ASTM D5185m	0 0 0 1010 1070 1150 1270 2060 limit/base >25	10 0 54 <1 801 976 942 1071 2580 current 9 5 2	8 0 65 <1 876 1019 938 1167 2797 history1 9 2 6	54 4 43 3 519 1708 751 916 3012 history2 17 15 <1
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINAN Silicon Sodium Potassium INFRA-RED	ppm ppm ppm ppm ppm ppm ppm ppm TS	ASTM D5185m ASTM D5185m	0 0 0 1010 1070 1150 1270 2060 2060 225 >25 >20 20 20	10 0 54 <1 801 976 942 1071 2580 current 9 5 2 2	8 0 65 <1 876 1019 938 1167 2797 history1 9 2 6 history1	54 4 43 519 1708 751 916 3012 history2 17 15 <1 history2
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINAN Silicon Sodium Potassium INFRA-RED Soot %	ppm ppm ppm ppm ppm ppm ppm ppm TS ppm ppm ppm	ASTM D5185m ASTM D5185m	0 0 0 1010 1070 1150 1270 2060 Imit/base >25 >20 Imit/base >20	10 0 54 <1 801 976 942 1071 2580 <u>current</u> 9 5 2 2 <u>current</u> 0.1	8 0 65 <1 876 1019 938 1167 2797 history1 9 2 6 history1 0.1	54 4 43 519 1708 751 916 3012 history2 17 15 <1 15 <1 history2 0.1
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINAN Silicon Sodium Potassium INFRA-RED Soot % Nitration	ppm ppm ppm ppm ppm ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m	0 0 0 1010 1070 1150 1270 2060 Imit/base >25 >20 Imit/base >20	10 0 54 <1 801 976 942 1071 2580 current 9 5 2 2 current 0.1 5.3	8 0 65 <1 876 1019 938 1167 2797 history1 9 2 6 history1 0.1 5.9	54 4 43 3 519 1708 751 916 3012 history2 17 15 <1 15 <1 history2 0.1 6.1
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINAN Silicon Sodium Potassium INFRA-RED Soot % Nitration Sulfation FLUID DEGRAD	ppm ppm ppm ppm ppm ppm ppm ppm TS ppm ppm ppm ppm ppm ppm ppm	ASTM D5185m ASTM D7844 *ASTM D7624	0 0 0 1010 1070 1150 2260 2060 225 220 220 imit/base >3 >20 >30 >30	10 0 54 <1 801 976 942 1071 2580 current 9 5 2 2 current 0.1 5.3 17.4 current	8 0 65 <1 876 1019 938 1167 2797 history1 9 2 6 6 history1 0.1 5.9 17.6 history1	54 4 43 3 519 1708 751 916 3012 history2 17 15 <1 15 <1 history2 0.1 6.1 21.7 history2
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINAN Silicon Sodium Potassium INFRA-RED Soot % Nitration Sulfation	ppm ppm ppm ppm ppm ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m	0 0 0 1010 1070 1150 1270 2060 /////////////////////////////////	10 0 54 <1 801 976 942 1071 2580 <u>current</u> 9 5 2 2 <u>current</u> 0.1 5.3 17.4	8 0 65 <1 876 1019 938 1167 2797 history1 9 2 6 6 history1 0.1 5.9 17.6	54 4 43 3 519 1708 751 916 3012 history2 17 15 <1 15 <1 history2 0.1 6.1 21.7





OIL ANALYSIS REPORT





VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPE	RTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	15.4	13.4	12.7	12.5
GRAPHS						





* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Certificate L2367

Submitted By: WILLIAM BROWN