


# **OIL ANALYSIS REPORT**



**NORMAL** 



# Machine Id **834000**

Component

**Natural Gas Engine** 

PETRO CANADA DURON SHP 15W40 (---

### DIAGNOSIS

### Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

### Contamination

Elevated aluminum (Al) and/or lead (Pb) and potassium (K) levels in your metals analysis are likely a result of solder flux release into the lubricant and is common on new equipment/components. There is no indication of any contamination in the


### **Fluid Condition**

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

GAL)			Jun2023	Nov2023		
SAMPLE INFORI	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		GFL0084641	GFL0084755	
Sample Date		Client Info		01 Nov 2023	19 Jun 2023	
Machine Age	hrs	Client Info		1216	35	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		Changed	Not Changd	
Sample Status				NORMAL	NORMAL	
WEAR METAL	S	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	15	44	
Chromium	ppm	ASTM D5185m	>4	1	<1	
Nickel	ppm	ASTM D5185m	>2	<1	<1	
Titanium	ppm	ASTM D5185m		0	0	
Silver	ppm	ASTM D5185m	>3	0	0	
Aluminum	ppm	ASTM D5185m	>9	14	30	
Lead	ppm	ASTM D5185m	>30	0	<1	
Copper	ppm	ASTM D5185m	>35	2	14	
Tin	ppm	ASTM D5185m	>4	<1	0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	9	38	
Barium	ppm	ASTM D5185m	0	0	2	
Molybdenum	ppm	ASTM D5185m	60	56	47	
Manganese	ppm	ASTM D5185m	0	2	15	
Magnesium	ppm	ASTM D5185m	1010	692	786	
Calcium	ppm	ASTM D5185m	1070	1618	1101	
Phosphorus	ppm	ASTM D5185m	1150	765	755	
Zinc	ppm	ASTM D5185m	1270	1109	897	
Sulfur	ppm	ASTM D5185m	2060	2784	2912	
CONTAMINAN	TS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>+100	8	37	
Sodium	ppm	ASTM D5185m		6	8	
Potassium	ppm	ASTM D5185m	>20	56	90	
INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844		0	0.1	
Nitration	Abs/cm	*ASTM D7624	>20	11.0	7.3	
Sulfation	Abs/.1mm	*ASTM D7415	>30	21.8	20.6	
FLUID DEGRA	OATION	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414	>25	18.4	17.5	
Base Number (BN)	mg KOH/g	ASTM D2896	9.8	4.6	9.2	



## **OIL ANALYSIS REPORT**







Certificate L2367

Laboratory Sample No. Lab Number Unique Number Test Package : FLEET

: GFL0084641 : 05999638 : 10727998

To discuss this sample report, contact Customer Service at 1-800-237-1369.

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received Diagnosed

: 06 Nov 2023 : 07 Nov 2023 : Wes Davis Diagnostician

GFL Environmental - 856 - Houston South 8515 Highway 6 South Houston, TX

US 77083 Contact: Apolinar Zacarias

pzacariascano@gflenv.com T:

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: