

PROBLEM SUMMARY

Sample Rating Trend





Area [98589053]

KR-GR-001554-SOUTH - 15000 MIXER (S/N MIX E - 11513084)


Gearbox

PETRO CANADA 220 (--- QTS)





COMPONENT CONDITION SUMMARY



RECOMMENDATION

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

| PROBLEMATIC TEST RESULTS | | | | | | | | | |
|--------------------------|--------------|-----------|-----------------|----------|----------|--|--|--|--|
| Sample Status | | | ABNORMAL | ABNORMAL | MARGINAL | | | | |
| Particles >4µm | ASTM D7647 | >10000 | <u> </u> | | | | | | |
| Particles >6μm | ASTM D7647 | >2500 | 10172 | | | | | | |
| Oil Cleanliness | ISO 4406 (c) | >20/18/16 | 23/21/16 | | | | | | |

Customer Id: KRAKIR Sample No.: PCA0051937 Lab Number: 06000483 Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

| Action | Status | Date | Done By | Description |
|---------------|--------|------|---------|---|
| Change Filter | | | ? | We recommend you service the filters on this component if applicable. |

HISTORICAL DIAGNOSIS

03 May 2023 Diag: Don Baldridge

WATER



We advise that you check for the source of water entry. We advise that you follow the water drain-off procedure for this component. We recommend an early resample to monitor this condition. All component wear rates are normal. There is a light concentration of water present in the oil. Free water present. The condition of the oil is acceptable for the time in service.



08 Feb 2023 Diag: Doug Bogart

WATER



We advise that you check for the source of water entry. Resample at the next service interval to monitor. All component wear rates are normal. There is a light concentration of water present in the oil. The condition of the oil is acceptable for the time in service.

view report

10 Nov 2022 Diag: Don Baldridge

WATER



We advise that you check for the source of water entry. We recommend that you drain the oil from the component if this has not already been done. We recommend an early resample to monitor this condition. All component wear rates are normal. There is a high concentration of water present in the oil. Free water present. The oil is no longer serviceable due to the presence of contaminants.






OIL ANALYSIS REPORT

Area [98589053]

KR-GR-001554-SOUTH - 15000 MIXER (S/N MIX E - 11513084)

Gearbox

PETRO CANADA 220 (--- QTS)





DIAGNOSIS

Recommendation

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

| | | Feb2020 | Nov2020 Nov2021 | May2022 Nov2022 Ma | ay2023 | |
|-----------------|--------|--------------|-----------------|--------------------|-------------|-------------|
| SAMPLE INFORM | MATION | method | limit/base | current | history1 | history2 |
| Sample Number | | Client Info | | PCA0051937 | PCA0097170 | PCA0091094 |
| Sample Date | | Client Info | | 05 Nov 2023 | 03 May 2023 | 08 Feb 2023 |
| Machine Age | hrs | Client Info | | 0 | 0 | 0 |
| Oil Age | hrs | Client Info | | 0 | 0 | 0 |
| Oil Changed | | Client Info | | N/A | N/A | N/A |
| Sample Status | | | | ABNORMAL | ABNORMAL | MARGINAL |
| WEAR METALS | S | method | limit/base | current | history1 | history2 |
| Iron | ppm | ASTM D5185m | >200 | 30 | 138 | 114 |
| Chromium | ppm | ASTM D5185m | >15 | <1 | <1 | <1 |
| Nickel | ppm | ASTM D5185m | >15 | <1 | 0 | 0 |
| Titanium | ppm | ASTM D5185m | | <1 | 0 | 0 |
| Silver | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Aluminum | ppm | ASTM D5185m | >25 | <1 | 0 | <1 |
| Lead | ppm | ASTM D5185m | >100 | <1 | 0 | 0 |
| Copper | ppm | ASTM D5185m | >200 | <1 | <1 | <1 |
| Tin | ppm | ASTM D5185m | >25 | 0 | 0 | 0 |
| Vanadium | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Cadmium | ppm | ASTM D5185m | | 0 | 0 | 0 |
| ADDITIVES | | method | limit/base | current | history1 | history2 |
| Boron | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Barium | ppm | ASTM D5185m | | 0 | 0 | 2 |
| Molybdenum | ppm | ASTM D5185m | | 0 | <1 | <1 |
| Manganese | ppm | ASTM D5185m | | <1 | 2 | 1 |
| Magnesium | ppm | ASTM D5185m | | 0 | <1 | 1 |
| Calcium | ppm | ASTM D5185m | | 3 | 8 | 7 |
| Phosphorus | ppm | ASTM D5185m | | 405 | 281 | 260 |
| Zinc | ppm | ASTM D5185m | | 0 | 82 | 71 |
| Sulfur | ppm | ASTM D5185m | | 2198 | 9381 | 8640 |
| CONTAMINAN | TS | method | limit/base | current | history1 | history2 |
| Silicon | ppm | ASTM D5185m | >50 | 3 | 2 | 2 |
| Sodium | ppm | ASTM D5185m | | 3 | 6 | 4 |
| Potassium | ppm | ASTM D5185m | >20 | 3 | 11 | 9 |
| FLUID CLEANL | INESS | method | limit/base | current | history1 | history2 |
| Particles >4µm | | ASTM D7647 | >10000 | △ 56613 | | |
| Particles >6µm | | ASTM D7647 | >2500 | <u> </u> | | |
| Particles >14µm | | ASTM D7647 | >640 | 378 | | |
| Particles >21µm | | ASTM D7647 | >160 | 82 | | |
| Particles >38µm | | ASTM D7647 | >40 | 1 | | |
| Particles >71µm | | ASTM D7647 | >10 | 0 | | |
| Oil Cleanliness | | ISO 4406 (c) | >20/18/16 | 23/21/16 | | |
| | | ` ' | | | | |

Acid Number (AN) mg KOH/g ASTM D8045

0.45



OIL ANALYSIS REPORT







Laboratory Sample No. Lab Number **Unique Number**

: 06000483 : 10728843

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : PCA0051937 Received

Diagnosed Diagnostician

: 07 Nov 2023 : 09 Nov 2023 : Don Baldridge

Test Package : IND 2 (Additional Tests: PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. KraftHeinz - Kirksville - Plant 8333 PCA

2504 INDUSTRIAL DR KIRKSVILLE, MO US 63501

Contact: WALLACE WARD wallace.ward@kraftheinzcompany.com

> T: (660)627-1031 F: (660)627-5887

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)