


OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Area
LONGHORN C
Machine Id
LONGHORN C (S/N 1645612)
Component
Natural Gas Engine
Fluid
PETRO CANADA SENTRON LD 3000 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

Fuel content negligible. There is no indication of any contamination in the oil.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	PCA0080859	PCA0080858	PCA0080857
Sample Date	Client Info	01 Nov 2023	13 Oct 2023	03 Oct 2023
Machine Age	hrs	6150	5701	5462
Oil Age	hrs	307	3760	3521
Oil Changed	Client Info	Changed	Not Changd	Not Changd
Sample Status		NORMAL	NORMAL	NORMAL

WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m >50	0	0	12
Chromium	ppm	ASTM D5185m >4	0	0	0
Nickel	ppm	ASTM D5185m >2	0	0	<1
Titanium	ppm	ASTM D5185m	0	0	0
Silver	ppm	ASTM D5185m >3	0	0	0
Aluminum	ppm	ASTM D5185m >9	<1	<1	0
Lead	ppm	ASTM D5185m >30	0	<1	2
Copper	ppm	ASTM D5185m >35	0	<1	2
Tin	ppm	ASTM D5185m >4	0	0	<1
Vanadium	ppm	ASTM D5185m	0	0	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m 5	5	0	2
Barium	ppm	ASTM D5185m 1	0	0	2
Molybdenum	ppm	ASTM D5185m 2	<1	<1	1
Manganese	ppm	ASTM D5185m 1	0	0	<1
Magnesium	ppm	ASTM D5185m 5	8	8	8
Calcium	ppm	ASTM D5185m 1220	1295	1377	1321
Phosphorus	ppm	ASTM D5185m 298	269	267	305
Zinc	ppm	ASTM D5185m 350	335	356	371
Sulfur	ppm	ASTM D5185m 1995	2946	2135	2646

CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >+100	1	2	4
Sodium	ppm	ASTM D5185m	2	6	<1
Potassium	ppm	ASTM D5185m >20	1	2	2
Fuel	%	ASTM D3524 >4.0	0.3	0.5	0.5





INFRA-RED

method	limit/base	current	history1	history2	
Soot %	%	*ASTM D7844	0	0	0
Nitration	Abs/cm	*ASTM D7624 >20	6.1	13.2	12.2
Sulfation	Abs/.1mm	*ASTM D7415 >30	14.3	21.7	20.5

FLUID DEGRADATION

method	limit/base	current	history1	history2	
Oxidation	Abs/.1mm	*ASTM D7414 >25	10.2	23.1	21.2
Acid Number (AN)	mg KOH/g	ASTM D8045 0.86	0.90	▲ 3.47	3.28
Base Number (BN)	mg KOH/g	ASTM D2896 3.85	3.07	▲ 1.62	3.91









OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	13.7	13.2	14.2

GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : PCA0080859 **Received** : 08 Nov 2023
Lab Number : 06002375 **Diagnosed** : 10 Nov 2023
Unique Number : 10736137 **Diagnostician** : Wes Davis
Test Package : MOB 2 (Additional Tests: FuelDilution, PercentFuel)

DIVERSIFIED ENERGY - CURWENSVILLE
 325 WALNUT ST FL2
 CURWENSVILLE, PA
 US 16833
 Contact: ZACH MCGARY
 zmcgary@dgoc.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: