

## **OIL ANALYSIS REPORT**

#### Sample Rating Trend

22 May2022 Jun2022 Aug2022 Dec2022 Aug2023 Jun2023 Aug2023 Oct20





Component

Natural Gas Engine

PETRO CANADA DURON GEO LD 15W40 (5 GAL)

### DIAGNOSIS

#### Recommendation

Resample at the next service interval to monitor.

#### Wear

Metal levels are typical for a new component breaking in.

#### Contamination

There is no indication of any contamination in the oil.

#### Fluid Condition


The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.


SAMPLE INFORI	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		GFL0098114	GFL0088517	GFL0088555
Sample Date		Client Info		10 Nov 2023	03 Oct 2023	03 Aug 2023
Machine Age	hrs	Client Info		645	645	645
Oil Age	hrs	Client Info		436	319	451
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL
WEAR METAL	S	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	9	7	8
Chromium	ppm	ASTM D5185m	>4	<1	<1	<1
Nickel	ppm	ASTM D5185m	>2	<1	0	0
Titanium	ppm	ASTM D5185m		<1	0	0
Silver	ppm	ASTM D5185m	>3	<1	0	0
Aluminum	ppm	ASTM D5185m	>9	2	<1	2
Lead	ppm	ASTM D5185m	>30	1	<1	0
Copper	ppm	ASTM D5185m	>35	1	2	0
Tin	ppm	ASTM D5185m	>4	<1	<1	<1
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	50	9	9	9
Barium	ppm	ASTM D5185m	5	0	0	0
Molybdenum	ppm	ASTM D5185m	50	56	54	52
Manganese	ppm	ASTM D5185m	0	<1	<1	<1
Magnesium	ppm	ASTM D5185m	560	577	601	600
Calcium	ppm	ASTM D5185m	1510	1633	1636	1708
Phosphorus	ppm	ASTM D5185m	780	724	739	727
Zinc	ppm	ASTM D5185m	870	988	996	1022
Sulfur	ppm	ASTM D5185m	2040	2540	2450	2885
CONTAMINAN	TS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>+100	5	4	4
Sodium	ppm	ASTM D5185m		2	6	7
Potassium	ppm	ASTM D5185m	>20	4	<1	2
INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844		0	0	0.1
Nitration	Abs/cm	*ASTM D7624	>20	10.7	9.8	10.5
Sulfation	Abs/.1mm	*ASTM D7415	>30	20.9	19.4	20.7
FLUID DEGRA	DATION	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414	>25	18.3	16.7	18.1
Base Number (BN)	mg KOH/g	ASTM D2896	10.2	5.3	5.8	5.5



# **OIL ANALYSIS REPORT**

VISUAL





	VISUAL	meth	od limit/base	current	nistory i	nistory2
	White Metal	scalar *Visua	NONE	NONE	NONE	NONE
	Yellow Metal	scalar *Visua		NONE	NONE	NONE
	Precipitate	scalar *Visua		NONE	NONE	NONE
	Silt	scalar *Visua		NONE	NONE	NONE
	Debris	scalar *Visua		NONE	NONE	NONE
	Sand/Dirt	scalar *Visua	NONE	NONE	NONE	NONE
Aug3/23 0ct3/23 Nov10/23	Appearance	scalar *Visua	NORML	NORML	NORML	NORML
Au Nov	Odor	scalar *Visua	NORML	NORML	NORML	NORML
	Emulsified Water	scalar *Visua	>0.1	NEG	NEG	NEG
	Free Water	scalar *Visua		NEG	NEG	NEG
				current	history1	history2
	Visc @ 100°C	cSt ASTM [	)445 15.1	15.1	15.1	15.1
	GRAPHS					
	Ferrous Alloys					
23	iron					
Aug <i>s/23</i> 0ct3/23	50 - chromium					
-	40-					
	Ē_30-					
	20	$\sim$				
	10					
		/22 /23 /23	/23			
	Apr8/22 May17/22 Jun13/22 Aug16/22	Dec13/22 Apr14/23 Jun20/23 Aug3/23	0ct3/23 Nov10/23			
		_	2			
	Non-ferrous Meta	IS				
	copper					
	15 -					
	<u>۾</u> 10-					
	d					
	5					
		-	In the second se			
100		23				
	Apr8/22 - May17/22 - Jun13/22 - Aug16/22 -	Dec13/22 Apr14/23 Jun20/23 Aug3/23	0ct3/23 Nov10/23			
	M L A		N			
	Viscosity @ 100°(	-		Base Number		
	18 Abnormal		12.0	Base		
	Abnormal			0 - Base		
			0.8 KOH(0) aquinaper (mb KOH(0) agus 4.0 888			
	Base 15 314 Base		ßm			
	5314		· 등 6.0		$\searrow$	
			N 4.0	0	$\setminus$ /	
	13 Abnormal		2.0	0	$\sim$	
	12-					
		22	0.0	12 12 10 0	22	33 53
	: Apr8/22 Jun13/22 Aug16/22	Dec13/22 Apr14/23 Jun20/23 Aug3/23	0ct3/23 Nov10/23	Apr8/22 - May17/22 - Jun13/22 -	Aug16/22 Dec13/22 Apr14/23	Junzu/23 Aug3/23 Oct3/23
	, Ju Au	Ju A	Nc	Ma Ju	Au Ar	
ooratory	: WearCheck USA -			3 GFL E	Environmental	
mple No.					148 S	tone Park Cou
o Number		•	: 15 Nov 2023			Durham, N
que Number	: 10739136	Diagnostician	Wes Davis		0	US 2770
st Package	: FLEET		1000			ct: Shane Park
nnie renort .	contact Customer Serv	/ICe at 1-800-237-	1369.		snane.par	ks@gflenv.cor

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Certificate L2367

Page 2 of 2

T: (919)596-1363

F: (919)598-1852