

# COOLANT REPORT

Sample Rating Trend

**NORMAL**



Machine Id  
**MACOM MACOM 6100**  
 Component  
**Coolant**  
 Fluid  
**CHEVRON INHIBITOR/WATER (--- QTS)**



## DIAGNOSIS

### Recommendation








This is a baseline read-out on the submitted sample.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			<b>PCA0066053</b>	---	---
Sample Date	Client Info			<b>04 Nov 2023</b>	---	---
Machine Age	hrs	Client Info		<b>4176</b>	---	---
Oil Age	hrs	Client Info		<b>0</b>	---	---
Oil Changed	Client Info			<b>N/A</b>	---	---
Sample Status				<b>NORMAL</b>	---	---

PHYSICAL TEST RESULTS		method	limit/base	current	history1	history2
Specific Gravity		*ASTM D1298		<b>1.000</b>	---	---
pH	Scale 0-14	ASTM D1287		<b>7.87</b>	---	---
Nitrites	ppm	AP-053:2009		<b>372</b>	---	---
Reserve Alkalinity	Scale 0-20	*ASTM D1121		<b>---</b>	---	---
Percentage Glycol	%	ASTM D3321		<b>1.7</b>	---	---
Freezing Point	°F	ASTM D3321		<b>---</b>	---	---
Total Dissolved Solids				<b>110.0</b>	---	---
Carboxylate				<b>n/a</b>	---	---

VISUAL		method	limit/base	current	history1	history2
Coolant Color		*Visual		<b>Yellow</b>	---	---
Coolant Appearance		*Visual	Clear	<b>normal</b>	---	---
Color					no image	no image
Bottom					no image	no image

# COOLANT REPORT



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : PCA0066053 **Received** : 16 Nov 2023  
**Lab Number** : 06010455 **Diagnosed** : 28 Nov 2023  
**Unique Number** : 10749599 **Diagnostician** : Doug Bogart  
**Test Package** : COOL- ( Additional Tests: COOL )

**AB Energy USA LLC - Pine Brook**  
 26 CHAPIN ROAD UNIT 1108  
 PINE BROOK, NJ  
 US 07058  
 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:  
F: