


PROBLEM SUMMARY

Area PROCESS CHEESE [98605329] Machine Id 4615-CMX

Component Pump Fluid R&O OIL ISO 68 (--- GAL)

COMPONENT CONDITION SUMMARY



Sample Rating Trend ISO

RECOMMENDATION

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS							
Sample Status		ABNORMAL	ABNORMAL	ABNORMAL			
Particles >4µm	ASTM D7647 >5	5000 A 72324	▲ 69591				
Particles >6µm	ASTM D7647 >1	1300 🔺 13480	1 4782				
Particles >14µm	ASTM D7647 >3	320 A 548	▲ 872				
Particles >21µm	ASTM D7647 >8	30 🔺 127	A 249				
Oil Cleanliness	ISO 4406 (c) >1	19/17/15 🔺 23/21/16	▲ 23/21/17				

Customer Id: KRASPRMO Sample No.: PCA0096856 Lab Number: 06013980 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Don Baldridge +1 <u>don.b505@comcast.net</u>

To change component or sample information: Customer Service +1 1-800-237-1369 <u>customerservice@wearcheck.com</u>

RECOMMENDED ACTIONS							
Action	Status	Date	Done By	Description			
Change Fluid			?	Oil and filter change at the time of sampling has been noted.			
Change Filter			?	Oil and filter change at the time of sampling has been noted.			

HISTORICAL DIAGNOSIS



15 Aug 2023 Diag: Angela Borella

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



12 Jun 2023 Diag: Don Baldridge

VISUAL METAL



The oil change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to metal particles present in this sample.Moderate concentration of visible metal present. All component wear rates are normal. No other contaminants were detected in the oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

18 May 2023 Diag: Don Baldridge





The oil change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to metal particles present in this sample.Moderate concentration of visible metal present. All component wear rates are normal. No other contaminants were detected in the oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.



view report

view report





OIL ANALYSIS REPORT

Area **PROCESS CHEESE [98605329]** Machine Id **4615-CMX** Component

Pump Fluid R&O OIL ISO 68 (--- GAL)

DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear


All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.




SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PCA0096856	PCA0096857	PCA0096805
Sample Date		Client Info		11 Nov 2023	15 Aug 2023	12 Jun 2023
Machine Age	mths	Client Info		0	0	0
Oil Age	mths	Client Info		1	1	1
Oil Changed		Client Info		Changed	Changed	Changed
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
CONTAMINAT		method	limit/base	current	history1	history2
Water		WC Method		NEG	NEG	NEG
WEAR METAL	S	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>90	16	17	8
Chromium	ppm	ASTM D5185m		<1	0	0
Nickel	ppm	ASTM D5185m	>5	<1	0	0
Titanium	ppm	ASTM D5185m		<1	<1	0
Silver	ppm	ASTM D5185m	>3	0	0	0
Aluminum	ppm	ASTM D5185m		2	0	0
Lead		ASTM D5185m	>12	0	0	<1
	ppm	ASTM D5185m		0 <1	0	0
Copper Tin	ppm		>30	<1	0	0
	ppm	ASTM D5185m	>3	< 1		
Vanadium	ppm	ASTM D5185m		-	<1	0
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	5	0	0	0
Barium	ppm	ASTM D5185m	5	4	0	2
Molybdenum	ppm	ASTM D5185m	5	<1	0	0
Manganese	ppm	ASTM D5185m		<1	0	0
Magnesium	ppm	ASTM D5185m	5	<1	<1	<1
Calcium	ppm	ASTM D5185m	5	0	0	2
Phosphorus	ppm	ASTM D5185m	100	80	60	71
Zinc	ppm	ASTM D5185m	25	31	30	18
Sulfur	ppm	ASTM D5185m	1500	0	2	0
CONTAMINAN	TS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>60	4	3	2
Sodium	ppm	ASTM D5185m		<1	<1	0
Potassium	ppm	ASTM D5185m	>20	<1	0	1
FLUID CLEANL	INESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>5000	<u> </u>	▲ 69591	
Particles >6µm		ASTM D7647	>1300	<u> </u>	1 4782	
Particles >14µm		ASTM D7647	>320	<u> </u>	A 872	
Particles >21µm		ASTM D7647	>80	🔺 127	<u> </u>	
Particles >38µm		ASTM D7647	>20	5	19	
Particles >71µm		ASTM D7647	>4	0	2	
Oil Cleanliness		ISO 4406 (c)	>19/17/15	23/21/16	▲ 23/21/17	
FLUID DEGRAD	DATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.08	0.11	0.12	0.23
· · · · · · · · · · · · · · · · · · ·	с J		_			


Report Id: KRASPRMO [WUSCAR] 06013980 (Generated: 11/23/2023 14:09:32) Rev: 1


Contact/Location: Service Manager - KRASPRMO



OIL ANALYSIS REPORT







Apr26/22

Jan 12/22

en 8/71

() 0€

र् र उ


80 Abnorma Base Abnorma

60

Sep 19/20 an27/21 Mav20/21

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	LIGHT	🔺 MODER
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>.1	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPE	RTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	68	71.4	71.5	71.9
SAMPLE IMAG	iES	method	limit/base	current	history1	history2
Color				e national a		

Bottom



* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Certificate L2367

Contact/Location: Service Manager - KRASPRMO