


PROBLEM SUMMARY


Area
PROCESS CHEESE [98605329]
 Machine Id
4625-CMX
 Component
Pump
 Fluid
R&O OIL ISO 68 (--- GAL)

Sample Rating Trend



COMPONENT CONDITION SUMMARY

Ferrous Alloys



RECOMMENDATION

Oil and filter change at the time of sampling has been noted. We advise that you inspect for the source(s) of wear. We recommend an early resample to monitor this condition. We were unable to perform a particle count due to a high concentration of particles present in this sample.

PROBLEMATIC TEST RESULTS

Sample Status				SEVERE	ABNORMAL	ABNORMAL
Iron	ppm	ASTM D5185m	>90	413	56	57
Debris	scalar	*Visual	NONE	HEAVY	HEAVY	HEAVY
Appearance	scalar	*Visual	NORML	HAZY	NORML	NORML

Customer Id: KRASPRMO
 Sample No.: PCA0096855
 Lab Number: 06013981
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Don Baldrige +1
don.b505@comcast.net

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Inspect Wear Source	---	---	?	We advise that you inspect for the source(s) of wear.
Change Fluid	---	---	?	Oil and filter change at the time of sampling has been noted.
Change Filter	---	---	?	Oil and filter change at the time of sampling has been noted.
Resample	---	---	?	We recommend an early resample to monitor this condition.
Alert	---	---	?	We were unable to perform a particle count due to a high concentration of particles present in this sample.

HISTORICAL DIAGNOSIS

15 Aug 2023 Diag: Angela Borella

SEDIMENT



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of visible silt present in the sample. High concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

view report



12 Jun 2023 Diag: Don Baldrige

WATER



The oil change at the time of sampling has been noted. We recommend you service the filters on this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. There is a light concentration of water present in the oil. High concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

view report



18 May 2023 Diag: Jonathan Hester

WEAR




The oil change at the time of sampling has been noted. We recommend you service the filters on this component if applicable. We recommend an early resample to monitor this condition. The iron level is abnormal. There is a high amount of particulates present in the oil. Appearance is hazy. The AN level is acceptable for this fluid.

view report



OIL ANALYSIS REPORT

Sample Rating Trend



Area
PROCESS CHEESE [98605329]
 Machine Id
4625-CMX
 Component
Pump
 Fluid
R&O OIL ISO 68 (--- GAL)

DIAGNOSIS

Recommendation
 Oil and filter change at the time of sampling has been noted. We advise that you inspect for the source(s) of wear. We recommend an early resample to monitor this condition. We were unable to perform a particle count due to a high concentration of particles present in this sample.

Wear
 The iron level is severe.

Contamination
 Appearance is hazy. High concentration of visible dirt/debris present in the oil.

Fluid Condition
 The AN level is acceptable for this fluid.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		PCA0096855	PCA0081541	PCA0096806
Sample Date	Client Info		11 Nov 2023	15 Aug 2023	12 Jun 2023
Machine Age	mths	Client Info	0	0	0
Oil Age	mths	Client Info	1	1	1
Oil Changed	Client Info		Changed	Changed	Changed
Sample Status			SEVERE	ABNORMAL	ABNORMAL

CONTAMINATION

	method	limit/base	current	history1	history2
Water	WC Method	>.1	NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >90	413	56	57
Chromium	ppm	ASTM D5185m >5	2	0	0
Nickel	ppm	ASTM D5185m >5	<1	0	0
Titanium	ppm	ASTM D5185m >3	<1	<1	0
Silver	ppm	ASTM D5185m >3	0	0	0
Aluminum	ppm	ASTM D5185m >7	2	0	0
Lead	ppm	ASTM D5185m >12	0	0	0
Copper	ppm	ASTM D5185m >30	1	<1	<1
Tin	ppm	ASTM D5185m >9	0	0	0
Vanadium	ppm	ASTM D5185m	0	<1	0
Cadmium	ppm	ASTM D5185m	<1	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 5	0	0	0
Barium	ppm	ASTM D5185m 5	4	0	2
Molybdenum	ppm	ASTM D5185m 5	<1	0	0
Manganese	ppm	ASTM D5185m	3	<1	<1
Magnesium	ppm	ASTM D5185m 5	<1	<1	0
Calcium	ppm	ASTM D5185m 5	5	0	2
Phosphorus	ppm	ASTM D5185m 100	76	22	37
Zinc	ppm	ASTM D5185m 25	89	15	35
Sulfur	ppm	ASTM D5185m 1500	0	4	0

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >60	4	1	2
Sodium	ppm	ASTM D5185m	5	2	0
Potassium	ppm	ASTM D5185m >20	2	0	2

FLUID CLEANLINESS


	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>1300	---	---	---
Particles >6µm	ASTM D7647	>320	---	---	---
Particles >14µm	ASTM D7647	>80	---	---	---
Particles >21µm	ASTM D7647	>20	---	---	---
Particles >38µm	ASTM D7647	>4	---	---	---
Particles >71µm	ASTM D7647	>3	---	---	---
Oil Cleanliness	ISO 4406 (c)	>17/15/13	---	---	---

FLUID DEGRADATION


	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 0.08	0.091	0.11	0.085

OIL ANALYSIS REPORT


● Ferrous Alloys



Acid Number




Viscosity @ 40°C



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	▲ MODER	NONE
Debris	scalar	*Visual	▲ HEAVY	▲ HEAVY	▲ HEAVY
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	▲ HAZY	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>.1	NEG	0.2%
Free Water	scalar	*Visual		NEG	0.2%


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 68	72.0	70.7	71.0

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------




GRAPHS


● Ferrous Alloys




Non-ferrous Metals



Viscosity @ 40°C



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : PCA0096855 **Received** : 21 Nov 2023
Lab Number : 06013981 **Diagnosed** : 24 Nov 2023
Unique Number : 10753125 **Diagnostician** : Don Baldrige
Test Package : IND 2 (Additional Tests: PrtCount)

KraftHeinz - Springfield - Plant 8311 PCA
 2035 E BENNETT
 SPRINGFIELD, MO
 US 65804
 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: