

PROBLEM SUMMARY

Sample Rating Trend




Reversing Mill

[Reversing Mill] 135140-S TEN REEL:DRV END MTR BRG WST

Drive End Circulating System

SHELL TURBO T ISO 68 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

We recommend you service the filters on this component. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS									
Sample Status			ABNORMAL	NORMAL	NORMAL				
Particles >4µm	ASTM D7647	>5000	<u> </u>						
Oil Cleanliness	ISO 4406 (c)	>19/17/14	22/17/11						

Customer Id: SDITER Sample No.: PCA0101613 Lab Number: 06015032 Test Package: PLANT



To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter			?	We recommend you service the filters on this component.

HISTORICAL DIAGNOSIS

23 Jul 2023 Diag: Don Baldridge

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



01 Apr 2023 Diag: Jonathan Hester

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



01 Jan 2023 Diag: Angela Borella

150



We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend

ISO

Reversing Mill

[Reversing Mill] 135140-S TEN REEL:DRV END MTR BRG WST

Drive End Circulating System

SHELL TURBO T ISO 68 (--- GAL)

Fluid

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Oct2021 Jan	2022 Apr2022 Jul2022	Oct2022 Jan 2023 Apr 2023 Jul 202	23 Nov2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PCA0101613	PCA0095410	PCA0095388
Sample Date		Client Info		21 Nov 2023	23 Jul 2023	01 Apr 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	Not Changd
Sample Status				ABNORMAL	NORMAL	NORMAL
WEAR METALS	S	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m		6	4	5
Chromium	ppm	ASTM D5185m		<1	0	0
Nickel	ppm	ASTM D5185m		0	0	0
Titanium	ppm	ASTM D5185m		<1	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m		2	0	<1
Lead	ppm	ASTM D5185m		0	0	0
Copper	ppm	ASTM D5185m		<1	0	0
Tin	ppm	ASTM D5185m		0	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		<1	0	0
Manganese	ppm	ASTM D5185m		0	0	<1
Magnesium	ppm	ASTM D5185m		0	0	2
Calcium	ppm	ASTM D5185m		<1	0	<1
Phosphorus	ppm	ASTM D5185m		4	0	2
Zinc	ppm	ASTM D5185m		0	2	0
Sulfur	ppm	ASTM D5185m		0	0	0
CONTAMINAN		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m		2	2	2
Sodium	ppm	ASTM D5185m		0	<1	<1
Potassium	ppm		>20	<1	0	<1
Water	%	ASTM D6304	720	NEG	NEG	NEG
			lineit/lenene			
FLUID CLEANL	IINE 55		limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>5000	<u>A</u> 31541		
Particles >6µm			>1300	1281		
Particles >14µm		ASTM D7647	>160	14		
Particles >21µm		ASTM D7647		3		
Particles >38µm		ASTM D7647	>10	0		
Particles >71μm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>19/17/14	<u>22/17/11</u>		
FLUID DEGRAD	ATION	method	limit/base	current	history1	history2

Acid Number (AN)

mg KOH/g ASTM D8045 .05

0.06


0.042

Contact/Location: BRAD ELLIS - SDITER

0.115



OIL ANALYSIS REPORT







Laboratory Sample No. Lab Number

Unique Number

Test Package : PLANT

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : PCA0101613 Received : 22 Nov 2023 : 26 Nov 2023

: 06015032 Diagnosed : 10754176 Diagnostician

: Don Baldridge

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. SDI - Steel DynamicsInc. - Heartland

Contact/Location: BRAD ELLIS - SDITER

455 West Industrial Drive Terre Haute, IN US 47802

Contact: BRAD ELLIS

brad.ellis@steeldynamics.com

T:

F:

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)