


Machine Id
GE HSK 4

Component
Gas Turbine

Fluid
AMSOIL SYN TURB ISO VG 32 (--- GAL)



DIAGNOSIS

▲ Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

▲ Contamination

There is a high amount of particulates present in the oil. The water content is negligible.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			PCA0099974	PCA0108266	PCA0099970
Sample Date	Client Info			28 Nov 2023	10 Nov 2023	17 Sep 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed	Client Info			N/A	N/A	N/A
Sample Status				ABNORMAL	ABNORMAL	NORMAL

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>15	0	0	<1
Chromium	ppm	ASTM D5185m	>4	0	0	<1
Nickel	ppm	ASTM D5185m	>2	0	0	0
Titanium	ppm	ASTM D5185m		0	0	<1
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>10	0	1	0
Lead	ppm	ASTM D5185m		0	0	<1
Copper	ppm	ASTM D5185m	>5	<1	<1	<1
Tin	ppm	ASTM D5185m	>5	0	0	1
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	<1






ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	6	0
Molybdenum	ppm	ASTM D5185m		0	0	<1
Manganese	ppm	ASTM D5185m		<1	0	<1
Magnesium	ppm	ASTM D5185m		0	0	0
Calcium	ppm	ASTM D5185m		3	3	<1
Phosphorus	ppm	ASTM D5185m		17	42	23
Zinc	ppm	ASTM D5185m		0	0	0
Sulfur	ppm	ASTM D5185m		651	750	669

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	0	0	<1
Sodium	ppm	ASTM D5185m		<1	0	<1
Potassium	ppm	ASTM D5185m	>20	0	<1	2
Water	%	ASTM D6304	>0.03	0.009	0.001	0.001
ppm Water	ppm	ASTM D6304	>300	95	12.6	3.3

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles 5-15µm	count	*NAS 1638	>16000	▲ 1746398	▲ 42115	11307
Particles 15-25µm	count	*NAS 1638	>2850	▲ 76840	1220	693
Particles 25-50µm	count	*NAS 1638	>506	▲ 17422	286	433
Particles 50-100µm	count	*NAS 1638	>90	▲ 205	0	42
Particles >100µm	count	*NAS 1638	>16	0	0	10
NAS 1638	Class	*NAS 1638	>6	>12	8	6

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.111	0.055	0.09


OIL ANALYSIS REPORT











VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.03	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	31.2	31.2	30.99
Visc @ 100°C	cSt	ASTM D445	6.22	6.26	6.22
Viscosity Index (VI)	Scale	ASTM D2270	153	155	155

SAMPLE IMAGES



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : PCA0099974 **Received** : 06 Dec 2023
Lab Number : 06026368 **Diagnosed** : 07 Dec 2023
Unique Number : 10776159 **Diagnostician** : Doug Bogart
Test Package : MOB 2 (Additional Tests: KF, KV100, PrtCountNAS, VI)

MDU-HESKETT STATION
 2035 38TH ST
 MANDAN, ND
 US 58554
 Contact: DJ STOCKWELL
 dj.stockwell@mdu.com
 T: (406)931-3562
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)