


OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



749012-310059

Component

Natural Gas Engine

PETRO CANADA DURON GEO LD 15W40 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

Metal levels are typical for a new component breaking in.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition


The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.


(GAL)		Sep2021	Mar2022 Dec2022	Feb.2023 Apr2023 Se	p2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		GFL0092010	GFL0084672	GFL0078172
Sample Date		Client Info		04 Dec 2023	18 Sep 2023	25 Apr 2023
Machine Age	hrs	Client Info		14418	13829	143791
Oil Age	hrs	Client Info		600	0	0
Oil Changed		Client Info		Changed	Changed	Not Changd
Sample Status				NORMAL	NORMAL	NORMAL
CONTAMINATI	ON	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG	NEG	NEG
WEAR METALS	3	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	7	9	5
Chromium	ppm	ASTM D5185m	>4	<1	<1	0
Nickel	ppm	ASTM D5185m	>2	1	<1	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m	>3	0	0	0
Aluminum	ppm	ASTM D5185m	>9	2	2	1
Lead	ppm	ASTM D5185m	>30	2	0	0
Copper	ppm	ASTM D5185m	>35	5	9	4
Tin	ppm	ASTM D5185m	>4	1	<1	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	50	7	10	23
Barium	ppm	ASTM D5185m	5	0	0	0
Molybdenum	ppm	ASTM D5185m	50	50	53	55
Manganese	ppm	ASTM D5185m	0	0	<1	<1
Magnesium	ppm	ASTM D5185m	560	639	625	682
Calcium	ppm	ASTM D5185m	1510	1770	1666	1650
Phosphorus	ppm	ASTM D5185m	780	821	707	837
Zinc	ppm	ASTM D5185m	870	1133	964	1034
Sulfur	ppm	ASTM D5185m	2040	2725	2897	2756
CONTAMINAN	ΓS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>+100	8	11	3
Sodium	ppm	ASTM D5185m		6	6	6
Potassium	ppm	ASTM D5185m	>20	5	<1	0
INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844		0	0	0
Nitration	Abs/cm	*ASTM D7624	>20	10.6	11.2	7.9
Sulfation	Abs/.1mm	*ASTM D7415	>30	20.6	23.4	17.8
FLUID DEGRAD	ATION	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414	>25	18.0	19.9	15.8

Base Number (BN) mg KOH/g ASTM D2896 10.2 4.7



OIL ANALYSIS REPORT








VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG


FLUID PROPERTIES		method				history2
Visc @ 100°C	cSt	ASTM D445	15.1	14.8	14.9	14.9

GRAPHS













Certificate L2367

Laboratory Sample No. Lab Number **Unique Number** Test Package : FLEET

: 06027075 : 10776866

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : GFL0092010 Received

: 06 Dec 2023 Diagnosed : 08 Dec 2023 Diagnostician : Wes Davis

GFL Environmental - 856 - Houston South

8515 Highway 6 South Houston, TX US 77083

Contact: Apolinar Zacarias pzacariascano@gflenv.com T:

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: