

### **OIL ANALYSIS REPORT**

Sample Rating Trend



# Machine Id 948011-205254

Component Natural Gas Engine

PETRO CANADA DURON GEO LD 15W40 (--- GAL)

#### DIAGNOSIS

#### Recommendation

Resample at the next service interval to monitor.

#### Wear

Metal levels are typical for a new component breaking in.

#### Contamination

There is no indication of any contamination in the oil.


#### Fluid Condition


The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

			11 11 11			
SAMPLE INFOR	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		GFL0092029	GFL0092026	GFL0048590
Sample Date		Client Info		06 Dec 2023	07 Nov 2023	07 Jul 2022
Machine Age	hrs	Client Info		57310	4989	56261
Oil Age	hrs	Client Info		600	0	0
Oil Changed		Client Info		Not Changd	Changed	Not Changd
Sample Status				NORMAL	NORMAL	NORMAL
CONTAMINAT	ION	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG	NEG	NEG
WEAR METAL	S	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	7	15	19
Chromium	ppm	ASTM D5185m	>4	<1	0	<1
Nickel	ppm	ASTM D5185m	>2	0	0	<1
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m	>3	0	0	<1
Aluminum	ppm		>9	2	2	2
Lead	ppm	ASTM D5185m		0	_ <1	- <1
Copper	ppm	ASTM D5185m	>35	0	3	1
Tin	ppm	ASTM D5185m	>4	0	0	1
Antimony	ppm	ASTM D5185m	21			
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
	ppiii			-		
ADDITIVES		method	limit/base		history1	history2
Boron	ppm	ASTM D5185m	50	23	8	9
Boron Barium	ppm ppm	ASTM D5185m ASTM D5185m	50 5	23 0	8 0	9 0
Boron		ASTM D5185m	50 5 50	23 0 51	8 0 50	9 0 53
Boron Barium Molybdenum Manganese	ppm	ASTM D5185m ASTM D5185m	50 5 50 0	23 0	8 0 50 0	9 0 53 3
Boron Barium Molybdenum	ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m	50 5 50 0 560	23 0 51	8 0 50 0 594	9 0 53
Boron Barium Molybdenum Manganese	ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	50 5 50 0	23 0 51 0	8 0 50 0	9 0 53 3
Boron Barium Molybdenum Manganese Magnesium	ppm ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	50 5 50 0 560	23 0 51 0 560 1547 727	8 0 50 0 594	9 0 53 3 886
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc	ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	50 5 50 0 560 1510	23 0 51 0 560 1547	8 0 50 0 594 1691	9 0 53 3 886 1402 787 1004
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus	ppm ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	50 5 50 0 560 1510 780	23 0 51 0 560 1547 727	8 0 50 0 594 1691 800	9 0 53 3 886 1402 787
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc	ppm ppm ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	50 5 50 0 560 1510 780 870	23 0 51 0 560 1547 727 960 2453	8 0 50 0 594 1691 800 1027	9 0 53 3 886 1402 787 1004
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur	ppm ppm ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	50 5 50 560 1510 780 870 2040 <b>limit/base</b>	23 0 51 0 560 1547 727 960 2453	8 0 50 0 594 1691 800 1027 2551	9 0 53 3 886 1402 787 1004 3056
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINAN	ppm ppm ppm ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	50 5 50 560 1510 780 870 2040 <b>limit/base</b>	23 0 51 0 560 1547 727 960 2453 current	8 0 50 0 594 1691 800 1027 2551 history1	9 0 53 3 886 1402 787 1004 3056 history2
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINAN Silicon	ppm ppm ppm ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m <b>method</b> ASTM D5185m	50 5 50 0 560 1510 780 870 2040 <b>limit/base</b> >+100	23 0 51 0 560 1547 727 960 2453 current 4	8 0 50 0 594 1691 800 1027 2551 history1 6	9 0 53 3 886 1402 787 1004 3056 history2 27
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINAN Silicon Sodium	ppm ppm ppm ppm ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m <b>method</b> ASTM D5185m ASTM D5185m	50 5 50 0 560 1510 780 870 2040 <b>limit/base</b> >+100	23 0 51 0 560 1547 727 960 2453 current 4 6 6 <1	8 0 50 0 594 1691 800 1027 2551 history1 6 7	9 0 53 3 886 1402 787 1004 3056 history2 27 2
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINAN Silicon Sodium Potassium	ppm ppm ppm ppm ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m	50 50 00 560 1510 780 870 2040 <b>limit/base</b> >+100	23 0 51 0 560 1547 727 960 2453 current 4 6 6 <1	8 0 50 0 594 1691 800 1027 2551 history1 6 7 <1	9 0 53 3 886 1402 787 1004 3056 history2 27 27 2 0
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINAN Silicon Sodium Potassium INFRA-RED	ppm ppm ppm ppm ppm ppm ppm ppm ppm TS	ASTM D5185m ASTM D5185m	50 50 0 560 1510 780 870 2040 <b>Iimit/base</b> >+100 >20	23 0 51 0 560 1547 727 960 2453 <u>current</u> 4 6 <1 current	8 0 50 0 594 1691 800 1027 2551 history1 6 7 <1 history1	9 0 53 3 886 1402 787 1004 3056 history2 27 2 2 0 bistory2
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINAN Silicon Sodium Potassium INFRA-RED Soot %	ppm ppm ppm ppm ppm ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m	50 50 0 560 1510 780 870 2040 <b>Iimit/base</b> >+100 >20	23 0 51 0 560 1547 727 960 2453 <u>current</u> 4 6 <1 <u>current</u> 0	8 0 50 0 594 1691 800 1027 2551 history1 6 7 <1 6 7 <1 0	9 0 53 3 886 1402 787 1004 3056 history2 27 2 27 2 0 history2 0
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINAN Silicon Sodium Potassium INFRA-RED Soot % Nitration	ppm ppm ppm ppm ppm ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m	50 50 00 560 1510 780 870 2040 <b>Iimit/base</b> >+100 20 <b>Iimit/base</b>	23 0 51 0 560 1547 727 960 2453 <u>current</u> 4 6 <1 current 0 8.8 19.5	8 0 50 0 594 1691 800 1027 2551 history1 6 7 <1 history1 0 10.9	9 0 53 3 886 1402 787 1004 3056 history2 27 27 27 27 2 0 history2 0 history2
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINAN Silicon Sodium Potassium INFRA-RED Soot % Nitration Sulfation	ppm ppm ppm ppm ppm ppm ppm ppm ppm ppm	ASTM D5185m ASTM D7844 *ASTM D7844	50 50 560 1510 780 870 2040 >100 >+100 >20 100 220 20 20 20 20 20 20 20 20 20 20 20	23 0 51 0 560 1547 727 960 2453 <i>current</i> 4 6 <1 <i>current</i> 0 8.8 19.5	8 0 50 0 594 1691 800 1027 2551 history1 6 7 <1 history1 0 10.9 23.0 history1	9 0 53 3 886 1402 787 1004 3056 history2 27 27 2 27 2 20 0 history2 0 12.2 23.7
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINAN Silicon Sodium Potassium INFRA-RED Soot % Nitration Sulfation	ppm ppm ppm ppm ppm ppm ppm ppm ppm ppm	ASTM D5185m ASTM D7844 *ASTM D7624 *ASTM D7414	50 50 560 1510 780 870 2040 <b>imit/base</b> >+100 220 <b>imit/base</b> >20 30 <b>imit/base</b>	23 0 51 0 560 1547 727 960 2453 <u>current</u> 4 6 <1 current 0 8.8 19.5	8 0 50 0 594 1691 800 1027 2551 history1 6 7 <1 6 7 <1 bistory1 0 10.9 23.0	9 0 53 3 886 1402 787 1004 3056 <b>history2</b> 27 2 2 0 <b>history2</b> 0 <b>history2</b> 0 12.2 23.7




## **OIL ANALYSIS REPORT**





VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPE	RTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	15.1	14.5	14.5	14.7
GRAPHS						
Ferrous Alloys						



To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Certificate L2367

T:

F: