

OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id 810039

Component **Diesel Engine**

Fluid PETRO CANADA DURON SHP 15W40 (--- LT

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

| .TR) | R) | | | | | | | | |
|------------------|----------|-------------|------------|-------------|-------------|-------------|--|--|--|
| | JATION | method | limit/base | Current | historv1 | history2 | | | |
| Sample Number | | Client Info | | GEI 0100434 | GEL 0071669 | GEL 0071662 | | | |
| Sample Date | | Client Info | | 01 Dec 2023 | 15 Nov 2023 | 15 Nov 2023 | | | |
| Machine Age | hrs | Client Info | | 5930 | 5798 | 5798 | | | |
| Oil Age | hrs | Client Info | | 845 | 713 | 713 | | | |
| Oil Changed | | Client Info | | N/A | N/A | Not Changd | | | |
| Sample Status | | | | NORMAL | NORMAL | NORMAL | | | |
| CONTAMINATI | ON | method | limit/base | current | history1 | history2 | | | |
| Fuel | | WC Method | >5 | <1.0 | <1.0 | <1.0 | | | |
| Water | | WC Method | >0.2 | NEG | NEG | NEG | | | |
| Glycol | | WC Method | | NEG | NEG | NEG | | | |
| WEAR METAL | S | method | limit/base | current | history1 | history2 | | | |
| Iron | ppm | ASTM D5185m | >100 | 3 | 2 | 10 | | | |
| Chromium | ppm | ASTM D5185m | >20 | <1 | 0 | <1 | | | |
| Nickel | ppm | ASTM D5185m | >4 | 0 | 0 | 0 | | | |
| Titanium | ppm | ASTM D5185m | | 0 | 0 | 0 | | | |
| Silver | ppm | ASTM D5185m | >3 | 0 | 0 | 0 | | | |
| Aluminum | ppm | ASTM D5185m | >20 | <1 | <1 | 3 | | | |
| Lead | ppm | ASTM D5185m | >40 | 0 | 0 | <1 | | | |
| Copper | ppm | ASTM D5185m | >330 | 0 | 0 | <1 | | | |
| Tin | ppm | ASTM D5185m | >15 | 0 | 0 | 0 | | | |
| Vanadium | ppm | ASTM D5185m | | 0 | <1 | 0 | | | |
| Cadmium | ppm | ASTM D5185m | | 0 | 0 | 0 | | | |
| ADDITIVES | | method | limit/base | current | history1 | history2 | | | |
| Boron | ppm | ASTM D5185m | 0 | 4 | 4 | 2 | | | |
| Barium | ppm | ASTM D5185m | 0 | 0 | 0 | 0 | | | |
| Molybdenum | ppm | ASTM D5185m | 60 | 62 | 63 | 64 | | | |
| Manganese | ppm | ASTM D5185m | 0 | 0 | 0 | <1 | | | |
| Magnesium | ppm | ASTM D5185m | 1010 | 923 | 920 | 1008 | | | |
| Calcium | ppm | ASTM D5185m | 1070 | 1010 | 1054 | 1083 | | | |
| Phosphorus | ppm | ASTM D5185m | 1150 | 966 | 1056 | 905 | | | |
| Zinc | ppm | ASTM D5185m | 1270 | 1193 | 1211 | 1263 | | | |
| Sulfur | ppm | ASTM D5185m | 2060 | 3185 | 3094 | 3251 | | | |
| CONTAMINAN | TS | method | limit/base | current | history1 | history2 | | | |
| Silicon | ppm | ASTM D5185m | >25 | 2 | 2 | 3 | | | |
| Sodium | ppm | ASTM D5185m | | <1 | 2 | 3 | | | |
| Potassium | ppm | ASTM D5185m | >20 | 1 | 2 | 4 | | | |
| INFRA-RED | | method | limit/base | current | history1 | history2 | | | |
| Soot % | % | *ASTM D7844 | >3 | 0.4 | 0.3 | 0.7 | | | |
| Nitration | Abs/cm | *ASTM D7624 | >20 | 5.4 | 5.1 | 6.7 | | | |
| Sulfation | Abs/.1mm | *ASTM D7415 | >30 | 17.5 | 17.2 | 18.8 | | | |
| FLUID DEGRAD | DATION | method | limit/base | current | history1 | history2 | | | |
| Oxidation | Abs/.1mm | *ASTM D7414 | >25 | 12.6 | 12.5 | 13.4 | | | |
| Base Number (BN) | mg KOH/g | ASTM D2896 | 9.8 | 8.7 | 8.8 | 8.7 | | | |



OIL ANALYSIS REPORT





| VISUAL | | method | | | | history2 |
|------------------|--------|-----------|------------|---------|----------|----------|
| White Metal | scalar | *Visual | NONE | NONE | NONE | NONE |
| Yellow Metal | scalar | *Visual | NONE | NONE | NONE | NONE |
| Precipitate | scalar | *Visual | NONE | NONE | NONE | NONE |
| Silt | scalar | *Visual | NONE | NONE | NONE | NONE |
| Debris | scalar | *Visual | NONE | NONE | NONE | NONE |
| Sand/Dirt | scalar | *Visual | NONE | NONE | NONE | NONE |
| Appearance | scalar | *Visual | NORML | NORML | NORML | NORML |
| Odor | scalar | *Visual | NORML | NORML | NORML | NORML |
| Emulsified Water | scalar | *Visual | >0.2 | NEG | NEG | NEG |
| Free Water | scalar | *Visual | | NEG | NEG | NEG |
| FLUID PROPE | RTIES | method | limit/base | current | history1 | history2 |
| Visc @ 100°C | cSt | ASTM D445 | 15.4 | 14.1 | 14.1 | 14.1 |
| GRAPHS | | | | | | |





Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: