


OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



SCOF [98589727] VACUUM PUMP 3

Component **Vacuum Pump**

ISO 100 (--- QTS)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

Миу2021 Aug2021 Jan2022 Nov2022 Миу2023 Aug2023						
SAMPLE INFORM	ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PCA0101652	PCA0100109	PCA0100134
Sample Date		Client Info		16 Oct 2023	10 Aug 2023	22 Jun 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		Filtered	Filtered	Filtered
Sample Status				NORMAL	ATTENTION	ABNORMAL
CONTAMINATIO	NC	method	limit/base	current	history1	history2
Water		WC Method	>.1	NEG	NEG	NEG
WEAR METALS	;	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>20	0	2	2
Chromium	ppm	ASTM D5185m	>20	0	<1	0
Nickel	ppm	ASTM D5185m	>20	0	0	0
Titanium	ppm	ASTM D5185m		0	<1	<1
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>20	0	<1	<1
Lead	ppm	ASTM D5185m	>20	0	<1	0
Copper	ppm	ASTM D5185m	>20	0	<1	0
Tin	ppm	ASTM D5185m	>20	0	<1	0
Vanadium	ppm	ASTM D5185m		0	<1	0
Cadmium	ppm	ASTM D5185m		0	<1	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	14
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	<1	0
Magnesium	ppm	ASTM D5185m		<1	6	12
Calcium	ppm	ASTM D5185m		0	0	3
Phosphorus	ppm	ASTM D5185m		495	299	352
Zinc	ppm	ASTM D5185m		0	13	25
Sulfur	ppm	ASTM D5185m		1468	1340	1424
CONTAMINANT	S	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	2	5	4
Sodium	ppm	ASTM D5185m		2	2	1
Potassium	ppm	ASTM D5185m	>20	2	3	<1
FLUID CLEANLI	NESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>1300	511	1009	▲ 1696
Particles >6µm		ASTM D7647	>320	148	4 03	▲ 707
Particles >14μm		ASTM D7647	>80	17	30	9 0
Particles >21μm		ASTM D7647	>20	7	4	23
Particles >38µm		ASTM D7647	>4	1	0	1
Particles >71µm		ASTM D7647	>3	1	0	0
Oil Cleanliness		ISO 4406 (c)	>17/15/13	16/14/11	▲ 17/16/12	△ 18/17/14
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
A siel Nivershau (ANI)		AOTM D0045		0.007	0.00	0.054

Acid Number (AN)

mg KOH/g ASTM D8045

0.087

0.054



OIL ANALYSIS REPORT







Certificate L2367

Laboratory Sample No.

Lab Number **Unique Number**

: PCA0101652 : 06036789 : 10792018

120

110

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : 15 Dec 2023 Recieved Diagnosed

: 20 Dec 2023 Diagnostician : Jonathan Hester

Aug10/23

(B1.00 0.80

Ĕ0.60 흔 0.40 ≥ 0.20 ₽ 0.00 L

Test Package : IND 2 (Additional Tests: PrtCount) To discuss this sample report, contact Customer Service at 1-800-237-1369.

Jan 4/22

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

KraftHeinz - Springfield - Plant 8311 PCA

2035 E BENNETT SPRINGFIELD, MO

US 65804

Contact: Service Manager

T: F: