


OIL ANALYSIS REPORT

Sample Rating Trend







Machine Id **749000**

Component

Natural Gas Engine

PETRO CANADA DURON GEO LD 15W40 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

Metal levels are typical for a new component breaking in.

Contamination

There is no indication of any contamination in the


Fluid Condition


The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

GAL)		Feb 2022 A	pr2022 Jul2022 Jan	2023 Apr2023 Jun2023	Oct2023	
SAMPLE INFOR	RMATION	method	limit/base	current	history1	history2
Sample Number		Client Info		GFL0092052	GFL0084652	GFL0084719
Sample Date		Client Info		14 Dec 2023	17 Oct 2023	16 Jun 2023
Machine Age	hrs	Client Info		14860	143304	0
Oil Age	hrs	Client Info		600	0	0
Oil Changed		Client Info		Changed	Changed	Changed
Sample Status				NORMAL	ABNORMAL	SEVERE
CONTAMINAT	ΓΙΟΝ	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG	NEG	NEG
Glycol		WC Method				0.10
WEAR METAL	_S	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	8	8	15
Chromium	ppm	ASTM D5185m	>4	<1	<1	1
Nickel	ppm	ASTM D5185m	>2	0	0	0
Titanium	ppm	ASTM D5185m		0	<1	0
Silver	ppm	ASTM D5185m	>3	0	0	0
Aluminum	ppm	ASTM D5185m	>9	2	2	2
Lead	ppm	ASTM D5185m	>30	1	<1	1
Copper	ppm	ASTM D5185m	>35	<1	1	3
Tin	ppm	ASTM D5185m	>4	0	0	<1
Vanadium	ppm	ASTM D5185m		<1	<1	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	50	18	7	33
Barium	ppm	ASTM D5185m	5	0	0	0
Molybdenum	ppm	ASTM D5185m	50	52	54	74
Manganese	ppm	ASTM D5185m	0	<1	<1	1
Magnesium	ppm	ASTM D5185m	560	550	558	570
Calcium	ppm	ASTM D5185m	1510	1541	1649	1469
Phosphorus	ppm	ASTM D5185m	780	734	642	783
Zinc	ppm	ASTM D5185m	870	962	962	934
Sulfur	ppm	ASTM D5185m	2040	2443	2326	2821
CONTAMINAN	NTS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>+100	4	4	13
Sodium	ppm	ASTM D5185m		18	<u>^</u> 70	△ 319
Potassium	ppm	ASTM D5185m	>20	14	△ 61	<u> </u>
INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844		0.1	0	0.1
Nitration	Abs/cm	*ASTM D7624	>20	9.1	10.3	8.1
Sulfation	Abs/.1mm	*ASTM D7415	>30	19.4	20.1	19.6
FLUID DEGRA	AOITAD.	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414	>25	16.7	17.7	15.9
Base Number (BN)		ASTM D2896		6.0	5.1	10.7
()	0 - 3					



OIL ANALYSIS REPORT








VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG


FLUID PROPI	ERTIES	method				history2
Visc @ 100°C	cSt	ASTM D445	15.1	14.9	15.3	14.7

GRAPHS













Certificate L2367

Laboratory Sample No. Lab Number Unique Number : 10795105 Test Package : FLEET

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : GFL0092052 : 06039876

Recieved Diagnosed Diagnostician : Wes Davis

: 19 Dec 2023 : 20 Dec 2023 GFL Environmental - 856 - Houston South

8515 Highway 6 South Houston, TX US 77083

Contact: Gino Griego

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:

F: