

OIL ANALYSIS REPORT

Sample Rating Trend





Machine Id 834055 Component Natural Gas Engine Fluid NOT GIVEN (--- GAL)

Recommendation

Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample.

Wear

Metal levels are typical for a new component breaking in.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition


The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

		0ct202			x2023	la ta ta mu O
SAMPLE INFORI	VIATION		limit/base	current	history1	history2
Sample Number		Client Info		GFL0102433	GFL0102556	GFL0098585
Sample Date		Client Info		20 Dec 2023	29 Nov 2023	21 Nov 2023
Machine Age	hrs	Client Info		716	585	532
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	Not Changd	N/A
Sample Status				NORMAL	NORMAL	NORMAL
CONTAMINAT	ION	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG	NEG	NEG
WEAR METAL	S	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	52	47	48
Chromium	ppm	ASTM D5185m	>4	<1	<1	<1
Nickel	ppm	ASTM D5185m	>2	<1	<1	2
Titanium	ppm	ASTM D5185m		0	0	<1
Silver	ppm	ASTM D5185m	>3	0	0	<1
Aluminum	ppm	ASTM D5185m	>9	4	4	2
Lead	ppm	ASTM D5185m	>30	2	<1	1
Copper	ppm	ASTM D5185m	>35	21	21	24
Tin	ppm	ASTM D5185m	>4	2	1	2
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	<1
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		4	6	8
Barium	ppm	ASTM D5185m		3	0	0
Molybdenum	ppm	ASTM D5185m		54	51	53
Manganese	ppm	ASTM D5185m		14	12	14
Magnesium	ppm	ASTM D5185m		873	740	772
Calcium	ppm	ASTM D5185m		1298	1127	1216
Phosphorus	ppm	ASTM D5185m		735	632	613
Zinc	ppm	ASTM D5185m		965	869	892
Sulfur	ppm	ASTM D5185m		2360	2324	2372
CONTAMINAN	TS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>+100	32	32	37
Sodium	ppm	ASTM D5185m		4	4	<1
Potassium	ppm	ASTM D5185m	>20	1	4	3
INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844		0	0	0
Nitration	Abs/cm	*ASTM D7624	>20	12.8	12.6	12.7
Sulfation	Abs/.1mm	*ASTM D7415	>30	24.4	23.1	22.5
FLUID DEGRA		method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414	>25	23.2	21.7	20.9
Base Number (BN)	mg KOH/g	ASTM D2896		3.3	3.5	4.6



OIL ANALYSIS REPORT

VISUAL



NONE NONE NONE NONE NONE NORML NORML NORML
NONE NONE NONE NONE NORML NORML NEG
NONE NONE NONE NORML NORML NEG
NONE NORML NORML NORML NEG
NONE NORML NORML NORML
NONE NORML NORML NEG
NORML NORML NEG
NEG
NEG
NEG
history2
14.2
17.2
Harrison 1 Route 29 onville, M
•

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: BRYAN SWANSON - GFL837

F: