


OIL ANALYSIS REPORT

Sample Rating Trend







Machine Id 2615C Component

Natural Gas Engine

PETRO CANADA DURON GEO LD 15W40 (12 GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition


The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.


(12 GAL)						
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		GFL0088503	GFL0088522	GFL0088567
Sample Date		Client Info		04 Jan 2024	03 Oct 2023	17 Jul 2023
Machine Age	hrs	Client Info		10430	10430	535
Oil Age	hrs	Client Info		501	478	535
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL
CONTAMINAT	ION	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG	NEG	NEG
WEAR METAL:	S	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	5	7	6
Chromium	ppm	ASTM D5185m	>4	<1	<1	<1
Nickel	ppm	ASTM D5185m	>2	0	0	<1
Titanium	ppm	ASTM D5185m		0	<1	<1
Silver	ppm	ASTM D5185m	>3	0	<1	0
Aluminum	ppm	ASTM D5185m	>9	2	<1	<1
Lead	ppm	ASTM D5185m	>30	0	1	<1
Copper	ppm	ASTM D5185m	>35	<1	<1	<1
Tin	ppm	ASTM D5185m	>4	<1	<1	<1
Vanadium	ppm	ASTM D5185m		0	0	<1
Cadmium	ppm	ASTM D5185m		0	<1	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	50	13	14	14
Barium	ppm	ASTM D5185m	5	0	0	1
Molybdenum	ppm	ASTM D5185m	50	51	57	50
Manganese	ppm	ASTM D5185m	0	<1	<1	<1
Magnesium	ppm	ASTM D5185m	560	571	731	552
Calcium	ppm	ASTM D5185m	1510	1524	1944	1658
Phosphorus	ppm	ASTM D5185m	780	716	849	692
Zinc	ppm	ASTM D5185m	870	958	1201	962
Sulfur	ppm	ASTM D5185m	2040	2413	3275	2869
CONTAMINAN	TS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>+100	4	5	4
Sodium	ppm	ASTM D5185m		9	9	8
Potassium	ppm	ASTM D5185m	>20	0	2	2
INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844		0	0	0
Nitration	Abs/cm	*ASTM D7624	>20	10.3	9.5	10.4
Sulfation	Abs/.1mm	*ASTM D7415	>30	20.8	19.5	20.2
FLUID DEGRAD	DATION	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414	>25	17.7	16.5	17.6
Daga Number (DNI)				F 4	F 7	T 4

Base Number (BN) mg KOH/g ASTM D2896 10.2 5.4



OIL ANALYSIS REPORT








VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG


FLUID PROPI	ERTIES	method				history2
Visc @ 100°C	cSt	ASTM D445	15.1	14.7	14.8	14.7

GRAPHS













Certificate L2367

Laboratory Sample No. Lab Number **Unique Number** Test Package : FLEET

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : GFL0088503 : 06051401

: 10817350

To discuss this sample report, contact Customer Service at 1-800-237-1369.

Recieved : 04 Jan 2024 Diagnosed Diagnostician

: Don Baldridge

: 05 Jan 2024

GFL Environmental - 017 - Durham 148 Stone Park Court Durham, NC US 27703

Contact: Shane Parks shane.parks@gflenv.com T: (919)596-1363

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: (919)598-1852