


# OIL ANALYSIS REPORT

Sample Rating Trend

FUEL

Area  
**INDEPENDENCE**  
Machine Id  
**Unit 05 DB200105E**  
Component  
**Natural Gas Engine**  
Fluid  
**PETRO CANADA DURON MONOGRADE HD 40W (250 GAL)**



## DIAGNOSIS

- Recommendation**  
No corrective action is recommended at this time. Resample at the next service interval to monitor.
- Wear**  
All component wear rates are normal.
- Contamination**  
Light fuel dilution occurring.
- Fluid Condition**  
The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>PCA0097009</b>	PCA0097022	PCA0097025
Sample Date	Client Info	<b>03 Jan 2024</b>	05 Dec 2023	12 Oct 2023
Machine Age	hrs	<b>2626</b>	2584	2259
Oil Age	hrs	<b>2626</b>	2584	2259
Oil Changed	Client Info	<b>Not Chngd</b>	Not Chngd	Not Chngd
Sample Status		<b>MARGINAL</b>	MARGINAL	MARGINAL

## CONTAMINATION

method	limit/base	current	history1	history2
Water	WC Method >0.1	<b>NEG</b>	NEG	NEG

## WEAR METALS

method	limit/base	current	history1	history2
Iron	ppm ASTM D5185m >50	<b>10</b>	9	8
Chromium	ppm ASTM D5185m >4	<b>&lt;1</b>	<1	<1
Nickel	ppm ASTM D5185m >2	<b>&lt;1</b>	0	0
Titanium	ppm ASTM D5185m	<b>&lt;1</b>	0	0
Silver	ppm ASTM D5185m >3	<b>0</b>	0	0
Aluminum	ppm ASTM D5185m >9	<b>2</b>	2	<1
Lead	ppm ASTM D5185m >30	<b>2</b>	2	<1
Copper	ppm ASTM D5185m >35	<b>2</b>	2	3
Tin	ppm ASTM D5185m >4	<b>2</b>	<1	<1
Vanadium	ppm ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm ASTM D5185m	<b>&lt;1</b>	0	0

## ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm ASTM D5185m	<b>6</b>	5	4
Barium	ppm ASTM D5185m	<b>0</b>	0	0
Molybdenum	ppm ASTM D5185m	<b>7</b>	4	3
Manganese	ppm ASTM D5185m	<b>&lt;1</b>	0	0
Magnesium	ppm ASTM D5185m	<b>929</b>	868	785
Calcium	ppm ASTM D5185m	<b>1076</b>	1039	958
Phosphorus	ppm ASTM D5185m	<b>1015</b>	983	924
Zinc	ppm ASTM D5185m	<b>1293</b>	1220	1070
Sulfur	ppm ASTM D5185m	<b>3426</b>	3155	2467

## CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185m >+100	<b>6</b>	4	5
Sodium	ppm ASTM D5185m	<b>0</b>	<1	4
Potassium	ppm ASTM D5185m >20	<b>2</b>	1	0
Fuel	% ASTM D3524 >4.0	<b>▲ 2.7</b>	▲ 3.1	▲ 2.9

## INFRA-RED


method	limit/base	current	history1	history2
Soot %	% *ASTM D7844	<b>0</b>	0	0
Nitration	Abs/cm *ASTM D7624 >20	<b>4.5</b>	4.5	4.4
Sulfation	Abs/.1mm *ASTM D7415 >30	<b>13.4</b>	13.4	13.4

## FLUID DEGRADATION


method	limit/base	current	history1	history2
Oxidation	Abs/.1mm *ASTM D7414 >25	<b>7.2</b>	7.3	7.2
Acid Number (AN)	mg KOH/g ASTM D8045	<b>1.18</b>	1.07	1.24
Base Number (BN)	mg KOH/g ASTM D2896 8.5	<b>8.69</b>	8.45	7.65

# OIL ANALYSIS REPORT


## Fuel Dilution




## Acid Number



## Base Number



## Viscosity @ 100°C




VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	14.4	<b>13.0</b>	13.1

## GRAPHS


### Iron (ppm)




### Lead (ppm)




### Aluminum (ppm)




### Chromium (ppm)




### Copper (ppm)




### Silicon (ppm)



### Viscosity @ 100°C



### Base Number



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : PCA0097009 **Received** : 08 Jan 2024  
**Lab Number** : 06055007 **Diagnosed** : 12 Jan 2024  
**Unique Number** : 10820956 **Diagnostician** : Jonathan Hester  
**Test Package** : MOB 2 ( Additional Tests: FuelDilution, PercentFuel )

**Magellan Midstream LP - Independence**  
 836 South Rosser Road  
 Independence, KS  
 US 67301  
 Contact: Heath James  
 heath.james@magellanlp.com  
 T: (620)779-2040  
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)